

From Structure	To Structure	Controlling Weather Case	Clearance Infraction (ft)	Description	G.O. 95 Required Clearance (ft.)	PG&E Required Clearance (ft.)	Existing Minimum Clearance (ft.)	New Minimum Clearance (ft.)
16/77	17/78	185°F Bare	-0.87	Transmission Foreign Xing	10	13.5	9.13	13.80
17/79	17/80	185°F Bare	-0.09	Ground	27	28	26.91	30.51
18/84	18/85	185°F Bare	-1.23	Ground	27	28	25.77	39.25