

From Structure	To Structure	Controlling Weather Case	Clearance Infraction (ft)	Description	G.O. 95 Required Clearance (ft.)	PG&E Required Clearance (ft.)	Existing Minimum Clearance (ft.)	New Minimum Clearance (ft.)
13/62	13/63	185°F Bare	-5.70	Transmission Foreign Xing	10	13.5	4.3	16.28