From:Dietz, SidneySent:3/11/2013 4:42:16 PMTo:Campbell, Michael (Michael.Campbell@cpuc.ca.gov)Cc:Sec:Bcc:FW: Gas Incident at 195 Shawnee Street, San Francisco (3/11)

fyi

From: Redacted
Sent: Monday, March 11, 2013 10:48 AM
To: Dietz, Sidney
Subject: FW: Gas Incident at 195 Shawnee Street, San Francisco (3/11)

From: Redacted
Sent: Monday, March 11, 2013 10:46 AM
To: UO EP Gas Incident Notify
Cc: Redacted
Subject: RE: Gas Incident at 195 Shawnee Street, San Francisco (3/11)

All:

I have got a couple of questions regarding Redacted I feel silly because I spoke to Gas Control for further clarification after the incident and Redacted is the name of the GSR that was on-site! The pages we get can be cryptic at times, but this was a learning experience for me as well.

I apologize about any confusion. If you have any further questions, please do not hesitate to ask.

Best,

Redacted

Redacted

Senior Compliance Analyst | Gas Operations Support (DRU)

Redacted

Fro	m: Redacted	
Sent: Monday, March 11, 2013 7:30 AM		
	UO EP Gas Incident Notify	
Cc:	Redacted	

Subject: Gas Incident at 195 Shawnee Street, San Francisco (3/11)

At approximately 4:00 am this morning, at 195 Shawnee Street, San Francisco, a car accident severed a PG&E riser. Gas was released as a result. The SFFD stopped the blowing gas with a redwood plug at the service (PG&E is still gathering information regarding the time this occurred). A PG&E GSR wing quock was on site at 4:38 AM. The riser was a single service riser and one customer was out of service as a result of the incident. A Channel 4 News Helicopter was seen around 5:20 AM. There were no injuries, fatalities, and no ignition. Damage is less than \$50,000. Reportable due to media on site.

If you have further questions, please do not hesitate to ask.

Best,

Redacted

Redacted

Senior Compliance Analyst | Gas Operations Support (DRU)

Redacted