

**PACIFIC GAS AND ELECTRIC COMPANY  
Data Response**

PG&E Data Request No.:	CPUC_001-Q01-8		
PG&E File Name:	GenReq_DR_CPUC_001-Q5		
Request Date:	February 21, 2013	Requester DR No.:	CPUC-PG&E #5
Date Sent:	March 7, 2013	Requesting Party:	CPUC Legal Division
Respondent:	Jon Eric Thalman (Director, Electric Asset Management, Regulatory Strategy)	Requester:	Traci Bone
Respondent Direct Supervisor:	PJ Martinez (Vice President, Electric Asset Management)		

**QUESTION 5**

For transmission facilities designated as partially under CAISO control and partially under IOU control, where does PG&E document the percentage split?

**ANSWER 5**

PG&E is not aware of any PG&E electric transmission facilities that are designated as partially under CAISO control and partially under IOU control. Within a substation, CAISO and non-CAISO controlled facilities can exist. In the case of substations, individual substation components such as busses, circuit breakers, and switches are identified in the CAISO Transmission Register. No substation components have a partial designation.