

Energy Storage Valuation Tool Draft Results

*Investigation of Cost-Effectiveness Potential for Select CPUC Inputs
and Storage Use Cases in 2015 and 2020*

Ben Kaun & Stella Chen
EPRI Energy Storage Program
CPUC Storage OIR Workshop (R.10-12-007)
3-25-13

My Garage



My Garage – An Asset Utilization Case Study



New Industries are Emerging to Address Low Asset Utilization

- Underutilized assets leave a lot of money on the table
- Improved communication and information has lowered transaction costs and enabled new markets





Photo by: Ben Kaun

EPRI | ELECTRIC POWER
RESEARCH INSTITUTE


Peak Loads Cause Utilization Issues for Electric Systems

- Not just generation, but the entire T&D delivery system
- Storage could shift load from off-peak to on-peak load periods to avoid additional peak generation and T&D delivery system



Energy Storage Can Help



- Not just generation, but the entire T&D delivery system
- Storage could shift load from off-peak to on-peak load periods to avoid additional peak generation and T&D delivery system



The Bottle Opener – An Elegant Tool




The Bottle Opener - Alternatives exist, but they are less well-suited




Other options are awkward and may damage the tool itself

Frequency Regulation – A niche, challenging service for conventional grid assets



Slow Ramping of Conventional Generator



Flywheel / Battery Energy Storage Example

Sources Kirby, B. "Ancillary Services: Technical and Commercial Insights." Wartsilla, July, 2007. pg. 13


- Fossil generator has slower response and ramp than required, and has opportunity cost of lost energy sales
- Storage can provide not only its generating capacity, but also its load to balance the system frequency
- FERC755 (Regulation Pay-for-performance) is planned for implementation in 2013 and may increase current CAISO Regulation prices when implemented

This is a High Value Service for Storage.

Storage value lies where it has a strong competitive advantage vs. conventional assets

- Use charging and discharging to simultaneously address both under (off-peak) and over-utilization (peak) of grid assets (T&D deferral & System capacity)
- Create value for storage charging, speed, and accuracy (Regulation)

Example of Distribution Energy Storage Annual Revenue by Service



- Value for energy time-shift (arbitrage) is comparatively low

Today's Proposed Agenda

- Introduction to EPRI
- Background
- Analytical Process
- **Discussion Break**
- Model
- Input Discussion Preface
- Performed Use Case Inputs and Results
 - #1: Bulk Storage (Peaker Substitution)
 - #2: Ancillary Services (Regulation) - only
- **Discussion Break / Lunch**
- Performed Use Case Inputs and Results
 - #3: Distributed Storage sited at Utility Substation
- Conclusions & Next Steps
- **Discussion**

EPRI Introduction

The Electric Power Research Institute (EPRI)




- Independent, non-profit, **collaborative** research institute, with full spectrum industry coverage
 - *Nuclear*
 - *Generation*
 - *Power Delivery & Utilization*
 - *Environment & Renewables*
- Major offices in Palo Alto, CA; Charlotte, NC; and Knoxville, TN




Technically informing regulatory / policy-makers fits within EPRI's mission

EPRI Energy Storage Program Mission


- Facilitate the development and implementation of storage options for the grid.
 - Understanding storage technologies
 - Identifying and calculating the impacts and value of storage
 - Specification and testing of storage products
 - Implementation and deployment of storage systems



Storage costs are falling with manufacturing investment



Creating a Complete Storage Product



Storage Technologies

- Define duty cycle and expectations for life and efficiency
- Characterize performance in different regimes

Power Conditioning System


- Define critical functions and performance levels
- Test capabilities to understand optimal performance

Product Integration

- Guidelines for integration of components to ensure proper performance
- Test and evaluate product as a whole

Acquiring complete, working systems has been the most challenging part of energy storage efforts to date

Grid Deployment and Integration



Field Deployment

- Installation, operations, and disposal best practices
- Siting and permitting issues
- Safety and emergency protocols

Grid Integration

- Physical interconnection and protection protocols
- Methods for understanding the effects on the distribution system

Control and Dispatch

- Communication and control protocol
- SGIP and cybersecurity
- Developing optimal dispatch algorithms

**Interconnection of storage to the grid
is still relatively poorly understood**


Focus for Today's Presentation

- There are many areas of ongoing research to enable grid-ready energy storage
- **Today we are discussing one part: storage value analysis (under specific assumptions)**




Background / Analytical Process

Overview of this Analytical Process



Overview of Process



Overview of EPRI Storage Cost-Effectiveness Methodology

Step 1a: Grid Problem / Solution Concepts

Define quantifiable services storage can provide

Step 1b: Grid Service Requirements

Step 2: Feasible Use Cases

Understand “first-order” cost-effectiveness of quantifiable benefits

Step 3: Grid Impacts and Incidental Benefits

Understand storage impact on electric system/environment

Step 4: Energy Storage Business Cases

Investigate impact of policies, business models, etc.

EPRI Storage Cost-Effectiveness Methodology

Step 1a: Grid Problem / Solution Concepts

Define quantifiable services storage can provide

Step 1b: Grid Service Requirements

Step 2: Feasible Use Cases

Understand “first-order” cost-effectiveness of quantifiable benefits

Not Included in Today’s Analysis

EPRI Storage Cost-Effectiveness Methodology

Step 1a: Grid Problem / Solution Concepts

Step 1b: Grid Service Requirements

Define quantifiable services storage can provide

 **Step 2: Feasible Use Cases**

Focus of this Analysis

Not Included in Today's Analysis

Overview of Step 2: Feasible Use Cases

- **Simulate energy storage use case operation** to address multiple grid services with quantifiable technical requirements and benefits
 - Prioritize serving long-term commitments (e.g. multi-year asset deferral over a day-ahead market opportunity)
 - Constrain operation by storage technical limitations
 - Co-optimize dispatch in the markets to maximize benefits
- **Total Resource Cost (TRC) test approach** – focus on aggregate (“stacked”) value, ignore stakeholders & transaction costs
 - Ignore bulk system and environmental impacts
 - Ignore policy incentives and monetization restrictions

Understand which use case assumptions (technology, site, etc.) may make storage cost-effective, and which inputs are important.

CPUC Use Cases

Use Cases	Categories
Transmission-Connected Energy Storage	Bulk Storage System
	Ancillary Services
	On-Site Generation Storage
	On-Site Variable Energy Resource Storage
Distribution-Level Energy Storage	Distributed Peaker
	Distributed Storage Sited at Utility Substation
	Community Energy Storage
Demand-Side (Customer-Sited) Energy Storage	Customer Bill Management
	Customer Bill Management w/ Market Participation
	Behind the Meter Utility Controlled
	Permanent Load Shifting
	EV Charging

CPUC Use Cases Investigated in the Analysis

Use Cases	Categories	
Transmission-Connected Energy Storage	Bulk Storage System (aka Peaker Substitution)	★
	Ancillary Services	★
	On-Site Generation Storage	
	On-Site Variable Energy Resource Storage	
Distribution-Level Energy Storage	Distributed Peaker	
	Distributed Storage Sited at Utility Substation	★
	Community Energy Storage	
Demand-Side (Customer-Sited) Energy Storage	Customer Bill Management	
	Customer Bill Management w/ Market Participation	
	Behind the Meter Utility Controlled	
	Permanent Load Shifting	
	EV Charging	

Focus limited due to project resource constraints

Use Cases Defined by Quantifiable Grid Services Addressed



Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis		
		Bulk-"Peaker Sub"	Ancillary Services	Dist. Sub. Storage
Energy	Electric Supply Capacity	X		X
	Electric Energy Time-Shift	X		X
A/S	Frequency Regulation	X	X	X
	Spinning Reserve	X		X
	Non-Spinning Reserve	X		X
Transmission	Transmission Upgrade Deferral			
	Transmission Voltage Support			
Distribution	Distribution Upgrade Deferral			X
	Distribution Voltage Support			
Customer	Power Quality			
	Power Reliability			
	Retail Demand Charge Mgmt			
	Retail Energy Time-Shift			

**Other services and benefits may exist –
but they may be indirect or difficult to quantify**

Discussion Break

Energy Storage Valuation Tool Model

What is the Energy Storage Valuation Tool (ESVT) ?

Transparent, user-friendly, CBA tool to assess and communicate energy storage cost-effectiveness in different use cases

- Customizable storage **project lifecycle financial analysis**
- Includes **pre-loaded defaults** for energy storage service requirements, prioritization, values, storage technologies
- **Simulates use case cost-effectiveness** with Total Resource Cost (TRC) approach (stacks benefits across stakeholders)
- **Multi-stakeholder** services/benefits: Generation, Transmission, Distribution, Customer
- **Transparent model** approach with Analytica™ software - model / input transparency through influence diagrams

What is the Energy Storage Valuation Tool (ESVT) ?

Transparent, user-friendly, CBA tool to assess and communicate energy storage cost-effectiveness in different use cases

The screenshot displays the 'Energy Storage Valuation Tool 3.1' interface, organized into four main steps:

- Step 1: Select Grid Services for Analysis**
 - Enable Optimization: Yes
 - ISO/RTO/Service Area: CAISO: 2011
 - Services Selection
- Step 1b.: Define Grid Service Requirements**
 - System Market Inputs
 - Transmission Inputs
 - Distribution Inputs
 - Customer Premise Inputs
- Step 2: Select Financial and Economic Assumptions**
 - Ownership type: IOU
 - Discount Rate: Calc
 - Financial and Economic Inputs
- Step 3: Select Energy Storage System Performance Characteristics and Costs**
 - Technology: Li-Ion: 1 MW/4 Hour
 - Discharge Duration (Hours): 4
 - Discharge Capacity (kW): 1000
 - Storage System Capital Costs (\$): \$3,600,000
 - Define Custom Storage System (Optional)
 - Storage System Capital Co. (\$/kW): \$3,600
- Step 4: Calculate Results**
 - Calc All
 - NPV Cost vs. Benefit: Calc
 - Annual Services Revenue (\$): Calc
 - Daily Revenue (\$): Calc
 - Daily Dispatch (kWh): Calc
 - Financial Results
 - Technical Results
 - Service Specific Results
 - Model Details

Strengths and Current Limitations of ESVT

- Strengths


- Quick to setup and run analyses – dozens of input parameters, not hundreds
- Simulates storage optimal dispatch – provides insights into cost-effective use cases and relative importance of inputs
- Designed specifically to incorporate storage cost / performance parameters

- Limitations

- No system price or generators impacts measured – does not simulate the effects of different storage deployment levels
- No consideration of environmental / GHG impacts

Discussion of Inputs to CPUC Analysis

Review of Analysis Inputs Process



Review of Analysis Inputs Process

- December 2012 – Discussion of Use Cases for Initial Focus
 - Bulk – Peaker Substitution, A/S only
 - Distribution – Substation-sited
- Jan-Feb 2013 – CPUC request of 50 runs (prioritized)
- Jan-Mar 2013 – Weekly input clarification meetings with CPUC and 2 preliminary analysis results with stakeholder group
- March 2013 – Approximately 30 runs performed (time/budget constraints) with selected additional sensitivities

Overview of Input Worksheet provided by CPUC

- File: "Storage CE Input Template V12"

The screenshot shows an Excel spreadsheet titled "Storage CE Input Template V12 (2).xlsx" with several callout boxes and arrows pointing to specific data columns:

- Global (Financial) / Fuel Assumptions by Run:** Points to the "Case" column.
- Storage Tech Cost / Performance Assumptions:** Points to the "Technology" column.
- Prioritized Modeling Runs Requested by CPUC:** Points to the "Modeling Runs" column.
- Conventional Tech (CT) Cost / Performance Assumptions:** Points to the "EPRM Model Applicable?" and "XEMA Model Applicable?" columns.
- Market / Benefit Assumptions:** Points to the "Nameplate Capacity (MW)" and "Duration (h)" columns.

Project	Case	EPRM Model Applicable?	XEMA Model Applicable?	Technology	Nameplate Capacity (MW)	Duration (h)	Cost of New Entry (CONE)	Derated Capacity (MW)	Resource Balance Year	Market Scenario Name
					50	2	E3 DER Avoided Cost Model	25	2020	2020 Base
					50	2	E3 DER Avoided Cost Model	25	2020	2020 Base, 2.0x P4P
					50	3	E3 DER Avoided Cost Model	37.5	2020	2020 Base
					50	4	E3 DER Avoided Cost Model	50	2020	2020 Base
					50	4	E3 DER Avoided Cost Model	44	2020	2020 Base
							ESVT Derived - Version 3	44	2020	2020 Base
							E3 DER Avoided Cost Model	98	2020	2020 Base
							ESVT Derived - Version 3	25	2020	2020 Base
							ESVT Derived - Version 3	25	2020	2020 Base, 2.0x P4P
							E3 DER Avoided Cost Model	25	2020	2020 Hi Gas & AS, Lo E
							E3 DER Avoided Cost Model	25	2020	2020 Lo Gas & E
							E3 DER Avoided Cost Model	25	2020	2020 Hi Gas & AS, Lo E, 2.0x P4P
							E3 DER Avoided Cost Model	25	2020	2020 Lo Gas & E, 2.0x P4P
							E3 DER Avoided Cost Model	44	2020	2020 Hi Gas & AS, Lo E
							E3 DER Avoided Cost Model	44	2020	2020 Lo Gas & E
							E3 DER Avoided Cost Model	50	2020	2020 Base
							E3 DER Avoided Cost Model	100	2020	2020 Base
							E3 DER Avoided Cost Model	100	2020	2020 Base
							N/A	N/A	N/A	2020 Base, 2.0x P4P
							E3 DER Avoided Cost Model	25	2020	2015 Base
							E3 DER Avoided Cost Model	25	2025	2015 Base, 2.0x P4P
							E3 DER Avoided Cost Model	1	2020	2015 Base

Overview of Results Worksheet provided by EPRI

- File: “ESVT Results for CPUC workshop_draft_3-25-13”

Status	Run	B/C Ratio	Break-even Capital Cost (\$/kWh)*	Break-even Capital Cost (\$/kW)*	Break-even Capital Cost (2013)**	Break-even Capital Cost (\$/kW) (2013)**	Project Start Year	Use Case	Technology	Nameplate Capacity (MW)	Storage Duration (h)	Total Capex (\$/kw)	Replacement Cost (2013)	Replacement Cost 2013 Entry (CONe)	Cost of New Entry (CONE)
Done	run1d	1.14	837	1674	729	1457			Battery	50	2	1056	919	250	218 ES DER ACM
Done	run1e	0.96	420	840	366	733			Battery	50	2	1056	919	250	218 ES DER ACM
Done	run2	1.34	1820	3640	1584	3169			Battery	50	2	1056	919	250	218 ES DER ACM
		1.10	669	2007	582	1747			Battery	50	3	1406	1224	250	218 ES DER ACM
		1.05	521	2084	454	1814			Battery	50	4	1761	1533	250	218 ES DER ACM
		0.86	N/A	0	0	0			LM6000 SPRINT - CT	50	N/A	1619	1409	N/A	N/A ES DER ACM
		0.99	N/A	0						50	N/A	1619	1409	N/A	N/A ESVT Derived
		0.92	N/A	0						100	N/A	1535	1336	N/A	N/A ES DER ACM
		1.21	1060	2120						50	2	1056	919	250	218 ESVT Derived
		1.40	1860	3720						50	2	1056	919	250	218 ESVT Derived
		1.22	1120	2240						50	2	1056	919	250	218 ES DER ACM
		1.17	950	1900						50	2	1056	919	250	218 ES DER ACM
		1.46	2190	4380						50	2	1056	919	250	218 ES DER ACM
	run13	1.39	1830	3660						50					
	run14	0.85	0	0	0	0			LM6000 SPRINT - CT	50					
	run15	0.85	0	0	0	0			LM6000 SPRINT - CT	50					
	run16	1.22	762	3052	664	2657			Flow Battery	50					
	run16a	1.19	709	2836	617	2467			Flow Battery lower eff	50					
	run17	1.32	246	1960	214				Pumped Hydro	300	8	1325	1153	6.6	5 ES DER ACM
	run18	1.26								8	8	1684	1466		6 ES DER ACM
	run19	1.40										778			218 N/A
	run20	1.07										1206			240 ES DER ACM
	run21	1.30										1206			240 ES DER ACM
	run22	1.14										9900			1822 ES DER ACM

Use Case #1: Bulk Storage (Peaker Substitution) Inputs and Results

Reminder – 3 CPUC Use Cases



Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis		
		Bulk-"Peaker Sub"	Ancillary Services	Dist. Sub. Storage
Energy	Electric Supply Capacity	X		X
	Electric Energy Time-Shift	X		X
A/S	Frequency Regulation	X	X	X
	Spinning Reserve	X		X
	Non-Spinning Reserve	X		X
Transmission	Transmission Upgrade Deferral			
	Transmission Voltage Support			
Distribution	Distribution Upgrade Deferral			X
	Distribution Voltage Support			
Customer	Power Quality			
	Power Reliability			
	Retail Demand Charge Mgmt			
	Retail Energy Time-Shift			



Bulk Storage Peaker Substitution




Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis	
		Bulk-"Peaker Sub"	
Energy	Electric Supply Capacity	X	1. Electric Supply Capacity
	Electric Energy Time-Shift	X	
A/S	Frequency Regulation	X	2. Electric Energy Time Shift
	Spinning Reserve	X	
	Non-Spinning Reserve	X	
Transmission	Transmission Upgrade Deferral		3. Frequency Regulation
	Transmission Voltage Support		
Distribution	Distribution Upgrade Deferral		4. Spinning Reserve
	Distribution Voltage Support		
Customer	Power Quality		5. Non-Spinning Reserve
	Power Reliability		
	Retail Demand Charge Mgmt		
	Retail Energy Time-Shift		

Storage Dispatch Modeling Approach for Peaker Substitution Use Case

- Reserve top 20 CAISO load hours per month for providing energy to earn system capacity value




- Co-optimize for profitability between energy and ancillary services (reg up, reg down, spin, non-spin)



Before calculating storage cost effectiveness...


- We need a method for determining system capacity value
- System capacity value is determined by a metric called Cost of New Entry (CONE)
- CONE is the minimum required system capacity annual payment to build a new marginal combustion turbine(CT) – in California, LM6000 w/ SPRINT
- CONE was calculated two ways:
 - E3 DER Avoided Cost Calculator* (base)
 - ESVT Residual capacity value calc



$$\text{CONE} = \text{Fixed Cost} - \text{Energy and AS Revenue}$$

* http://www.ethree.com/documents/DERAvoidedCostModel_v3_9_2011_v4d.xlsm

System Capacity Revenue for Storage



Deriving and Comparing CONE values for System Capacity Value

	E3 DER CONE Value	ESVT-Derived CONE
CONE Value (Residual Capacity Value)	\$155/kW-yr	\$203/kW-yr

Base Case Inputs

Year 2020

50MW

CapEx = \$1619/kW


11.5% discount rate

Full Load Heat Rate = 9856 BTU/kWh


Heat rate curve in spreadsheet

Energy & A/S prices escalated 3%/yr from CAISO 2011

CT with E3 DER derived CONE (base)



CT ESVT Derived CONE



ESVT does not currently simulate CT participation in real time market, so

ESVT CONE is likely somewhat inflated.

Bulk – Peaker Substitution Use Case Base Case Assumptions Provided by CPUC

- Key Global and System / Market Assumptions

Category	Input	2020	2015
Global	Financial Model	IPP	IPP
	Discount Rate	11.47%	11.47%
	Inflation Rate	2%	2%
	Fed Taxes	35%	35%
	State Taxes	8.84%	8.84%
System / Market	Base Year Reference	CAISO 2011	CAISO 2011
	Real Fuel Escalation Rate	2%	2%
	Energy & A/S Escalation Rate	3%	3%
	Yr 1 capacity value (\$/kW-yr)	\$155	\$72
	CONE value (\$/kW-yr)	\$155	\$155
	Resource Balance Year	2020	2020
	Mean Energy Price (\$/MWh)	39.96	34.47
	Mean Reg Up Price (\$/MW-hr)	12.01	10.36
	Mean Reg Down price (\$/MW-hr)	9.04	7.80
	Mean Spin price (\$/MW-hr)	9.43	8.13
	Mean Non-Spin price (\$/MW-hr)	1.28	1.11

Bulk – Peaker Substitution Base Case Assumptions Provided by CPUC

- Key technology cost / performance assumptions – storage and conventional (CT)

Category	Input	2020					2015	
		Battery*	Flow Battery	PHS	AG CAES	CT**	Battery	Flow Battery
Technology Cost / Performance	Nameplate Capacity (MW)	50	50	300	100	50	50	50
	Nameplate Duration (hr)	2	4	8	8	-	2	4
	Capital Cost (\$/kWh) -Start Yr Nominal	528	443	166	211	-	603	775
	Capital Cost (\$/kW) - Start Yr Nominal	1056	1772	1325	1684	1619	1206	3100
	Project Life (yr)	20	20	100	35	20	20	17
	Roundtrip Efficiency	83%	75%	82.50%	-	-	83%	70%
	Variable O&M (\$/kWh)	0.00025	0.00025	0.001	0.003	0.004	0.00025	0.00025
	Fixed O&M (\$/kW-yr)	15	15	7.5	5	17.4	15	15
	Major Replacement Frequency	1	0	-	-	-	1	0
	Major Replacement Cost (\$/kWh)	250	-	-	-	-	250	-
	MACRS Depreciation Term (yr)	7	7	7	7	7	7	7
	Energy Charge Ratio (CAES)	-	-	-	0.7	-	-	-
	Full Capacity Heat Rate (CAES/CT)	-	-	-	3810	9387	-	-
	Heat Rate Curve (CAES/CT)	-	-	-	see wkst	see wkst	-	-
	Turbine Efficiency Curve (PHS)	-	-	see wkst	-	-	-	-
Pump Efficiency (PHS)	-	-	see wkst	-	-	-	-	

* Battery based loosely on Li-ion is most common base case

**CT based on LM6000 w/ SPRINT technology

Run 1: Peaker Substitution Result for Base Case with CPUC Inputs

- **Benefit/Cost Ratio = 1.17**
- **Breakeven Capital Cost: \$831/kWh (\$1662/kW) in 2013 inflation adjusted dollars**

Base Case Inputs

Year 2020

50MW, 2hr (battery)

CapEx = \$1056/kW, \$528/kWh


1 Batt Replacement @ \$250/kWh

11.5% discount rate

83% RT Efficiency

Energy & A/S prices escalated 3%/yr from CAISO 2011

2020 Base Case



Sensitivity to Regulation Service Value (1 of 2)


1X Regulation Price vs. 2X Price

	Base Case	Base Case + 2x Reg
Breakeven Capital Cost in 2013 dollars	\$831/kWh (\$1662/kW)	\$1584 /kWh (\$3168/kW)


Base Case Inputs

Year 2020
 50MW, 2hr (battery)
 CapEx = \$1056/kW, \$528/kWh
 1 Batt Replacement @ \$250/kWh
 11.5% discount rate
 83% RT Efficiency
 Energy & A/S prices escalated 3%/yr from CAISO 2011

2020 Base Case



Base Case + 2x Reg price Multiplier



Sensitivity to Regulation Service Value (2 of 2)

Base Regulation Value vs. No Regulation Value

	Base Case	Base Case w/o Regulation
Breakeven Capital Cost in 2013 dollars	\$831 /kWh (\$1662/kW)	\$423 /kWh (\$846/kW)

Base Case Inputs

Year 2020

50MW, 2hr (battery)



CapEx = \$1056/kW, \$528/kWh

1 Batt Replacement @ \$250/kWh

11.5% discount rate

83% RT Efficiency


Energy & A/S prices escalated 3%/yr from CAISO 2011



Sensitivity to Storage Duration Configuration

Base Case (2hr) vs. 3hr vs. 4hr

	Base Case	Duration 3hr	Duration 4hr
Breakeven Capital Cost in 2013 dollars	\$831 /kWh (\$1662/kW)	\$582 /kWh (\$1746/kW)	\$454 /kWh (\$1816/kW)




Base Case Inputs

Year 2020; 50MW, 2hr (battery); CapEx = \$1056/kW, \$528/kWh; 1 Batt Replacement @ \$250/kWh; 11.5% discount rate; 83% RT Efficiency; Energy & A/S prices escalated 3%/yr from CAISO 2011

Sensitivity to Battery Replacement Frequency*

No. of Replacements	Base Case (1X)	Base + 2X replace	Base + 3X replace
Breakeven Capital Cost in 2013 dollar	\$831 /kWh (\$1662/kW)	\$582 /kWh (\$1164/kW)	\$454 /kWh (\$908/kW)



Base Case Inputs

Year 2020; 50MW, 2hr (battery); CapEx = \$1056/kW, \$528/kWh; Batt Replacements @ \$250/kWh; Battery replacements equally spaced over 20 yr life; 11.5% discount rate; 83% RT Efficiency; Energy & A/S prices escalated 3%/yr from CAISO 2011

© 2013 Electric Power Research Institute, Inc. All rights reserved.

Sensitivity to Project Start Year: 2020 vs. 2015


	Base Case (2020 start)	Base Case (2015 start)
Breakeven Capital Cost in 2013 dollars	\$831/kWh (\$1662/kW)	\$749/kWh (\$1498/kW)

2020 Base Case

Base Case w/ 2015 start

Base Case Inputs

- Year 2020
- 50MW, 2hr (battery)
- CapEx = \$1056/kW, \$528/kWh
- 1 Batt Replacement @ \$250/kWh
- 11.5% discount rate
- 83% RT Efficiency
- Energy & A/S prices escalated 3%/yr from CAISO 2011



Other Technology Comparison (Flow Battery, CAES, Pumped Hydro)

	Flow Battery	Pumped Hydro	Abv Ground CAES
Breakeven Capital Cost in 2013 dollars	\$664/kWh (\$2657/kW)	\$214/kWh (\$1713/kW)	\$224/kWh (\$1790/kW)

Global Inputs

11.5% discount rate

Energy & A/S prices escalated 3%/yr from CAISO 2011

Flow Battery Inputs

50MW, 4hr (battery)

CapEx = \$1772/kW

75% RT Efficiency

No battery replacements

PH Inputs

300MW, 8hr

\$1325/kW, 100 yr project life

VO&M = \$1.02/MWh, FO&M = \$7.5/kW-yr

CAES Inputs

100MW, 8h


\$1584/kW, 35 yr life

Energy charge ratio = 0.7


Full load heat rate = 3810

© 2013 Electric Power Research Institute, Inc. All rights reserved.


Flow Battery



Pumped Hydro




AG CAES



Overview of Bulk / Peaker Results in ESVT - Breakeven Capital Costs (CPUC Inputs)

Breakeven Capital Cost (\$/kWh) in 2013 Dollars (inflation-adjusted)




* Based on 2011 EPRI Storage Cost Survey and other sources

** "Current costs" applicable to 2-4hr battery, not other technologies contained

Summary of B/C ratio results for Bulk Storage (Peaker Sub) – CPUC Inputs / Costs

B/C Ratio



Use Case #2: A/S (Regulation)–only Inputs & Results

Reminder – 3 CPUC Use Cases



Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis		
		Bulk-"Peaker Sub"	Ancillary Services	Dist. Sub. Storage
Energy	Electric Supply Capacity	X		X
	Electric Energy Time-Shift	X		X
A/S	Frequency Regulation	X	X	X
	Spinning Reserve	X		X
	Non-Spinning Reserve	X		X
Transmission	Transmission Upgrade Deferral			
	Transmission Voltage Support			
Distribution	Distribution Upgrade Deferral			X
	Distribution Voltage Support			
Customer	Power Quality			
	Power Reliability			
	Retail Demand Charge Mgmt			
	Retail Energy Time-Shift			


A/S (Regulation)-Only



Category		Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis	
			Ancillary Services	
Energy		Electric Supply Capacity		1.Frequency Regulation
		Electric Energy Time-Shift		
A/S		Frequency Regulation	X	
		Spinning Reserve		
		Non-Spinning Reserve		
Transmission		Transmission Upgrade Deferral		
		Transmission Voltage Support		
Distribution		Distribution Upgrade Deferral		
		Distribution Voltage Support		
Customer		Power Quality		
		Power Reliability		
		Retail Demand Charge Mgmt		
		Retail Energy Time-Shift		

Storage Dispatch Modeling Approach for Regulation Only Use Case

- Optimize for profitability between regulation up, regulation down, and no action; manage storage state-of-charge
- Account for associated charging / discharging costs and revenues



A/S (Regulation)-only Base Case Assumptions Provided by CPUC (1 case)

- Key Global and System / Market Assumptions

Category	Input	2020
Global	Financial Model	IPP
	Discount Rate	11.47%
	Inflation Rate	2%
	Fed Taxes	35%
	State Taxes	8.84%
System / Market	Base Year Reference	CAISO 2011
	Real Fuel Escalation Rate	2%
	Energy & A/S Escalation Rate	3%
	Mean Energy Price (\$/MWh)	39.96
	Mean Reg Up Price (\$/MW-hr)	12.01
	Mean Reg Down Price (\$/MW-hr)	9.04


ATS (Regulation)-only Base Case Assumptions Provided by CPUC (1 case)

- Key technology cost / performance assumptions

Category	Input	2020
		Battery
Technology Cost / Performance	Nameplate Capacity (MW)	20
	Nameplate Duration (hr)	0.25
	Capital Cost (\$/kWh) -Start Yr Nominal	3112
	Capital Cost (\$/kW) - Start Yr Nominal	778
	Project Life (yr)	20
	Roundtrip Efficiency	83%
	Variable O&M (\$/kWh)	0.00025
	Fixed O&M (\$/kW-yr)	15
	Major Replacement Frequency	1
	Major Replacement Cost (\$/kWh)	250
	MACRS Depreciation Term (yr)	7

Regulation Only Result (2x Regulation Price Multiplier)

Regulation Only Base Case



B/C Ratio	1.40
Breakeven Capital Cost in 2013 dollars	\$1678/kW (\$6712/kWh)

Discussion Break / Lunch

Use Case #3: Distribution Storage at Substation Inputs & Results

Reminder – 3 CPUC Use Cases



Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis		
		Bulk-"Peaker Sub"	Ancillary Services	Dist. Sub. Storage
Energy	Electric Supply Capacity	X		X
	Electric Energy Time-Shift	X		X
A/S	Frequency Regulation	X	X	X
	Spinning Reserve	X		X
	Non-Spinning Reserve	X		X
Transmission	Transmission Upgrade Deferral			
	Transmission Voltage Support			
Distribution	Distribution Upgrade Deferral			X
	Distribution Voltage Support			
Customer	Power Quality			
	Power Reliability			
	Retail Demand Charge Mgmt			
	Retail Energy Time-Shift			


Distribution Storage at Substation




Category	Quantifiable Grid Services	CPUC Use Cases Incl. in Analysis	
			Dist. Sub. Storage
Energy	Electric Supply Capacity	1. Electric Supply Capacity 2. Electric Energy Time Shift 3. Frequency Regulation 4. Spinning Reserve 5. Non-Spinning Reserve 6. Distribution Upgrade Deferral	X
	Electric Energy Time-Shift		X
A/S	Frequency Regulation		X
	Spinning Reserve		X
	Non-Spinning Reserve		X
Transmission	Transmission Upgrade Deferral		
	Transmission Voltage Support		
Distribution	Distribution Upgrade Deferral	X	
	Distribution Voltage Support		
Customer	Power Quality		
	Power Reliability		
	Retail Demand Charge Mgmt		
	Retail Energy Time-Shift		

Storage Dispatch Modeling Approach for Distribution Storage at Substation Use Case




- Top priority: Peak shave annual peak distribution load to offset load growth and defer upgrade investment for years



- Second priority: Reserve Top 20 CAISO load hours per month for providing energy



- Co-optimize for profitability between energy and ancillary services (reg up, reg down, spin, non-spin)



Distributed Storage at Substation Base Case Assumptions Provided by CPUC

- Key Global and System / Market Assumptions

Category	Input	2020	2015
Global	Financial Model	IPP	IPP
	Discount Rate	11.47%	11.47%
	Inflation Rate	2%	2%
	Fed Taxes	35%	35%
	State Taxes	8.84%	8.84%
System / Market	Base Year Reference	CAISO 2011	CAISO 2011
	Real Fuel Escalation Rate	2%	2%
	Energy & A/S Escalation Rate	3%	3%
	Cost of Distribution Upgrade (\$/kW)	\$309	\$279
	Feeder Type	C&I	C&I
	Load Growth Rate	2%	2%
	Yr 1 capacity value (\$/kW-yr)	\$155	\$72
	CONE value (\$/kW-yr)	\$155	\$155
	Resource Balance Year	2020	2020
	Mean Energy Price (\$/MWh)	39.96	34.47
	Mean Reg Up Price (\$/MW-hr)	12.01	10.36
	Mean Reg Down Price (\$/MW-hr)	9.04	7.80
	Mean Spin Price (\$/MW-hr)	9.43	8.13
	Mean Non-Spin Price (\$/MW-hr)	1.28	1.11

Distributed Storage at Substation Base Case Assumptions Provided by CPUC


- Key technology cost / performance assumptions

Category	Input	2020		2015
		Battery (4hr)	Battery (4hr)	Flow Battery (4hr)
Technology Cost / Performance	Nameplate Capacity (MW)	1	1	1
	Nameplate Duration (hr)	4	4	4
	Capital Cost (\$/kWh) - Start Yr Nominal	437	500	775
	Capital Cost (\$/kW) - Start Yr Nominal	1750	2000	3100
	Project Life (yr)	20	20	17
	Roundtrip Efficiency	83%	83%	70%
	Variable O&M (\$/kWh)	0.00025	0.00025	0.00025
	Fixed O&M (\$/kW-yr)	15	15	15
	Major Replacement Frequency	1	1	0
	Major Replacement Cost (\$/kWh)	250	250	
	MACRS Depreciation Term (yr)	7	7	7

Distribution Storage at Substation Cost-Effectiveness Result for Base Case

- **Benefit/Cost Ratio = 1.19**
- **Breakeven Capital Cost: \$851/kWh (\$3403/kW) in 2013 inflation adjusted dollars**

2015 Distributed Case



Base Case Inputs

Year 2015

1MW, 4hr (battery)

CapEx = \$2000/kW, \$500/kWh

11.5% discount rate

83% RT Efficiency

Energy & A/S prices escalated

3%/yr from CAISO 2011

\$279/kW upgrade cost

2% load growth rate

Distribution Base Case: Project Start Year 2015 vs. 2020

	Base Case (2015)	Base Case (2020)
Breakeven Capital Cost in 2013 dollars	\$851/kWh (\$3403/kW)	\$914 /kWh (\$3656/kW)


Base Case Inputs

1MW, 4hr (battery)
 CapEx = \$2000/kW, \$500/kWh
 11.5% discount rate
 83% RT Efficiency
 Energy & A/S prices escalated 3%/yr from CAISO 2011
 \$279/kW dist. upgrade cost
 2% load growth rate


2020 Case Inputs

CapEx = \$1750/kW, \$438/kWh
 Same battery performance as base
 \$309/kW upgrade cost
 2% load growth rate
 Same market inputs as 2020 peaker use case base

2015 Distributed Case



Base Case Start at 2020



Sensitivity to Distribution Base Case - Duration 4hr vs. 2hr


	Base Case (4 Hour)	Base Case (2 Hour)
Breakeven Capital Cost in 2013 dollars	\$851/kWh (\$3403/kW)	\$1490 /kWh (\$5960/kW)

Base Case Inputs


1MW, 4hr (battery)
 CapEx = \$2000/kW, \$500/kWh
 11.5% discount rate
 83% RT Efficiency
 Energy & A/S prices escalated
 3%/yr from CAISO 2011
 \$279/kW upgrade cost
 2% load growth rate

2 hr Inputs
 1MW, 2hr
 CapEx = \$1100/kW, \$550/kWh

2015 Base Case



2015 Distributed Case 2hr




Sensitivity to Regulation Price 2X multiplier

	Base Case	Base Case (2x Reg)
Breakeven Capital Cost in 2013 dollars	\$851/kWh (\$3403/kW)	\$1307 /kWh (\$5528/kW)


Base Case Inputs

- 1MW, 4hr (battery)
- CapEx = \$2000/kW, \$500/kWh
- 11.5% discount rate
- 83% RT Efficiency
- Energy & A/S prices escalated 3%/yr from CAISO 2011
- \$279/kW upgrade cost
- 2% load growth rate

2015 Base Case



Base Case + 2x Reg




Sensitivity Distribution Load Growth: 2% vs. 4%

	Base Case (2%)	Base Case (4%)
Breakeven Capital Cost in 2013 dollars	\$851/kWh (\$3404/kW)	\$619 /kWh (\$2476/kW)


Base Case Inputs

- 1MW, 4hr (battery)
- CapEx = \$2000/kW, \$500/kWh
- 11.5% discount rate
- 83% RT Efficiency
- Energy & A/S prices escalated 3%/yr from CAISO 2011
- \$279/kW upgrade cost
- 2% load growth rate

2015 Base Case



Base Case with High Load Growth Rate 4%



Storage Comparison: Battery (Base) vs. Flow Battery

	Base Case	Base Case w/ Flow Battery – 4h
Breakeven Capital Cost in 2013 dollars	\$851/kWh (\$3403/kW)	\$1000 /kWh (\$4000/kW)


Base Case Inputs

- 1MW, 4hr (battery)
- CapEx = \$2000/kW, \$500/kWh
- 11.5% discount rate
- 83% RT Efficiency
- Energy & A/S prices escalated 3%/yr from CAISO 2011
- \$279/kW upgrade cost
- 2% load growth rate


Flow Battery Inputs

- 1MW, 4hr
- 17 yr project life
- CapEx = \$3100/kW, \$775/kWh
- No replacements

2015 Base Case




Base Case with Flow Battery



Overview of Distribution Results: Breakeven Capital Costs

Breakeven Capital Cost (\$/kWh) in 2013 dollars




All Cases Cost-Effective with CPUC Inputs; Few Cases Cost-Effective at Current Costs

* Based on 2011 EPRI Storage Cost Survey and other sources

** "Current costs" applicable to 2-4hr battery, not other technologies contained

Overview of Distribution Case: Benefit-Cost Ratio with CPUC Inputs


B/C Ratio For Distributed Use Case



Conclusions & Next Steps

Overview of all Benefit-to-Cost Ratios

B/C Ratio



Overview of findings

- Key findings from modeling analysis
 - Under provided assumptions, no clear conclusions between cost-effectiveness of different storage tech
 - Shorter duration typically allows for higher breakeven costs and improved benefit-to-cost ratios
 - Regulation is valuable for storage and price multiplier (pay-for-performance) drives battery storage profitability significantly
 - System capacity and T&D investment deferral are high value services
 - Higher Energy & A/S price escalation assumptions drive higher values in storage

***Reminder*: Results provided are valid only under stated CPUC assumptions.**

Conclusions

- In this analysis, ESVT calculated that storage is cost-effective under most of the scenarios defined by the CPUC
- Storage still faces significant challenges in terms of integration and deployment in the field
- Cost targets for storage defined in these scenarios have yet to be achieved

***Reminder*: Results provided are valid only under stated CPUC assumptions.**

Next Steps – Comments and Reporting

- We would love to hear your comments and feedback to this analysis
- Intend to produce a publicly available EPRI report in the June timeframe to more formally present the results of this analysis
 - Opportunity to incorporate FAQ's from stakeholders and clarifications
- **Analysis is still at an early stage! Case runs were completed in a short amount of time. More analysis pending.**

Thank you!

- Active participation from CPUC, CESA, PG&E, SCE, and SDG&E to support our input clarification questions and format inputs in a way that resulted in only a small number of miscommunications
 - Special thanks to Giovanni Damato of CESA for managing the input template
- Great feedback on important tool outputs and formats that will be incorporated into future versions of the ESVT.

Together...Shaping the Future of Electricity