

From: Fugere, Raymond G.  
Sent: 4/16/2013 1:44:25 PM  
To: Allen, Meredith (/O=PG&E/OU=Corporate/cn=Recipients/cn=MEAe)  
Cc:  
Bcc:  
Subject: Re: CONFIDENTIAL: [Redacted]

Meredith  
Thanks for the update.  
Ray

"Allen, Meredith" <MEAe@pge.com> wrote:

Ray,

[Redacted]

Thanks,

Meredith

**From:** Allen, Meredith  
**Sent:** Tuesday, April 16, 2013 11:11 AM  
**To:** Fugere, Raymond G. (raymond.fugere@cpuc.ca.gov)  
**Subject:** CONFIDENTIAL: [Redacted]

Ray,

Here is the information on the equipment failure at [Redacted] as of 10 am. This information should be treated as confidential. I've also included below the external messaging.

Thanks,

Meredith

[Redacted] **Equipment report as of 1000 this morning:**

115kv CB 462 will not operate due to damage – this will need to be removed from service

115kv CB 472 will not operate due to damage – this will need to be removed from service

GCC in the process of switching to clear these CBs.

230/115KV BKs:

#2 & #4 out of service with gunshot damage

#3 in service carrying load oil level is below damaged area and no longer leaking – monitoring temps locally

#1 in service carrying load

500/230KV BKs:

#11 & #13 out of service with gunshot damage and reported electrical fault

#12 out of service , forced out this morning no electrical fault

Currently working with DOs to field transfer as much area load as possible.

Preparing to roll the 115KV bus section D to remove from service 115KV CBs 462 & 472

## External Messaging

- Early this morning, a PG&E substation was damaged by vandalism.
- There were gunshots heard at the facility.
- We are assessing the full scope of the vandalism.
- The vandalism did result in an oil leak and we are currently assessing the full impact of the leak.
- Crews are on site assessing the damage.
- The Santa Clara Sheriff's Department is the lead on the investigation.

## Flex Alert Messaging

- The CAISO has issued a Flex Alert for Northern California for today, April 16.
- The CAISO is asking residents and businesses in the San Jose area, in particular Santa Clara and Silicon Valley, to conserve electricity now following vandalism to the PG&E Redacted.
- PG&E is assessing the damage to the substation, and may take additional equipment at the substation out of service.
- Consumers are urged to reduce their electricity usage through midnight.
- Conservation tips include:
  - o Lower or turn off lighting not in use
  - o Turn off thermostats
  - o Power down any unnecessary electric appliances and devices
  - o Put off tasks like vacuuming, laundry, dishwashing and computer time if possible

PG&E is committed to protecting our customers' privacy.  
To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>