

From: Fugere, Raymond G.
Sent: 4/16/2013 5:35:43 PM
To: Allen, Meredith (/O=PG&E/OU=Corporate/cn=Recipients/cn=MEAe)
Cc:
Bcc:
Subject: Re: CONFIDENTIAL: [Redacted]

Thanks for the update, and that is good to hear that #2 may be operational tomorrow.

Raymond G. Fugere, P.E.
Program & Project Supervisor
Safety and Enforcement Division
320 W. 4th Street, Suite 500
Los Angeles, CA 90013
Office (213) 576-7015

-----Original Message-----

From: Allen, Meredith [mailto:MEAe@pge.com]
Sent: Tuesday, April 16, 2013 4:22 PM
To: Fugere, Raymond G.
Subject: Re: CONFIDENTIAL: [Redacted]

Ray,

In regard to the 230/115kv banks, we are hoping to have #2 operational tomorrow by replacing a transformer. I can provide you an update in the am.

Thanks,
Meredith

On Apr 16, 2013, at 1:41 PM, "Allen, Meredith" <MEAe@pge.com<mailto:MEAe@pge.com>> wrote:

Ray,

[Redacted]

Thanks,
Meredith

From: Allen, Meredith
Sent: Tuesday, April 16, 2013 11:11 AM
To: Fugere, Raymond G. (raymond.fugere@cpuc.ca.gov<mailto:raymond.fugere@cpuc.ca.gov>)
Subject: CONFIDENTIAL: [Redacted]

Ray,

Here is the information on the equipment failure at [Redacted] as of 10 am. This information should be treated as confidential. I've also included below the external messaging.

Thanks,
Meredith

Redacted Equipment report as of 1000 this morning:

115kv CB 462 will not operate due to damage - this will need to be removed from service 115kv CB 472 will not operate due to damage - this will need to be removed from service GCC in the process of switching to clear these CBs.

230/115KV BKs:

#2 & #4 out of service with gunshot damage

#3 in service carrying load oil level is below damaged area and no longer leaking - monitoring temps locally

#1 in service carrying load

500/230KV BKs:

#11 & #13 out of service with gunshot damage and reported electrical fault

#12 out of service , forced out this morning no electrical fault

Currently working with DOs to field transfer as much area load as possible.

Preparing to roll the 115KV bus section D to remove from service 115KV CBs 462 & 472

External Messaging

- * Early this morning, a PG&E substation was damaged by vandalism.
- * There were gunshots heard at the facility.
- * We are assessing the full scope of the vandalism.
- * The vandalism did result in an oil leak and we are currently assessing the full impact of the leak.
- * Crews are on site assessing the damage.
- * The Santa Clara Sheriff's Department is the lead on the investigation.

Flex Alert Messaging

- * The CAISO has issued a Flex Alert for Northern California for today, April 16.
- * The CAISO is asking residents and businesses in the San Jose area, in particular Santa Clara and Silicon Valley, to conserve electricity now following vandalism to the PG&E [Redacted].
- * PG&E is assessing the damage to the substation, and may take additional equipment at the substation out of service.
- * Consumers are urged to reduce their electricity usage through midnight.
- * Conservation tips include:
 - o Lower or turn off lighting not in use
 - o Turn off thermostats
 - o Power down any unnecessary electric appliances and devices
 - o Put off tasks like vacuuming, laundry, dishwashing and computer time if possible

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>