

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF CALIFORNIA**

Application of Pacific Gas and Electric  
Company for Authority, Among Other  
Things, to Increase Rates and Charges  
for Electric and Gas Service Effective on  
January 1, 2014 (U39M).

Application 12-11-009  
(Filed November, 15, 2012)

**OPENING TESTIMONY OF DAVID MARCUS ON BEHALF OF  
THE COALITION OF CALIFORNIA UTILITY EMPLOYEES**

May 17, 2013

## SUBJECT INDEX

I.	INTRODUCTION	1
II.	SUMMARY OF RECOMMENDATIONS	2
III.	CRITICAL OPERATING EQUIPMENT	3
	A. Nature Of The Issue	3
	B. Coe Appears To Be Improving	5
	C. The Reported Improvement Is Not As Dramatic As Pg&E Makes It Out To Be	6
	D. Still Plenty Of Room For Improvement	8
IV.	REPLACING AGING FACILITIES-NOT KEEPING UP	
V.	WITH FACILITY LIVES AS SHOWN IN DEPRECIATION ANALYSES	9
	A. Poles	10
	B. Distribution Breakers In Substations	15
	C. Overhead Conductor	17
VI.	PROACTIVELY IMPROVING RELIABILITY	19
	A. PG&E'S VOS Study Allows Reliability Benefits To Be Compared To Their Costs	20
	B. VOS Analyses Show Various PG&E Proposals Are Worth Doing	21
	C. Benefits/Cost Ratios Greater Than One Show PG&E Should Be Doing More	22
	1. Fuses	23
	2. Reclosers	24
	3. FLISR	25
	4. Targeted Circuit Improvements	28
	5. Underground Protection	30
VII.	PICARRO (EX.PGE3, CHAPTER 6)	31
	A. Background- How We Got Here	31
	1. CUE Identified The Problem In The Last GRC Cycle-Failure To Adequately Detect	

And Repair Gas Leaks	31
2. Picarro Is An Attempt To Improve Gas Leak Detection Technology	32
B. What Picarro Is And How It Works	33
1. Picarro Proper Is A Method That Is A Thousand Times More Sensitive To The Amount Of Gas In The Air- But Does Not Find The Actual Physical Leak	33
2. The “Picarro Methodology” Combines Picarro Detectors With Foot-Based Search And Evaluation, But Still Reduces Overall Leak Detection Costs	34
C. Picarro Methodology Results	34
1. Three Major Results From The 2012 Analyses	35
A. Picarro is cheaper, at least in labor terms, as a leak detection methodology	35
B. Picarro methodology finds a lot of leaks the traditional methods do not	35
C. The leaks found by traditional methods are largely not found by the Picarro methodology	36
2. The Results Of The 2012 Analyses Apply To All Relevant Leak Types	37
D. Policy Implications For The Picarro Methodology	38
1. Picarro Should Be Used	38
2. Picarro Should Not Replace Traditional Methods	38
3. The Cost Implications Of Picarro Are Currently Uncertain	39
A. Uncertain costs of leak detection	39
B. Uncertain costs of leak repair	40
4. PG&E’s Proposed Two-Way Balancing Account Should Be Approved	40
5. More Research Should Be Required Before The Next GRC	41
APPENDIX A – DAVID MARCUS CV	42

1 **I. INTRODUCTION**

2 Three years ago, on behalf of CUE, I testified in PG&E's TY 2011 GRC  
3 that the job of PG&E is service to customers and that job was not getting  
4 done.<sup>1</sup> I cited PG&E's own presentations regarding its inferior electrical  
5 service,<sup>2</sup> and presented evidence that PG&E's gas safety efforts were failing  
6 to discover or repair tens of thousands of gas leaks.<sup>3</sup> After the San Bruno gas  
7 explosion took place, PG&E clearly refocused. It is undertaken an immense  
8 program of fixing old gas problems and preventing new ones, with new senior  
9 management for its gas efforts. It has increased its focus on repairing critical  
10 operating equipment (COE).<sup>4</sup> In 2012 it replaced more aging transmission  
11 poles than in any year since 2004.<sup>5</sup> It has produced an updated value of  
12 service (VOS) study, which allows it to quantify the economic benefits of  
13 improving reliability, and used that study to justify various projects to  
14 proactively improve reliability.<sup>6</sup> And it is testing and starting to implement a  
15 potentially revolutionary new technology to find more gas leaks (including  
16 the most serious ones) faster and potentially more cheaply than it has in the  
17 past.<sup>7</sup>

---

<sup>1</sup> David Marcus, direct testimony in A.09-12-020, 5/19/10, p. 1.

<sup>2</sup> Ibid., p. 2.

<sup>3</sup> Ibid., p. 2.

<sup>4</sup> Section III of this testimony discusses COE.

<sup>5</sup> Section IV of this testimony addresses replacement of aging facilities, particularly poles.

<sup>6</sup> Section V of this testimony addresses specific PG&E projects to proactively improve reliability.

<sup>7</sup> Section VI of this testimony addresses that new gas leak detection technology, known as Picarro.

1           However, while improved, PG&E still lags far behind its own goals of  
2 several years ago in fixing broken COE, it is still replacing poles and other  
3 equipment at rates that equate to cycle times of over a century, or even over a  
4 millennium, it is still doing much less to proactively improve reliability than  
5 its own economic analyses show is justified, and its gas leak detection  
6 proposal seems more focused on reducing costs rather than finding as many  
7 leaks as feasible. The testimony below addresses each of these shortcomings  
8 in turn, and proposes ways the Commission should require PG&E to do a  
9 better job and the funding needed to enable PG&E to do a better job.

## 10   **II.   SUMMARY OF RECOMMENDATIONS**

- 11       □ The Commission should require PG&E to fix an additional 926 COE  
12       items per year, resulting in an expense increase of \$7.3 million per  
13       year.
- 14       □ The Commission should require PG&E to replace an additional 19,000  
15       poles per year, which would require an additional \$218.4 million  
16       annual capital investment. It would increase the 2014 PG&E revenue  
17       requirement by approximately \$19.7 million.
- 18       □ The Commission should require PG&E to double its proposed breaker  
19       replacement rate, which would require an additional \$31.5 million in  
20       capital costs, or an average of \$10.5 million per year. It would increase  
21       2014 revenue requirement by roughly \$0.9 million.
- 22       □ The Commission should require PG&E to double its proposed overhead  
23       line replacement rate, which would require an additional \$101.1  
24       million in capital costs, or an average of \$33.4 million per year. That  
25       would increase 2014 revenue requirement by roughly \$3.0 million.
- 26       □ The Commission should require PG&E to double its overhead fuse  
27       program which would require an additional capital investment of \$3  
28       million per year. That would increase 2014 revenue requirements by  
29       roughly \$0.3 million.

- 1       □ The Commission should require PG&E to double its recloser program  
2       which would require an additional capital investment of \$9.8 million  
3       over the GRC period, or an average of \$3.3 million per year. That  
4       would increase 2014 revenue requirements by roughly \$0.3 million.
  
- 5       □ The Commission should require PG&E to expand its FLISR program  
6       by 50 percent, to 300 circuits per year, which would require an  
7       additional capital investment of \$36.6 million per year. That would  
8       increase 2014 revenue requirements by roughly \$3.3 million.
  
- 9  
10      □ The Commission should require PG&E to expand its targeted circuit  
11      program by 50 percent, to 120 circuits per year, which would require  
12      an additional capital investment of \$13 million per year. That would  
13      increase 2014 revenue requirements by roughly \$1.2 million.
  
- 14  
15      □ The Commission should require PG&E to expand its underground  
16      protection program by 50 percent, to a total of 100 fuses and  
17      interrupters, which would require an additional capital investment of  
18      \$4 million, or an average of \$1.3 million per year. That would increase  
19      2014 revenue requirements by roughly \$0.1 million.
  
- 20  
21      □ The combined effect of the above recommendations would be an  
22      increase in PG&E's 2014 revenue requirement of approximately \$36  
23      million.<sup>8</sup>
  
- 24  
25      □ The Commission should order PG&E to use the Picarro methodology,  
26      but to use it in addition to existing leak detection methodology, and  
27      also approve PG&E's proposed two-way balancing account.

### 28   **III. CRITICAL OPERATING EQUIPMENT**

#### 29   **A. Nature of the Issue**

30   PG&E has explained to CUE that it:

31   has equipment on its electric distribution system that is very  
32   important to the operation and functionality of the system. This  
33   includes equipment such as fuses, interrupters, line reclosers,  
34   sectionalizers, switches and disconnects. This equipment plays

---

<sup>8</sup> \$7.3 million in increased expense (first bullet item). \$319.5 million per year in increased capital investment (next 8 bullet items). Assuming the capital investment was spread evenly across the year, the increase in 2014 average rate base would be \$319.5 million x ½ = \$159.75 million. Assuming an 18 percent fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$159.75 million x .18 = \$28.755 million. \$7.3 million plus \$28.8 million = \$36.1 million.

1 a major role in preventing customer interruptions and is critical  
2 to restoring power after an outage. Prior to April 2011, when  
3 this equipment required maintenance, PG&E referred to it as  
4 Equipment Requiring Repair (ERR). Beginning in April 2011,  
5 after a benchmark study and internal reviews, this equipment  
6 was re-designated as Critical Operating Equipment (COE).<sup>9</sup>  
7

8 In the last GRC, CUE identified ERR (now COE) as an area of  
9 significant problems for PG&E.<sup>10</sup> The average length of time from when an  
10 item was added to the ERR list until it was repaired and removed from the  
11 ERR list, the “cycle time,” was according to PG&E, the “key metric” for  
12 diagnosing ERR problems.<sup>11</sup> PG&E’s overall average cycle time for ERR had  
13 grown from 100 days in 2006-07 to 153 days by the end of 2007 to 560 days by  
14 the end of 2009. PG&E’s internal ERR Report made clear that ERR problems  
15 were unique to PG&E. While SDG&E and SCE both repaired protective  
16 devices in under five days,<sup>12</sup> PG&E’s ERR problems were attributed to,  
17 among other things, repeated budget cuts, giving ERR a lower priority than  
18 new business, having no coordinated SCADA repair process, lacking SCADA  
19 parts, having no backlog reduction plan, and not doing work on ERR devices  
20 if they had not been repaired after a year had elapsed.<sup>13</sup>

21 The effect of unrepaired ERR/COE is decreased reliability. As CUE  
22 told the Commission three years ago, “[u]nfixed ERR means that when a  
23 device is needed to assure reliability, it’s not operable and thus doesn’t do its

---

<sup>9</sup> PG&E, response to DR CUE 2-15.

<sup>10</sup> David Marcus, direct testimony in A.09-12-020, 5/19/10, pp. 16-21.

<sup>11</sup> Ibid., p. 16, citing PG&E, “LSS Equipment Requiring Repair,” Final Report, 8/8/08, provided as Attachment 1 to PGE’s response to CUE DR 1-13 in the TY2011 GRC case (cited below as “ERR Report”).

<sup>12</sup> Ibid., p. 17, citing PG&E’s ERR Report, p. 10.

<sup>13</sup> Ibid., p. 17, citing PG&E’s ERR Report, p. 19.

1 job. Inoperable fuses increase SAIFI and SAIDI both, inoperable switches  
2 increase SAIDI, and so on.<sup>14</sup> PG&E estimates that an ERR backlog of 2,061  
3 devices (the 12/31/07 level) causes 5.7 minutes per year of SAIDI and 0.04 of  
4 SAIFI per year if not worked off.”<sup>15</sup>

5 **B. COE Appears to be Improving**

6 Given the seriousness of the ERR problems identified in CUE  
7 testimony in the TY2011 GRC, and in PG&E’s own ERR report, CUE posed a  
8 variety of data requests to PG&E regarding the ERR/COE issue. PG&E’s  
9 replies showed that the number of COE items identified each year has fallen  
10 in each of the last two years,<sup>16</sup> that the number of COE items repaired has  
11 increased from 2010 to 2012,<sup>17</sup> that the backlog of unrepaired maintenance  
12 tags relating to COE is well on its way to being eliminated this year,<sup>18</sup> that  
13 cycle times were reduced 37% from 2008 to 2009,<sup>19</sup> and that cycle times have  
14 decreased since then for most categories of COE.<sup>20</sup> PG&E is to be  
15 commended for its efforts to address its past ERR problems, and the progress  
16 it appears to be making.

17

---

<sup>14</sup> Ibid., p. 17, citing PG&E’s ERR Report, p. 17.

<sup>15</sup> Ibid., pp. 17-18, citing PG&E’s ERR Report, p. 17. 5.7 minutes of SAIDI is more than 5 percent of PG&E’s total SAIDI in 2011, and 0.04 of SAIFI is more than 4 percent of PG&E’s total SAIFI in 2011. PG&E, Ex. PGE-4, pp. 15-6 and 15-7. The SAIDI and SAIFI amounts are each about 2/3 of PG&E’s average annual improvement from 2007-11 (8.7 minutes per year of SAIDI, 0.06 per year of SAIFI). Ibid.

<sup>16</sup> PG&E, response to DR CUE 2-15.

<sup>17</sup> PG&E, response to DR CUE 2-16.

<sup>18</sup> PG&E, response to DR CUE 2-23.

<sup>19</sup> PG&E, response to DR CUE 2-24.

<sup>20</sup> PG&E, responses to DRs CUE 2-17 and 2-24.



1           **C.     The Reported Improvement is Not as Dramatic as PG&E**  
2           **Makes it Out to be**

3           PG&E shows that its backlog of “outstanding maintenance tags” has  
4           been reduced from 2,321 at the end of 2008 to 81 at the end of 2012, and is  
5           expected to be zero by the end of 2013.<sup>21</sup> This might be read as saying that  
6           PG&E has reduced the number of unfixed COE items to near zero. But that  
7           can’t possibly be the case, since PG&E shows that it still has cycle times in  
8           2012 of over 120 days for each of the subcategories of COE,<sup>22</sup> which implies a  
9           backlog of well over 1,000 items as of the end of 2012.<sup>23</sup> The reduction to zero  
10          that PG&E reports in its data response is apparently the reduction in the  
11          backlog of items that were listed as ERR at the end of 2008; and while it is  
12          certainly good that everything on the ERR list in 2008 is now fixed, the fact  
13          that some of those items took from 2008 to 2013 to get fixed is not adequate.

14          Similarly, PG&E indicates at one point that it has reduced the cycle  
15          time for four of the subcategories of COE by 33 percent from 2009 to 2012.<sup>24</sup>  
16          But the biggest component of that alleged improvement is a reduction in the  
17          cycle time for the “switch” category from 793 days in 2009 to 239 days in  
18          2012.<sup>25</sup> It turns out that between 2009 and 2012, PG&E changed the

---

<sup>21</sup> PG&E, response to DR CUE 2-23.

<sup>22</sup> Fuses, per PG&E, responses to DRs CUE 2-24; Cutouts, per PG&E, responses to DR CUE 2-17; boosters/regulators, capacitors, conductors, interrupters, reclosers/sectionalizers, and switches, per both DR CUE 2-17 and DR CUE 2-24.

<sup>23</sup> 3451 COE items identified in 2012, per DR CUE 2-15; 2012 cycle times of 127 days or more for all categories of COE items (see previous footnote);  $3451 \times 127/366 = 1197+$  items in backlog.

<sup>24</sup> PG&E, response to DR CUE 2-24, both in the text and in the boldfaced bottom line of the associated table.

<sup>25</sup> PG&E, response to DR CUE 2-24.

1 definition of the “switch” category to include disconnects along with  
2 switches.<sup>26</sup> In 2009, the cycle time for disconnect repairs was only 35 days,<sup>27</sup>  
3 so by excluding them from the 2009 definition of the “switch” category, the  
4 improvement from 2009 to 2012 was overstated, probably by a lot. Similarly,  
5 PG&E changed the definition of the “recloser” category from 2009 to 2012,  
6 adding in sectionalizers (which, on their own, had a 2009 cycle period of just  
7 21 days).<sup>28</sup> Again, the definition change means that the reported  
8 improvement from 2009 to 2012 (the second largest improvement PG&E  
9 reported<sup>29</sup>) was in large part due to the definitional change, and not to an  
10 actual decrease in cycle times.

11         The potentially inaccurate effects of comparing categories whose  
12 definitions have changed over time can be avoided by looking 2010-12 data  
13 along with the 2009-12 data for categories whose definitions have not  
14 changed. There, PG&E shows major improvement in the cycle time for  
15 conductor COE, from 268 days to 127 days, and smaller improvements for  
16 four other categories. However, two categories have gotten slightly worse  
17 and interrupter cycle times have gotten dramatically worse—from 30 days in  
18 2009 to 191 days in 2010 and 262 days in 2012.<sup>30</sup> The overall change still  
19 appears to be in the direction of improvement, but not nearly by 33 percent.

---

<sup>26</sup> Ibid.

<sup>27</sup> Ibid.

<sup>28</sup> Ibid.

<sup>29</sup> Ibid.

<sup>30</sup> PG&E, responses to DRs CUE 2-17 and 2-24.

1 Finally, a comparison of the year-by-year difference between COE  
2 items identified and COE items repaired shows that, while more items were  
3 fixed than found in 2012, the opposite was true in 2010 and 2011.<sup>31</sup> Over the  
4 three year period, 13,462 items were identified, but only 10,685 were fixed.<sup>32</sup>  
5 This implies that the COE backlog actually increased by 2,777 items over the  
6 three-year period.<sup>33</sup> And since PG&E does not plan to fix any more items  
7 that it finds over the TY2014 GRC cycle,<sup>34</sup> that backlog will not be reduced.

#### 8 **D. Still Plenty of Room for Improvement**

9 PG&E acknowledges that the goal it identified in 2008 in its ERR  
10 Report was a 30-day cycle time, while 2012 cycle times still ranged from 127  
11 to 262 days for the various COE subcategories.<sup>35</sup> It acknowledges that it does  
12 not forecast cycle times,<sup>36</sup> despite the ERR Report calling them the “key  
13 metric” for diagnosing ERR problems.<sup>37</sup> It acknowledges that it has no  
14 formal performance targets for COE,<sup>38</sup> despite the ERR Report calling for  
15 incorporating an ERR metric into PG&E’s STIP (short-term incentive  
16 program).<sup>39</sup> Its plans for 2013-16 include repairing no more COE items than  
17 are identified,<sup>40</sup> meaning its backlog of unrepaired items will not shrink from

---

<sup>31</sup> PG&E, responses to DRs CUE 2-15 and 2-16.

<sup>32</sup> Ibid.

<sup>33</sup>  $13,462 - 10,685 = 2,777$ .

<sup>34</sup> PG&E, response to DR CUE 3-13a.

<sup>35</sup> PG&E, response to CUE DR 2-24.

<sup>36</sup> PG&E, response to DR CUE 3-13a.

<sup>37</sup> David Marcus, direct testimony in A.09-12-020, 5/19/10, p. 16, citing the ERR Report, p. 8.

<sup>38</sup> PG&E, response to DR CUE 3-13b.

<sup>39</sup> David Marcus, direct testimony in A.09-12-020, 5/19/10, p. 18, citing the ERR Report, p. 26.

<sup>40</sup> PG&E, response to DR CUE 3-13a.

1 its size at the end of 2012. PG&E's COE performance still has plenty of room  
2 for improvement.

3 At a minimum, the Commission should direct PG&E to eliminate the  
4 increase in the COE backlog of 2,777 items which occurred over the 2010-12  
5 period, and provide the funding to do so. Across the 2014-16 GRC cycle, that  
6 would require fixing an additional 926 COE items per year.<sup>41</sup> PG&E  
7 estimates an expense cost of \$33.328 million per year for the 4,234 COE  
8 items it currently plans to fix each year in 2014-16.<sup>42</sup> Fixing an additional  
9 926 items per year would increase that expense by \$7.289 million.<sup>43</sup> It would  
10 reduce the average cycle time for COE items by 80 days per year,<sup>44</sup> bringing  
11 PG&E closer to its proposed goals from the 2008 ERR Report.<sup>45</sup>

12 **IV. REPLACING AGING FACILITIES – NOT KEEPING UP WITH**  
13 **FACILITY LIVES AS SHOWN IN DEPRECIATION ANALYSES**

14 In Ex. PG&E-2, PG&E provides estimates of the average service lives  
15 for various categories of facilities, while in Ex. PG&E-4, PG&E identifies its  
16 plans to replace various aging electrical system components. CUE has  
17 identified three areas in which there are large discrepancies between what  
18 PG&E's depreciation data implies regarding retirement rates, and what

---

<sup>41</sup>  $2777 / 3 = 926$ .

<sup>42</sup> 4,234 COE items per year in 2014-16 per PG&E, response to DR CUE 3-13a. The 4,234 figure is the sum of COE numbers found in the Ex. PGE-4 Workpapers, at pp. WP5-10:5, WP 5-12:3, WP 5-25:3, and WP 5-27:3. The associated dollar costs, which sum to \$33.328 million, are found in the Ex. PGE-4 Workpapers at pp. WP 5-10:25, WP 5-12:11, WP 5-25:15, and WP 5-27:11.

<sup>43</sup>  $\$33.328 \text{ million} \times 926/4234 = \$7.289 \text{ million}$ .

<sup>44</sup>  $((926 \text{ items extra fixed /year}) / (4234 \text{ items found/year})) \times 365 \text{ days/year} = 79.8 \text{ days}$ .

<sup>45</sup> The 2008 ERR report called for cycle times of 5 days for protective devices and 30 days for "priority one" devices. David Marcus, direct testimony in A.09-12-020, 5/19/10, p. 18, citing the ERR Report, pp. 5 and 14.

1 PG&E's actual proposals are for retiring and replacing aging facilities. The  
2 data suggests that, at least for those three areas (and possibly others that  
3 CUE has not reviewed), PG&E's GRC proposals would make its aging  
4 infrastructure problems worse, not better.

5 **A. Poles**

6 According to PG&E, distribution poles (FERC account 364) have an  
7 average service life of 42 years, and the current stock of distribution poles,  
8 towers, and fixtures had an average remaining life of 31.12 years as of  
9 December 31, 2011.<sup>46</sup> Accordingly, PG&E has requested \$181 million per  
10 year to cover the depreciation costs of those pre-2012 poles over their  
11 estimated average remaining life of 31+ years.

12 At the same time, PG&E is not replacing its pre-2012 poles on  
13 anything like a 31 year cycle, or even a 42-year cycle. While PG&E has about  
14 2.2 million poles,<sup>47</sup> it has removed an average of just 21,540 poles per year  
15 over the last decade, and only 19,090 per year over the last five years.<sup>48</sup> At  
16 those rates, it would take over a century to remove all of the existing poles.<sup>49</sup>

17 Because of this slow pace of pole removal and replacement, the average  
18 age of PG&E's stock of poles has been growing steadily for the last decade. In  
19 2003, the average PG&E pole was 32.75 years old.<sup>50</sup> That average has

---

<sup>46</sup> Ex. PGE-2, p. 11-4.

<sup>47</sup> PG&E, response to DR CUE 2-4, showing a 2012 count of 2,199,408 poles.

<sup>48</sup> PG&E, attachment 2 to response to DR CUE 5-3.

<sup>49</sup> 2.2 million poles/21540 poles per year = 102 years; 2.2 million poles / 19,090 poles per year = 115 years.

<sup>50</sup> PG&E, response to DR CUE 2-4. Note that PG&E's average pole age data contradict its data from the last GRC.

1 increased every year since, and today the average pole is 39.26 years old.<sup>51</sup>  
2 Whereas PG&E had about 150,000 poles over 60 years old in 2007 and over  
3 260,000 poles over 60 years old in 2011, by the start of the Test Year 2014 it  
4 will have some 344,000 poles over 60 years old.<sup>52</sup> Moreover, during the GRC  
5 period of 2014-16, more than 120,000 existing poles will reach the age of 60  
6 years.<sup>53</sup>

7 If PG&E truly believed that its average remaining pole life is 31.12  
8 years, and it simplistically assumed that therefore half of its poles will reach  
9 the end of their lives in the next 31.12 years, it would have to replace over  
10 35,000 poles per year.<sup>54</sup> If PG&E were simply trying to keep the number of  
11 poles over 60 years old on its system from growing, it would have to replace  
12 over 40,000 poles per year.<sup>55</sup>

13 But if PG&E were to align its pole replacement policies with its  
14 depreciation rates, it should be replacing over 100,000 poles in 2014. The  
15 reason is that PG&E claims to know, and incorporates in its depreciation  
16 rates, not just the average service life of its poles, but also their retirement  
17 pattern. Using what are known as Iowa curves, PG&E has estimated that its

---

<sup>51</sup> Ibid.

<sup>52</sup> Data on poles over 60 in 2007 and 2011 from Marcus rebuttal testimony in PG&E's TY2011 GRC, p. 9. 2014 data from attachment 1 to PG&E's response to DR CUE 5-3, summing all poles with an install date of 1953 or earlier.

<sup>53</sup> PG&E, Attachment 1 to response to DR CUE 5-3, sum of pole counts for poles installed in 1954-56 is 120,829 poles.

<sup>54</sup> 2.2 million poles with an average remaining life of 31.12 years. Assuming a symmetrical distribution of life expectancies, half of them, or 1.1 million, will reach their life expectancy in the next 31.12 years. Replacing them on a straight-line basis would require replacing  $1.1 \text{ million} / 31.12 = 35,347$  per year.

<sup>55</sup>  $120,829 \text{ poles reaching age 60 in 2014-16, per Attachment 1 to PG&E's response to DR CUE 5-3. } 120,829 \text{ poles} / 3 \text{ years} = 40,276 \text{ poles per year.}$

1 distribution poles will have an R1.5 pattern of retirements, in which  
2 retirements start out slowly, but then accelerate as poles reach and pass  
3 their average service life, which in this case is 42 years.<sup>56</sup> Applying R1.5  
4 curve data and a 42 year average service life, it is possible to estimate the  
5 expected number of retirements of each vintage of PG&E poles. Thus, the  
6 42R1.5 retirement curve implies that every pole should be retired by age 84,  
7 which means all 2,688 of PG&E's pre-1929 poles should be retired by 2014.  
8 Applying a 42R1.5 retirement curve to each vintage of PG&E poles, and  
9 summing across all the vintages, the calculated number of poles that should  
10 be retired in 2014 would be just over 100,000.<sup>57</sup>

11 How do these estimates of required pole replacements – from 35,000 to  
12 100,000 poles per year, compare to PG&E's actual plans? The answer is  
13 unclear. When asked how many poles PG&E has budgeted to replace in each  
14 of the years 2013-16, PG&E's answer was limited to its Pole Replacement  
15 Program,<sup>58</sup> which expects to replace only 5,760 poles per year during the GRC  
16 period of 2014-16.<sup>59</sup> When re-asked for the total number of poles expected to  
17 be replaced through all of its programs, PG&E again referenced just the Pole

---

<sup>56</sup> Ex. PG&E-2, p. 11-4. DRA accepts PG&E's Iowa curve and average service life proposal. Ex. DRA-19, p. 5.

<sup>57</sup> See Marcus workpaper 1, showing 101,647 expected pole retirements in 2014, based on PG&E data regarding pole vintage and using a 42R1.5 Iowa curve to estimate annual retirements for each age cohort of poles.

<sup>58</sup> PG&E, response to DR CUE 2-2b.

<sup>59</sup> Ex. PGE-4, p. 7-6, Table 7-1. DRA has accepted PG&E's proposed pole replacement rate, while proposing to cut the number of annual pole inspections that would be funded through rates. Ex. DRA-5, pp. 35-41.

1 Replacement Program.<sup>60</sup> When asked for the number of expected future  
2 distribution pole replacement for *each* of its programs that replaces poles,  
3 PG&E asserted that it “does not forecast the number of distribution pole  
4 replacements for any of its programs under which poles are replaced except  
5 the Pole Replacement Program.”<sup>61</sup> So the one program that is explicitly  
6 designed to find and replace poles that are at the end of their lives, the Pole  
7 Replacement Program is expected to replace only 5,760 poles per year, which  
8 corresponds to a pole replacement cycle of over 380 years.<sup>62</sup> PG&E has  
9 rejected the validity of the 380-year figure, but only by pointing to its  
10 historical overall pole replacement rate of fewer than 19,000 poles per year in  
11 the last 6 years.<sup>63</sup> That would be a replacement cycle of 116 years.<sup>64</sup>

12 How should the Commission respond to PG&E’s multi-year practice of  
13 replacing too few poles,<sup>65</sup> which has led to an ever-increasing average pole  
14 age and an ever-increasing number of poles over the age of 60? In the last  
15 PG&E GRC, CUE said that PG&E should be doing all of its planned pole  
16 replacements, should be working off its backlog of poles identified as needing  
17 replacement, and should be replacing 28,000 poles per year if it was to

---

<sup>60</sup> PG&E, response to DR CUE 3-2b.

<sup>61</sup> PG&E, response to DR CUE 3-2a. See also PG&E’s response to DR CUE 3-4b, reiterating that PG&E does not forecast its pole count or average pole age, and PG&E’s response to DR CUE 3-1a, where PG&E says it does not have historical data either for how many poles it has actually replaced under each of its various programs.

<sup>62</sup> 2.2 million poles / 5760 poles per year = 381.9 years.

<sup>63</sup> PG&E, response to DR CUE 2-2d, citing 113,833 pole removals in the 6 years from 2007-12, or 18,972 per year.

<sup>64</sup> 2.2 million poles / 18,972 poles per year = 115.96 years.

<sup>65</sup> We note that this problem is not unique to PG&E. Southern California Edison and SDG&E also replace too few poles to ensure they are replaced before the end of their useful lives. Underfunding this activity is typical in Commission decisions in electric utility GRCs.



1 achieve an 80-year replacement cycle.<sup>66</sup> PG&E did indeed do all of its  
2 planned replacements, it is indeed working off its backlog, and it even  
3 managed to remove 28,000 poles in one year of the GRC cycle (2012). Yet  
4 overall, PG&E's pole removal rate over the last three years (19,140 poles per  
5 year) has barely budged from the rate over the last 6 years (18,943 poles per  
6 year), and is down from the average of the last decade (21,540 poles per  
7 year).<sup>67</sup>

8         This time we urge the Commission to order PG&E to double its rate of  
9 pole replacement from the 19,000 poles per year that has characterized the  
10 last two GRC cycles and authorize funding to do so. Replacing an additional  
11 19,000 poles per year would increase the 2014 PG&E revenue requirement by  
12 approximately \$19.7 million.<sup>68</sup> Any Commission order to increase the pole  
13 replacement rate should be subject to a one-way balancing account to make  
14 sure that ratepayers will not pay for pole replacements that do not occur.  
15 That would be an increase of 10,000 poles per year from what PG&E actually

---

66 David Marcus, direct testimony in A.09-12-020, 5/19/10, pp. 8-11.

67 Pole removal data is from Attachment 2 to PG&E's response to DR CUE 5-3, showing pole removals from all programs combined.

68 PG&E projects a capital cost of \$11,493 per pole to replace 5,760 poles per year in 2014-16. Ex. PGE-4 Workpapers, p. WP 7-5. Replacing an additional 19,000 poles per year, if costs were proportional, would require an additional  $\$11,493 \times 19,000 = \$218.367$  million annual capital investment. The associated revenue requirement, amortized over PG&E's 42-year average service life, would of course be much less. Assuming a \$218.367 million capital investment spread evenly across the year, the increase in 2014 average rate base would be  $\$218.367 \text{ million} \times \frac{1}{2} = \$109.184$  million. Assuming an 18 percent fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be  $\$109.184 \text{ million} \times .18 = \$19.653$  million.

1 did in 2012,<sup>69</sup> a manageable increase.<sup>70</sup> It will still be far fewer replacements  
2 than would be expected based on PG&E's claimed average pole service life of  
3 42 years,<sup>71</sup> and it would still not be enough to slow the increase in poles over  
4 the age of 60 (even if every single one of the 2014-16 replacements were of a  
5 pole over 60, which won't actually happen),<sup>72</sup> but it would be a start. It would  
6 not stop the aging of PG&E's fleet of poles – that would require 56,000 pole  
7 replacements per year<sup>73</sup> – but it would slow it down.<sup>74</sup> Increasing the rate of  
8 pole replacements now will buy time for PG&E to deal with pole aging in the  
9 future, and will improve reliability as the number of over-aged poles at risk  
10 for failure in major storms is decreased.

## 11 **B. Distribution Breakers in Substations**

12 In Ex. PGE-4, PG&E declares that it “has approximately 4500  
13 distribution circuit breakers in its substations” and their age is the number

---

<sup>69</sup> Proposed 2014-16 pole removals of 2 x 19,000 poles per year = 38,000 poles per year. Actual pole removals in 2012 were 27,999 poles. PG&E, attachment 2 to response to DR CUE 5-3. Increase of 38,000 – 27,999 = 10,001 poles per year.

<sup>70</sup> The number of poles removed in 2012 was an increase of more than 12,000 poles from the year before. PG&E, attachment 2 to response to DR CUE 5-3. CUE's proposal would require a smaller 2012-14 increase in the number of pole removals than actually occurred in 2011-12.

<sup>71</sup> 101,647 poles in 2014. See Marcus workpaper 1.

<sup>72</sup> PG&E has over 120,000 poles that will reach age 60 during 2014-16. Replacing 38000 poles per year for three years would mean 114,000 replacements, not enough to keep up.

<sup>73</sup> Simple algebra shows that to maintain the average age of its poles constant at its 2012 level of 39.26 years (per PGE response to DR CUE 2-4), PG&E must replace a 1/39.26 of its poles each year. With a 2012 pole count of 2,199,408 poles (ibid.), that corresponds to  $2,199,408/39.26 = 56,022$  poles per year.

<sup>74</sup> In 2012, when PG&E removed 27,999 poles, the most since 2004, its average pole age went up 0.45 years. With no replacements, the average pole age would increase 1 year each year, so the 2012 replacements reduced the fleet aging rate by about .02 years per 1000 poles removed.  $(1-.45)/27.999 = .0196$ . Replacing an additional 10,000 poles per year above that level would reduce the annual aging of the pole fleet to approximately .25 years  $(.45 - 10*.0196 = .254)$ . The average pole would still be over 40 years old by the end of the GRC cycle in 2016  $(39.26 + 4*.254 = 40.28)$ .

1 one prioritization criterion for replacing them prior to failure.<sup>75</sup> In Ex. PGE-2,  
2 PG&E estimates the average service life for distribution station equipment as  
3 42 years, with an average remaining life for the 12/31/2011 stock of station  
4 equipment of 31.5 years.<sup>76</sup> Over the four year period 2013-16, PG&E plans to  
5 proactively replace 130 of those 4,500 breakers,<sup>77</sup> or less than 3 percent of  
6 them.<sup>78</sup> At PG&E's planned peak replacement rate of 40 breakers per year, it  
7 would still take over 112 years to replace the current stock of distribution  
8 breakers.<sup>79</sup>

9 As with poles, PG&E has a substantial mismatch between the useful  
10 life of equipment as reflected in depreciation rates – a stock of assets with  
11 31.5 years of life left – and what it is planning to actually do, which is to  
12 replace its stock of breakers over a 112 year cycle.

13 PG&E should be required to align its replacement rate with its  
14 depreciation rate. If the average existing breaker has 31.5 years of life left,  
15 and if the distribution of remaining breaker life is symmetrical, then half of  
16 all existing breakers will reach the end of their lives over the next 31.5 years.  
17 That means that the average breaker replacement rate should be 71 per  
18 year,<sup>80</sup> not PG&E's planned average of 35 breakers per year in 2014-16. The  
19 Commission should order PG&E to double its planned breaker replacement

---

<sup>75</sup> Ex. PGE-4, p. 13-10.

<sup>76</sup> Ex. PGE-2, p. 11-4.

<sup>77</sup> Ex. PGE-4, p. 13-11.

<sup>78</sup>  $130/4500 = .0289 = 2.89\%$ .

<sup>79</sup>  $(4500-130)/40 = 109.25$  years after 2016, or 112.25 years from 1/1/2014.

<sup>80</sup> 4500 existing breakers, with half to be retired over 31.5 years implies  $4500/2/31.5 = 71.4$  retirements per year.

1 rate, and authorize funding to do so. PG&E projects a capital cost of \$31.5  
2 million for 105 breakers in 2014-16.<sup>81</sup> Doubling the breaker replacement  
3 rate, assuming costs are proportional, would require an additional \$31.5  
4 million in capital costs, or an average of \$10.5 million per year. That would  
5 increase 2014 revenue requirement by roughly \$0.9 million.<sup>82</sup>

### 6 C. Overhead Conductor

7 In Ex. PGE-4, PG&E declares that it “has over 113,500 miles of  
8 overhead conductor” subject to annealing and other types of deterioration.<sup>83</sup>  
9 In Ex. PGE-2, PG&E estimates the average service life for overhead  
10 distribution conductor and devices (FERC Account 365) as 42 years, with an  
11 average remaining life for the 12/31/2011 stock of 30.53 years.<sup>84</sup> Over the  
12 GRC period 2014-16, PG&E plans to proactively replace 62 miles per year of  
13 “deteriorated and annealed conductor,” which will not only prevent outages  
14 due to conductor failure but also “mitigate the public and system safety  
15 implications associated with “wire down” events.”<sup>85</sup> The planned  
16 replacements will total less than 1/6 of one percent of the total overhead  
17 distribution wire on PG&E’s system.<sup>86</sup> At PG&E’s planned replacement rate

---

<sup>81</sup> Ex. PGE-4, p. 13-11.

<sup>82</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$10.5 million x  $\frac{1}{2}$  = \$5.25 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$5.25 million x .18 = \$0.945 million.

<sup>83</sup> Ex. PGE-4, p. 15-16.

<sup>84</sup> Ex. PGE-2, p. 11-4.

<sup>85</sup> Ex. PGE-4, p. 15-12.

<sup>86</sup>  $(3 \times 62)/113500 = .00164 = 0.164\%$ .

1 of 62 miles per year, it would take over 1,800 years to replace the current  
2 stock of overhead distribution conductor.<sup>87</sup>

3 As with poles, PG&E has a substantial mismatch between the useful  
4 life of equipment as reflected in depreciation rates – a stock of assets with  
5 30.5 years of life left – and what it is planning to actually do, which is to  
6 replace its stock of distribution conductor over an 1,800+ year cycle.<sup>88</sup>

7 As a practical matter, PG&E cannot be required to align its overhead  
8 conductor replacement rate with its overhead conductor depreciation rate. If  
9 the average overhead distribution conductor has 30.53 years of life left, and if  
10 the distribution of remaining overhead conductor life is symmetrical, then  
11 half of all existing overhead conductor will reach the end of its life over the  
12 next 30.53 years. That means that the average overhead conductor  
13 replacement rate should be 1,859 miles per year,<sup>89</sup> not PG&E's planned  
14 average of 62 miles per year in 2014-16.

15 What the Commission can do is order PG&E to double its planned  
16 overhead conductor replacement rate, and authorize funding to do so. PG&E  
17 projects a capital cost of \$101.1 million for 62 miles of overhead line  
18 replacement in 2014-16.<sup>90</sup> Doubling the overhead line replacement rate,  
19 assuming costs are proportional, would require an additional \$101.1 million

---

<sup>87</sup>  $113500/62 = 1831$  years.

<sup>88</sup> DRA's proposal would cut PG&E's rate in half, to 31 miles per year, despite acknowledging and not disputing the B/C ratio of 2.0 that PG&E has calculated. Ex. DRA-7, pp. 52-53. DRA's proposal would double the replacement cycle length for overhead conductor to 3662 years (1831 years, per previous footnote, times 2).

<sup>89</sup>  $113,500$  miles of existing overhead conductor, with half to be retired over 30.53 years, implies  $113500/2/30.53 = 1859$  miles of retirements per year.

<sup>90</sup> Ex. PGE-4, p. 15-17.

1 in capital costs, or an average of \$33.4 million per year. That would increase  
2 2014 revenue requirements by roughly \$3.0 million.<sup>91</sup>

3 PG&E has demonstrated that the planned replacement rate will, by  
4 reducing outages, have a benefit/cost ratio of 2.0.<sup>92</sup> Doubling the replacement  
5 rate will increase the reliability benefits of the program by some amount,  
6 even if it does not increase them proportionately. Thus the resulting  
7 benefit/cost ratio will still be greater than one,<sup>93</sup> and PG&E will be a bit  
8 farther along towards its eventual need to replace its entire existing stock of  
9 overhead conductor.

## 10 **V. PROACTIVELY IMPROVING RELIABILITY**

11 More than ten years ago, CUE testified in PG&E's TY2003 GRC that  
12 PG&E's reliability was lower than that of other California and non-California  
13 utilities.<sup>94</sup> Four years ago, PG&E came before the Commission with  
14 testimony acknowledging that its reliability is lower than that of other  
15 California and non-California utilities.<sup>95</sup> The Commission has since approved  
16 the Cornerstone project to improve PG&E's reliability.<sup>96</sup> Now, in this GRC,  
17 the Commission once again faces the question of how much of PG&E's

---

<sup>91</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$33.4 million x  $\frac{1}{2}$  = \$16.7 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$16.7 million x .18 = \$3.006 million.

<sup>92</sup> Ex. PGE-4, p. 15-17.

<sup>93</sup> With a benefit/cost ratio of two for PG&E's proposed program, doubling the cost while increasing the benefit by any amount at all will result in a new benefit cost ratio greater than 1.

<sup>94</sup> A.02-11-017, Ex. 500, 5/2/03, section IV.

<sup>95</sup> A.08-05-023, 3/17/09 Updated CIP testimony, Chapter 2.

<sup>96</sup> D.10-06-048.

1 reliability deficit should be eliminated, and when it is appropriate to spend  
2 money to improve reliability.

3 At one time, PG&E rejected the idea that improving reliability was  
4 desirable at all, without regard to cost, arguing that the Commission did not  
5 want it to spend any money to improve reliability above 1996-98 levels.<sup>97</sup>  
6 PG&E evolved past that idea with its Cornerstone application in 2008,<sup>98</sup> but  
7 without any quantification of the dollar value of specific reliability  
8 improvements. In the Cornerstone decision, the Commission called on PG&E  
9 to provide some actual data on the economic value of reliability to customers  
10 for use in this GRC,<sup>99</sup> and PG&E responded appropriately by producing a  
11 Value of Service (VOS) study in 2012.<sup>100</sup>

12 **A. PG&E's VOS Study Allows Reliability Benefits to be**  
13 **Compared to Their Costs**

14  
15 The PG&E VOS study analyzes, for various customer classes and for  
16 various types and durations of outages, the economic costs associated with  
17 those outages. Of course, that means it also shows the economic values  
18 associated with avoiding those outages in the first place. By providing data  
19 to convert outage frequency and duration into dollar terms, the VOS study  
20 allows proposed expenditures to improve reliability to be evaluated on a

---

<sup>97</sup> A.02-11-017, Ex. 500, 5/2/03, section IX.

<sup>98</sup> A.08-05-023.

<sup>99</sup> D. 10-06-048, as cited in Ex. PGE-4, p. 15-13:5-9.

<sup>100</sup> Freeman, Sullivan & Co., *Pacific Gas & Electric Company's 2012 Value of Service Study*, 5/17/2012, provided as a workpaper in PG&E's GRC filing. See Ex. PGE-4 workpapers, pp. 15-20 to 15-103. Cited below as "VOS" or "VOS study" or "PG&E's VOS study."

1 benefit/cost basis.<sup>101</sup> Particular measures can have their reliability benefits  
2 estimated in terms of the level of avoided outages or avoided outage hours,  
3 and those benefits can then be converted into dollar terms using the data in  
4 the VOS study. PG&E is to be congratulated for having not just produced the  
5 VOS study (pursuant to Commission order), but for having used it to analyze  
6 the cost effectiveness of various proactive reliability improvements it is  
7 proposing in this GRC cycle.

8 **B. VOS Analyses Show Various PG&E Proposals are Worth**  
9 **Doing**

10 PG&E has applied the VOS study to a variety of measures it is  
11 proposing for this GRC to show that they would not only improve reliability,  
12 but that the dollar benefits of that improvement would outweigh the cost of  
13 the proposed measure. For example, PG&E proposes to expand its programs  
14 involving fuses and reclosers, FLISR, underground protection, and  
15 improvements to its worst-performing circuits, and in each case shows that  
16 its proposals would have benefit/cost (B/C) ratios above four.<sup>102</sup> DRA  
17 generally accepts PG&E's proposals.<sup>103</sup> The real question is whether PG&E  
18 should be doing even more.  
19  
20

---

<sup>101</sup> That is precisely the use the Commission contemplated. See D.10-06-048, p. 2, as cited in Ex. PGE-4, p. 15-13, fn. 10: saying that a VOS study will “help [PG&E] and the Commission decide to what extent, if any, electric distribution reliability should be improved to satisfy [PG&E] customers’ needs.”

<sup>102</sup> Ex. PGE-4, pp. 15-20 to 15-24.

<sup>103</sup> Ex. DRA-7, pp. 56-58, accepting PG&E's proposals for fuses and reclosers, underground protection, and worst-performing circuits, and half of PG&E's proposal with regard to FLISR.



1           **C.     Benefit/Cost Ratios Greater Than One Show PG&E**  
2           **Should Be Doing More**

3           With perfect information, expanding a proactive reliability program  
4 produces declining marginal returns. The most effective measures, with the  
5 highest B/C ratios, will be taken first, and each successive measure will  
6 produce less benefit and thus a lower B/C ratio. At the point when the B/C  
7 ratio drops below one, it will no longer make economic sense to spend money  
8 on that particular reliability-improving measure.<sup>104</sup> In economists' jargon,  
9 the total benefit of a program divided by its total cost is its average B/C ratio,  
10 while the benefit of the last unit of the program divided by the cost of that  
11 last unit is its marginal cost. With perfect information, marginal cost falls  
12 below average cost. So stopping program expansion when the marginal B/C  
13 ratio reaches one means that the average B/C ratio will still be above one.

14           In the real world, perfect information does not exist. Last year's worst-  
15 performing circuits may not be next year's worst-performing circuits. It may  
16 make more sense to add fuses on a geographic basis rather than trying to  
17 calculate exactly where new fuse installations would have the highest B/C  
18 ratio. Thus the marginal B/C ratio may not be known, and will not  
19 necessarily be lower than the average B/C ratio.

20           In this case, PG&E does not know the marginal B/C ratios associated  
21 with potential expansions of the various programs for which it has provided

---

<sup>104</sup> DRA claims it makes sense to stop even sooner, when the B/C ratio is above one, sometimes well above it. See Ex. DRA-7, pp. 57-58, among other places.

1 average B/C ratios.<sup>105</sup> However, it is reasonable to expect that the marginal  
2 B/C ratio will not be hugely lower than the average B/C ratio, particularly  
3 since PG&E will not be implementing any of these programs in perfect order  
4 of declining marginal benefit.

### 5 **1. Fuses**

6 PG&E proposes to spend \$3 million per year in 2014-16 to install 700  
7 overhead fuses, with a calculated B/C ratio of 21.0.<sup>106</sup> That means that the  
8 reduction in outages due to those 700 fuses will save customers from outage-  
9 related costs of some \$189 million.<sup>107</sup> In an expanded fuse program, even if  
10 each incremental fuse was only 1/10 as valuable in terms of improved  
11 reliability as the average of the fuses PG&E is proposing to install, the  
12 marginal B/C ratio for those additional fuses would still be greater than two.  
13 It seems very unlikely that PG&E has identified 700 fuses whose installation  
14 would have an average B/C ratio of 21, but that the 701<sup>st</sup> fuse would have a  
15 B/C ratio less than one.

16 The Commission should order PG&E to double its overhead fuse  
17 program by identifying additional locations for fuses that would have an  
18 incremental B/C ratio well above one. And the Commission should also  
19 authorize the necessary funding for an expanded program. Doubling PG&E's

---

<sup>105</sup> PG&E, response to CUE data request 4-1.

<sup>106</sup> Ex. PG&E-4, p. 15-23.

<sup>107</sup> Cost of \$3 million/year x 3 years x B/C ratio of 21 = benefit of \$189 million. Note that PG&E's workpapers show a present value (PV) benefit based on the VOS study of \$161.1 million (Ex. PGE-4 Workpapers, p. 15-15), which suggests a B/C ratio of \$161.1/\$9 = 17.9, rather than 21.0.

1 requested \$3 million per year program would require an additional capital  
2 investment of \$3 million per year. That would increase 2014 revenue  
3 requirements by roughly \$0.3 million.<sup>108</sup>

4 Given the B/C ratio of 21 for the proposed program, the downside risk  
5 of an expanded program is small. Even if PG&E doubled its program and the  
6 additional fuses produced no incremental benefits at all, the overall program  
7 B/C ratio would still be 10.5.<sup>109</sup>

## 8 **2. Reclosers**

9 PG&E proposes to spend \$9.8 million in 2014-16 to install 244 new line  
10 reclosers, with a calculated B/C ratio of 37.2.<sup>110</sup> That means that the  
11 reduction in outages due to those 244 reclosers will save customers from  
12 outage-related costs of some \$364 million.<sup>111</sup> In an expanded recloser  
13 program, even if each incremental recloser was only 1/10 as valuable in terms  
14 of improved reliability as the average of the reclosers PG&E is proposing to  
15 install, the marginal B/C ratio for those additional reclosers would still be  
16 greater than three. It seems very unlikely that PG&E has identified 244

---

<sup>108</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$3 million x 1/2 = \$1.5 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$1.5 million x .18 = \$0.270 million.

<sup>109</sup> \$189 million benefit / doubled cost of \$18 million = 10.5. If the benefit were only \$161.1 million (Ex. PGE-4 workpapers, p. 15-15), the B/C ratio would still be 8.9.

<sup>110</sup> Ex. PG&E-4, pp. 15-23, 15-24.

<sup>111</sup> Cost of \$9.8 million x B/C ratio of 37.2 = benefit of \$364.56 million. Note that PG&E's workpapers show a present value (PV) benefit based on the VOS study of \$309.4 million (Ex. PGE-4 Workpapers, p. 15-15), which suggests a B/C ratio of \$309.4/\$9.8 = 31.6, rather than 37.2.

1 reclosers whose installation would have an average B/C ratio of 37.2, but that  
2 the 245<sup>th</sup> recloser would have a B/C ratio less than one.

3 The Commission should order PG&E to double its recloser program by  
4 identifying additional locations for reclosers that would have an incremental  
5 B/C ratio well above one. And the Commission should also authorize the  
6 necessary funding for an expanded program. Doubling a \$9.8 million  
7 program would require an additional capital investment of \$9.8 million over  
8 the GRC period, or an average of \$3.3 million per year. That would increase  
9 2014 revenue requirements by roughly \$0.3 million.<sup>112</sup>

10 Given the B/C ratio of 37.2 for the proposed program, the downside  
11 risk of an expanded program is small. Even if PG&E doubled its program  
12 and the additional reclosers produced no incremental benefits at all, the  
13 overall program B/C ratio would still be 18.6.<sup>113</sup>

### 14 3. FLISR

15 Fault Location, Isolation, and Service Restoration (FLISR) is an  
16 automated technology that “reduces the impact of outages by quickly opening  
17 and closing automated switches to reduce what may have been a one-to-two-  
18 hour outage, to less than five minutes for most affected customers.”<sup>114</sup> PG&E  
19 proposes to spend \$180 million in 2014-16 to install FLISR on 600 circuits,

---

<sup>112</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be  $\$9.8 \text{ million} \times 1/3 \times 1/2 = \$1.633 \text{ million}$ . Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be  $\$1.633 \times .18 = \$0.294 \text{ million}$ .

<sup>113</sup>  $\$364 \text{ million benefit} / \text{doubled cost of } \$19.6 \text{ million} = 18.57$ . If the benefit were only \$309.4 million (Ex. PGE-4 workpapers, p. 15-15), the B/C ratio would still be 15.8.

<sup>114</sup> Ex. PGE-4, p. 1-10.

1 with a calculated B/C ratio of 31.2, although the actual B/C ratio may be as  
2 low as 21.8.<sup>115</sup> That means that the reduction in outages on those 600  
3 circuits will save customers from outage-related costs of at least \$4.78 billion  
4 over the life of the FLISR installations.<sup>116</sup> In an expanded FLISR program,  
5 even if each incremental circuit using FLISR was only 1/10 as valuable in  
6 terms of improved reliability as the average of the circuits on which PG&E is  
7 proposing to install FLISR, the marginal B/C ratio for the additional FLISR  
8 would still be greater than two. It seems very unlikely that PG&E has  
9 identified 600 circuits where FLISR installation would have an average B/C  
10 ratio of 21.8-31.2, but that the 601<sup>st</sup> circuit would have a FLISR B/C ratio less  
11 than one.

12 The Commission should order PG&E to expand its FLISR program by  
13 50 percent, to 300 circuits per year, by identifying additional circuits where  
14 FLISR would have an incremental B/C ratio well above one. And the  
15 Commission should also authorize the necessary funding for an expanded  
16 FLISR program. Increasing a \$60 million per year program by 50 percent

---

<sup>115</sup> Ex. PG&E-4, pp. 15-20, 15-21. Note that PG&E's workpapers show a present value (PV) benefit based on the VOS study of \$4783.2 million (Ex. PGE-4 Workpapers, p. 15-15), which suggests a B/C ratio of  $\$4783.2/\$180 = 26.6$ , rather than 31.2. Also, PG&E's B/C ratio calculations include associated recloser benefits but not the recloser costs, which increase FLISR costs by 22%, from \$300,000 per circuit to \$366,000 per circuit (Ex. PG&E-4 Workpapers, pp. 15-9 and 15-105). So the net B/C ratio could be as low as  $26.6/1.22 = 21.8$ .  
<sup>116</sup> Cost of \$180 million x B/C ratio of 31.2 = benefit of \$5616 million. PG&E-calculated PV of reliability benefits is \$4.7832 billion (Ex. PG&E-4 Workpapers, p. 15-15).

1 would require an additional capital investment of \$30 million per year. That  
2 would increase 2014 revenue requirements by roughly \$2.7 million.<sup>117</sup>

3           Given the B/C ratio of 21.8 to 31.2 for the proposed program, the  
4 downside risk of an expanded program is small. If PG&E increased its  
5 FLISR program by 50 percent, to 300 circuits per year, and the additional  
6 FLISR circuits produced no incremental benefits at all, the overall program  
7 B/C ratio would still be over 17.<sup>118</sup>

8           Increasing the FLISR program by 50% would not only increase FLISR  
9 capital costs by \$30 million per year, it would also increase recloser costs by  
10 \$6.6 million,<sup>119</sup> With an associated increase in 2014 revenue requirements of  
11 about \$0.6 million.<sup>120</sup> To the extent the Commission orders an expanded  
12 FLISR program, it should also authorize the required increase in recloser  
13 purchases.<sup>121</sup>

---

<sup>117</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$30 million x  $\frac{1}{2}$  = \$15 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$15 million x .18 = \$2.700 million.

<sup>118</sup> \$5616 million benefit / increased cost of \$180 million x 1.5 = 5616/270 = 20.8. If the benefit were only \$4783.2 million (Ex. PGE-4 workpapers, p. 15-15), the B/C ratio would still be 17.7.

<sup>119</sup> Ex. PGE-4 workpapers, pp. 15-9 and 15-105, showing that FLISR costs of \$300,000 per circuit do not include associated reclosers, and p. 15-8, showing 3 reclosers per FLISR circuit, at a cost of \$22,000 each, for a recloser cost of 3 x 100 x \$22,000 = \$6.6 million for an additional 100 FLISR circuits per year.

<sup>120</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$6.6 million x  $\frac{1}{2}$  = \$3.3 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$3.3 million x .18 = \$0.594 million.

<sup>121</sup> DRA has already acknowledged the linkage between the FLISR program and recloser purchase costs, when it calls for cuts in the FLISR program to trigger cuts in the associated recloser purchases. Ex. DRA-7, pp. 52-53. The same relationship applies in the other direction.

1 DRA also wants PG&E to change the size of its FLISR program by 50  
2 percent (100 circuits per year), but DRA wants the change to be a contraction  
3 rather than an expansion.<sup>122</sup> DRA acknowledges, and does not dispute, the  
4 31.2 B/C ratio that PG&E calculated using the Commission-ordered 2012  
5 VOS study.<sup>123</sup> DRA provides no basis for its desire to cut such a highly cost-  
6 effective program other than a claim that “judgment must be exercised” and  
7 that “in DRA’s judgment” cutting the FLISR proposal in half would be  
8 consistent with the FLISR installation rates approved in the Cornerstone  
9 case.<sup>124</sup> But the decision in this case must be based on the record in this case,  
10 not what the Commission did in Cornerstone. With a B/C ratio of 21.8 to 31.2,  
11 capital investments in FLISR will pay for themselves very quickly, possibly  
12 even during this GRC cycle. Unless the Commission proposes to simply  
13 ignore VOS data, after ordering it in the Cornerstone case, it should increase  
14 funding for projects with very high B/C ratios (like FLISR), not cut them in  
15 half as DRA proposes.

#### 16 4. Targeted Circuit Improvements

17 PG&E proposes to spend \$26 million per year in 2014-16 to target  
18 improvements for 80 of its 400 worst-performing circuits each year, with a  
19 calculated B/C ratio of 7.1.<sup>125</sup> That means that the reduction in outages due  
20 to those 80 targeted circuits per year will save customers from outage-related

---

<sup>122</sup> Ex. DRA-7, pp. 57-58.

<sup>123</sup> Ibid.

<sup>124</sup> Ibid.

<sup>125</sup> Ex. PG&E-4, pp. 15-21, 15-22.

1 costs of some \$364 million.<sup>126</sup> In an expanded targeted circuit program, even  
2 if each incremental targeted circuit investment was only ½ as valuable in  
3 terms of improved reliability as the average of the targeted circuits PG&E is  
4 proposing to install, the marginal B/C ratio for those incremental targeted  
5 circuits would still be greater than two. It seems very unlikely that PG&E  
6 can identify 240 circuits which can be improved with an average B/C ratio of  
7 7.1, but that the 241<sup>st</sup> targeted circuit would have a B/C ratio less than one.

8         The Commission should order PG&E to expand its targeted circuit  
9 program by 50 percent, to 120 circuits per year, by identifying additional  
10 circuits where targeting would have an incremental B/C ratio well above one.  
11 An expanded program would still not address all of the 400 worst-performing  
12 circuits over the three year GRC cycle. The Commission should also  
13 authorize the necessary funding for an expanded targeted circuit program.  
14 Increasing a \$26 million per year program by 50 percent would require an  
15 additional capital investment of \$13 million per year. That would increase  
16 2014 revenue requirements by roughly \$1.2 million.<sup>127</sup>

17         Given the B/C ratio of 7.1 for the proposed program, the downside risk  
18 of an expanded program is small. If PG&E increased its targeted circuit  
19 program by 50 percent, to 120 circuits per year, and the additional targeted

---

<sup>126</sup> Cost of \$26 million/year x 3 years x B/C ratio of 7.1 = benefit of \$553.8 million. Note that PG&E's workpapers show a present value (PV) benefit based on the VOS study of \$469.8 million (Ex. PGE-4 Workpapers, p. 15-15), which suggests a B/C ratio of \$469.8/\$78 = 6.0, rather than 7.1.

<sup>127</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$13 million x ½ = \$6.5 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$6.5 million x .18 = \$1.170 million.



1 circuits produced no incremental benefits at all, the overall program B/C ratio  
2 would still be over four.<sup>128</sup>

### 3 **5. Underground Protection**

4 PG&E proposes to spend \$8 million per in 2014-16 to install 67  
5 underground fuses and 67 interrupters, with a calculated B/C ratio of 4.6.<sup>129</sup>  
6 That means that the reduction in outages due to those underground fuses  
7 will save customers from outage-related costs of some \$36.8 million.<sup>130</sup> In an  
8 expanded underground protection program, even if each incremental  
9 underground fuse and interrupter was only ½ as valuable in terms of  
10 improved reliability as the average of the underground fuses and interrupters  
11 PG&E is proposing to install, the marginal B/C ratio for those additional  
12 underground fuses and interrupters would still be greater than two. It seems  
13 very unlikely that PG&E can identify 67 underground fuses and interrupters  
14 with an average B/C ratio of 4.6, but the 68<sup>th</sup> would have a B/C ratio less than  
15 one.

16 The Commission should order PG&E to expand its underground  
17 protection program by 50 percent, to a total of 100 fuses and interrupters, by  
18 identifying additional underground fuses and interrupters which would have  
19 an incremental B/C ratio well above one. The Commission should also

---

<sup>128</sup> \$553.8 million benefit / increased cost of \$78 million x 1.5 = 553.8/117 = 4.7. If the benefit were only \$469.8 million (Ex. PGE-4 workpapers, p. 15-15), the B/C ratio would still be 469.8/117 = 4.02.

<sup>129</sup> Ex. PG&E-4, p. 15-24. Ex. PGE-4 Workpapers, pp. 15-13 and 15-15.

<sup>130</sup> Cost of \$8 million x B/C ratio of 4.6 = benefit of \$36.8 million. Note that PG&E's workpapers show a present value (PV) benefit based on the VOS study of \$31.0 million (Ex. PGE-4 Workpapers, p. 15-15), which suggests a B/C ratio of \$31/\$8 = 3.9, rather than 4.6.

1 authorize the necessary funding for an expanded targeted circuit program.  
2 Increasing an \$8 million program by 50 percent would require an additional  
3 capital investment of \$4 million, or an average of \$1.3 million per year. That  
4 would increase 2014 revenue requirements by roughly \$0.1 million.<sup>131</sup>

5         Given the B/C ratio of 4.6 for the proposed program, the downside risk  
6 of an expanded program is small. If PG&E increased its underground  
7 protection program by 50 percent, to 100 fuses and 100 interrupters, and the  
8 additional underground fuses and interrupters produced no incremental  
9 benefits at all, the overall program B/C ratio would still be over 2.5.<sup>132</sup>

## 10 **VI. PICARRO (EX. PGE-3, CHAPTER 6)**

### 11 **A. Background – How We Got Here**

#### 12 **1. CUE Identified the Problem in the Last GRC Cycle** 13 **– Failure to Adequately Detect and Repair Gas** 14 **Leaks**

15         “Regarding natural gas service, where detecting gas leaks is a  
16 fundamental safety issue, PG&E has discovered that it has been failing to  
17 discover or repair tens of thousands of gas leaks.”<sup>133</sup> That is what CUE wrote  
18 in its expert testimony in PG&E’s last GRC.<sup>134</sup> At that time, the number of

---

<sup>131</sup> Assuming the increased spending was spread evenly across the year, the increase in average 2014 rate base would be \$4 million x 1/3 x 1/2 = \$0.667 million. Assuming an 18% fixed charge rate to convert that rate base increase into a revenue requirement increase, the 2014 revenue requirement would be \$0.667 million x .18 = \$0.120 million.

<sup>132</sup> \$36.8 million benefit / increased cost of \$8 million x 1.5 = 36.8/12 = 3.1. If the benefit were only \$31 million (Ex. PGE-4 workpapers, p. 15-15), the B/C ratio would still be 31/12 = 2.58.

<sup>133</sup> CUE, opening testimony of David Marcus in A.09-12-020, 5/19/10, p. 2.

<sup>134</sup> Ibid.

1 PG&E Gas T&D field employees had been falling for years, and was down 24  
2 percent from its level in 2004.<sup>135</sup>

3 Since the San Bruno explosion, PG&E has enormously stepped up its  
4 attention to gas safety. It has created a separate Gas Transmission and  
5 Distribution organization (in 2011) and has added or is adding more than two  
6 thousand new gas workers in the 2012-14 period.<sup>136</sup> It has also worked off, or  
7 plans to work off by the end of this year, the enormous backlog of known but  
8 unrepaired gas leaks that had built up by 2010. This is noteworthy progress.

9 **2. Picarro is an Attempt to Improve Gas Leak**  
10 **Detection Technology**

11 As part of its efforts to recover from its past history of insufficient leak  
12 detection, PG&E has become a leader in implementing a potentially  
13 revolutionary new technology. The Picarro technology is a methodology,  
14 comprising both new leak detection technology and adaptations to use that  
15 technology, which holds out the promise of detecting more leaks than  
16 traditional leak detection methods, at a lower cost. PG&E's GRC application  
17 proposes to implement Picarro in 2014 in three of PG&E's gas divisions.  
18 DRA also proposes a substantial move towards use of the Picarro approach.

19

---

<sup>135</sup> Ibid., p. 15, showing a drop in Gas T&D field service employees from 1572 in 2004 to 1201 in March 2010.

<sup>136</sup> PG&E, response to DR CUE 2-Q10.a., showing Gas T&D staffing increasing from 2534 at 12/31/11 to 4189 at 12/31/12 to a forecasted 4815 by the end of 2014.

1           **B.     What Picarro is and How it Works**

2                   **1.     Picarro Proper is a Method That is a Thousand**  
3                   **Times More Sensitive to the Amount of Gas in the**  
4                   **Air – But Does Not Find the Actual Physical Leak**

5           The Picarro technology relies upon high speed spectroscopy to detect  
6 methane in concentrations in the parts per billion range in the time that a  
7 moving vehicle travels just a few feet. That is up to a thousand times more  
8 sensitive than the traditional methods which involve walking the path of  
9 underground gas lines with a detector sensitive to methane in the parts per  
10 billion range. However, the Picarro detector by itself does not find any gas  
11 leaks. For that several more steps are required.

12           At the same time that a vehicle with a Picarro detector is being driven  
13 through a neighborhood with PG&E gas service, local wind speeds and wind  
14 types are also being detected or measured. From that data, a map is  
15 generated that shows the area within which any gas found by the detector is  
16 estimated to have originated. Using the vehicle-based data, a foot search is  
17 then made to detect and rate the actual leaks responsible for the plume of gas  
18 located from the vehicle. In addition, the Picarro-generated maps of plume  
19 areas are matched against PG&E’s maps of gas pipe locations to identify any  
20 areas which have gas pipes but were not inside the detection radius of the  
21 Picarro detector.<sup>137</sup> Those areas are also searched on foot for leaks.

---

<sup>137</sup> For example, if there were a strong wind from north-to-south, the Picarro search radius might not cover gas services located on the north side of a particular street. PG&E tries to mitigate this risk by driving each street twice, preferably at different times of day when wind

1                   **2.     The “Picarro Methodology” Combines Picarro**  
2                   **Detectors with Foot-Based Search and Evaluation,**  
3                   **But Still Reduces Overall Leak Detection Costs**  
4

5           Thus the “Picarro methodology” referred to in this testimony is really a  
6 combination of several linked actions: vehicle-based detection of leaks, vehicle  
7 and software-based mapping of the area(s) from which those leaks could have  
8 originated, foot-based search to find specific locations of Picarro-identified  
9 leaks, foot-based search of areas that the vehicle-based Picarro search did not  
10 cover, and foot-based evaluation and grading of leaks once found. In addition,  
11 the Picarro methodology requires increased foot patrols to monitor corrosion,  
12 which would otherwise be done as part of the traditional leak detection  
13 methods that are entirely foot-based.

14           Even with its multiple steps, the “Picarro methodology” is still much  
15 cheaper than traditional leak detection methodologies that involve entirely  
16 foot-based leak detection. The staff time savings from vehicle-based leak  
17 detection outweigh the capital costs associated with the Picarro detectors  
18 themselves and the unavoided labor costs for the detection and grading of the  
19 leaks themselves, as well as the labor costs for covering the small areas not  
20 covered by the Picarro detectors.

21           **C.     Picarro Methodology Results**

22           PG&E has performed and published two side-by-side comparisons of  
23 the Picarro methodology with traditional leak detection methodology. Those

---

direction is likely to be different, but there will always be some areas for which the Picarro detector returns no data.

1 two studies analyzed 16 plats each in PG&E's Sacramento and Diablo  
2 divisions, in February through April 2012. In the year since, there have been  
3 no published results from PG&E comparing the Picarro methodology to  
4 traditional gas leak detection methods.

5 **1. Three Major Results from the 2012 Analyses**

6 The 2012 PG&E studies had three major results, two of them  
7 anticipated and the third one very surprising indeed.

8 **a. Picarro is cheaper, at least in labor terms, as**  
9 **a leak detection methodology**

10  
11 First, both studies found that leak detection using Picarro was cheaper.  
12 For the Sacramento Division, the total time required for all components of  
13 the Picarro methodology was 192 hours, versus 369 hours with the  
14 traditional method.<sup>138</sup> The corresponding times for the Diablo division were  
15 252 hours with the Picarro methodology and 343 hours with the traditional  
16 methodology.<sup>139</sup> Overall, Picarro reduced time costs by 38 percent.<sup>140</sup> While  
17 these savings would be offset in part by its capital costs and operating  
18 expenses for vehicles and technology, they are probably enough to make  
19 Picarro cheaper overall than traditional methods of leak detection.

20 **b. Picarro methodology finds a lot of leaks the**  
21 **traditional methods do not.**

22  
23 Second, both studies found that the Picarro methodology detected a lot  
24 more leaks than the traditional approach. In Sacramento, the Picarro

---

<sup>138</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0.

<sup>139</sup> Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 7.0.

<sup>140</sup>  $(369-192+343-252)/(369+343) = .376$ .

1 methodology found 163 leaks while the traditional methodology found only  
2 117.<sup>141</sup> In the Diablo division, the disparity was even larger: Picarro found  
3 339 leaks while the traditional approach found barely half as many, or 189  
4 leaks.<sup>142</sup> Overall, the Picarro approach found 64 percent more leaks than the  
5 traditional approach.<sup>143</sup> The Picarro methodology not only found more leaks  
6 overall, it found more leaks of every grade,<sup>144</sup> as DRA also acknowledges.<sup>145</sup>

7 **c. The leaks found by traditional methods are**  
8 **largely not found by the Picarro methodology**

9 The third result of the 2012 side-by-side comparisons was the  
10 surprising one. While Picarro found a lot of leaks missed by the traditional  
11 method, it largely failed to find the leaks found by the traditional on-foot  
12 method. In Sacramento, where the traditional method found 117 leaks,  
13 Picarro found only 25 of those 117.<sup>146</sup> In the Diablo division, the disparity  
14 was even larger. Traditional methods found 189 leaks, only 23 of which were  
15 also found by Picarro.<sup>147</sup> Overall, less than 16 percent of the leaks found by  
16 the traditional methodology were also found by Picarro.<sup>148</sup> Basically, Picarro  
17 did not merely find *more* leaks than the traditional approach, it found

---

<sup>141</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 3.0. The 163 leaks are net of 75 false alarms, where Picarro sensors detected gas but an on-foot search was unable to find an associated leak. Ibid., pp. 7-8.

<sup>142</sup> Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0.

<sup>143</sup>  $(163-117+339-189)/(117+189) = .641$ . Note that DRA claims that Picarro can only be expected to find 33% more leaks than the traditional approach, contrary to the Diablo and Sacramento data. Ex. DRA-9, pp. 80-81.

<sup>144</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 3.0 and Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0.

<sup>145</sup> Ex. DRA-9, p. 124.

<sup>146</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 3.0.

<sup>147</sup> Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0.

<sup>148</sup>  $(25+23)/(117+189) = .157$ .

1 *different* leaks. Of the total of 760 distinct leaks found by the two  
2 approaches, only 48 (6 percent) were found by both.<sup>149</sup>

3 Because there is little overlap between the leaks found by the Picarro  
4 methodology and those found by traditional methodology, the effect of using  
5 both is to find far more leaks than either alone would find. While Picarro  
6 itself finds 64 percent more leaks than the traditional approach, doing both  
7 finds 148 percent more leaks than the traditional method.<sup>150</sup>

8 **2. The Results of the 2012 Analyses Apply to All**  
9 **Relevant Leak Types**

10 One question is whether the disparity between Picarro and traditional  
11 leak methods applies to all types of leaks. Perhaps one method is better for  
12 minor (Grade 3) leaks, while the other is better for larger, more serious leaks.  
13 The data contradict such a hypothesis. Because Grade 1 leaks are required  
14 to be fixed immediately, it was not possible to know whether the Grade 1  
15 leaks found by Picarro would also have been found by the traditional method.  
16 But for every other grade of leak (2, 2+, 3, and meter set leaks), the same  
17 result occurred. For every grade of leak, Picarro found more leaks than the  
18 traditional method, but found few of the leaks detected by the traditional  
19 methodology. For Grade 2+ leaks, Picarro found 50% of the particular leaks  
20 found by the traditional approach.<sup>151</sup> But for Grade 2 it found only 44%,<sup>152</sup>

---

<sup>149</sup>  $(25+23)/(306+502-25-23) = .063$ .

<sup>150</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 3.0, and Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0, showing 306 leaks found by the traditional method alone, and 760 found by both methods together.  $(760-306)/306 = 1.484$ .

<sup>151</sup> Ibid. 1 leak out of 2.

<sup>152</sup> Ibid. 24 leaks out of 55.



1 and for Grade 3 only 30%.<sup>153</sup> And for meter set leaks, Picarro found only 5%  
2 of the leaks that were found by the traditional in-person inspection.<sup>154</sup>

3 Similarly, the 2012 analyses show that using both leak detection  
4 methods finds far more leaks than the traditional method for all grades of  
5 leaks. In particular, using both methods finds six times as many Grade 2+  
6 leaks,<sup>155</sup> more than twice as many Grade 2 leaks,<sup>156</sup> more than three times as  
7 many Grade 3 leaks,<sup>157</sup> and more than twice as many meter set leaks.<sup>158</sup>

#### 8 **D. Policy Implications for the Picarro Methodology**

##### 9 **1. Picarro Should be Used**

10 The fact that the Picarro methodology finds previously unfound leaks,  
11 and a lot of them, implies that PG&E's proposal to introduce the Picarro  
12 methodology on an increasingly large scale in its service area should be  
13 approved.

##### 14 **2. Picarro Should Not Replace Traditional Methods**

15 On the other hand, the fact that existing methods find many leaks that  
16 Picarro misses, including Grade 2 and Grade 2+ leaks, implies that PG&E  
17 should not be permitted, at this time, to use the Picarro methodology in place  
18 of traditional methods. Rather, PG&E should be required, for this GRC cycle,  
19 to use Picarro only as a supplement to current methods. In the next GRC, if

---

<sup>153</sup> Ibid. 12 leaks out of 40.

<sup>154</sup> Ibid. 11 leaks out of 212.

<sup>155</sup> Ibid. 13 versus 2.

<sup>156</sup> Ibid., 146 versus 55.  $146/55 = 2.65$ .

<sup>157</sup> Ibid. 126 versus 40.  $126/40 = 3.15$ .

<sup>158</sup> Ibid. 462 versus 212.  $462/212 = 2.18$ .

1 further research results presented then demonstrate that improvements to  
2 the Picarro methodology are allowing it to find the leaks that current  
3 methodology finds, and not just leaks that the current methodology misses,  
4 then Picarro can be used as a replacement methodology.

5 **3. The Cost Implications of Picarro are Currently**  
6 **Uncertain**

7 PG&E's side-by-side studies provided data indicating that Picarro will  
8 likely be cheaper than current leak detection methods, when and if it is  
9 capable of replacing them rather than supplementing them. But that does  
10 not mean that Picarro will cause PG&E's costs to go down. Leak detection is  
11 only part of the cost associated with keeping the gas distribution system safe.  
12 Leak repair is the other half of the picture. Because Picarro finds so many  
13 more leaks than the current methods, it will cause leak repair costs to go up.  
14 It will also cause corrosion detection costs to go up as there will no longer be  
15 routine foot traffic to all services by PG&E gas employees.

16 **a. Uncertain costs of leak detection**

17 PG&E's two 2012 studies found different ratios of Picarro hours to  
18 traditional hours in the two areas studied; the ratios differed by a factor of  
19 about 40 percent,<sup>159</sup> suggesting an uncertainty as to Picarro leak detection  
20 labor costs of plus or minus 20 percent.

21

---

<sup>159</sup> Ibid, Figures 5.0 (Sacramento) and 7.0 (Diablo), showing a Picarro/traditional labor ratio of 52% in one division and 73% in the other.  $73/52 = 1.40$ .

1                                   **b.     Uncertain costs of leak repair**

2           Leak repair costs are generally a function of leak detection levels: the  
3 more leaks found, the more it will cost to repair them. The difference  
4 between the two areas in terms of number of leaks found was substantial. In  
5 Sacramento, the Picarro method found 26 leaks of Grade 1, 2+, or 2 that the  
6 traditional method had missed.<sup>160</sup> In the Diablo Division, in the same  
7 number of plats, the Picarro method found 83 leaks of Grade 1, 2+ or 2 that  
8 the traditional method had missed, or more than three times as many.<sup>161</sup>  
9 This suggests that there is still a great deal of uncertainty as to how many  
10 leaks requiring repair will be found by a given level of Picarro leak detection  
11 efforts.

12                                   **4.     PG&E’s Proposed Two-Way Balancing Account**  
13                                   **Should be Approved**  
14

15           Given the uncertainty about how many incremental leaks the Picarro  
16 methodology will find over and above traditional leak detection methods, and  
17 given the uncertainty about how much leak repair costs will increase to fix  
18 those newly-found leaks, PG&E’s proposed two-way balancing account  
19 relating to Picarro costs and associated leak repair costs should be approved.  
20 To attempt to pick a single number now for the costs of Picarro-based leak  
21 detection and the associated repair costs would be a futile exercise. It would  
22 give PG&E a financial incentive to not repair leaks, and would reward PG&E  
23 if Picarro turns out not to work as well as tests to date suggest it will. A two-

---

<sup>160</sup> Sacramento Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 3.0.

<sup>161</sup> Diablo Picarro Leak Detection Report 1 25 2013 FINAL.pdf, Figure 5.0.

1 way balancing account will both cover PG&E costs if Picarro works better  
2 than expected (triggering high repair costs), and provide refunds if Picarro  
3 works more poorly than expected, or is used less than currently expected.

4 **5. More Research Should be Required Before the Next**  
5 **GRC**

6  
7 PG&E should be required to continue side-by-side analyses of tradition  
8 and Picarro methodologies to see if technological improvements to Picarro can  
9 increase the overlap between leaks found by the two methodologies. In its  
10 next GRC filing, due in about two years, PG&E should be required to report  
11 on those continued studies and any policy changes that may be called for in  
12 response to them.<sup>162</sup>

---

<sup>162</sup> DRA has also called for further research on Picarro, with results to be reported in the next GRC. See Ex. DRA-9, p. 76, calling for Picarro to be treated as a “pilot” until the next GRC.