## **Comments on Performance Metrics**

# **Developmental Workshop on Performance Metrics**

# June 27, 2013 at the California Public Utilities Commission

# R.11-02-019: Order Instituting Rulemaking to Adopt New Safety and Reliability

# Regulations

	Page
Suggested Safety Performance Metrics	2
Appendix A. Example Safety Culture Surveys	7
Appendix B. CPUC GO 167 Root Cause Analysis Standard	13

Chris Parkes Sr. Utilities Engineer California Public Utilities Commission Safety and Enforcement Division Risk Assessment Section of that Gas, Safety and Reliability Branch 505 Van Ness Avenue San Francisco, CA 94102 (415) 703-1975

## **Suggested Safety Performance Metrics**

Below are comments supporting the adoption of specific safety performance metrics. Some of these metrics were discussed at the June 27 workshop. Some are currently used by utilities and industries as *leading* or *lagging* indicators of safety performance. In the context of process safety, The Center for Chemical Process Safety defines *Lagging Metrics* as a retrospective set of metrics that are based on incidents that meet the threshold of severity that should be reported as part of the industry-wide process safety metric. *Leading Metrics* are a forward looking set of metrics which indicate the performance of the key work processes, operating discipline, or layers of protection that prevent incidents.<sup>1</sup>

Five particular metrics are suggested below. Examples are included for how each metric may be implemented.

# 1. Safety Culture Metric (Leading Metric)

- Survey different classes and locations of workers using a standard set of questions on a defined schedule
  - i. Example: Survey 1/3 of workers annually

<sup>&</sup>lt;sup>1</sup> http://www.aiche.org/sites/default/files/docs/pages/CCPS\_ProcessSafety\_Lagging\_2011\_2-24.pdf

- b. Numerically score responses
  - i. Example: Adopt a numerical "Safety Culture Perception Index". The Contra Costa County Industrial Safety Ordinance requires industrial facilities to assess safety culture. See Appendix A for sample survey questions and a sample numerical safety culture index that Contra Costa provides as guidelines for industrial facilities. Similar survey questions may by tailored for the utility industry. The Navy and other organizations use surveys to assess safety culture.<sup>2</sup>
- c. Report on average numerical survey scores by worker class and location
- d. Report on metric trends

# 2. Incident Metric (Lagging Metric)

- a. Define incident types and criteria for classification as an incident. Include contract workers and the public in this metric.
  - i. Examples:
    - 1. Fatalities and injuries requiring in-patient hospitalization
    - 2. Property damage exceeding \$50,000

<sup>&</sup>lt;sup>2</sup>http://cchealth.org/hazmat/pdf/iso/section\_f.pdf

http://cchealth.org/hazmat/pdf/iso/attachment e.pdf

https://www.safetyclimatesurveys.org/mainpage.aspx

http://www.dupont.com/products-and-services/consulting-services-process-technologies/operation-riskmanagement-consulting/uses-and-applications/safety-perception-survey.html

- Incidents resulting in significant public attention or media coverage
- b. Report annually on quantity of incidents by incident type.
- c. Report on metric trends

# 3. Lost Work Day Metric (Lagging Metric)

- a. Example: Number of injuries that result in Lost Work Days per 1000 employees
- b. Report on metric trends

# 4. Past Due Actions (Backlog) Metric (Leading Metric)<sup>3</sup>

- a. Define "Actions"
  - Example: Work Orders, including Maintenance, Repairs, Audits, Inspections, Upgrades, and Corrective Actions, including Corrective Actions identified from Root Cause Analyses

# b. Define "Past Due"

- i. Example: Company defined past due date for each Work Order
- c. Define Staffing Levels
  - i. Example: Define quantity of workers by worker classification
- Report annually on number of past due actions relative to number of actions broken down by category and location.

<sup>&</sup>lt;sup>3</sup> <u>http://www.aiche.org/sites/default/files/docs/pages/CCPS\_ProcessSafety\_Lagging\_2011\_2-24.pdf</u>

- e. Report annually on staffing levels by worker classification
- f. Report on metric trends
  - i. Past Due Actions (Backlog) and Staffing Level metrics are reported together as supplemental indicators of adequate staffing.

# 5. Root Cause Analysis Program Effectiveness (Lagging and Leading Metric)

a. Define Criteria for Events or Conditions that warrant a Root Cause

Analysis ("RCA Triggers")<sup>4</sup>

- i. RCA Trigger Examples:
  - 1. Incidents as defined in the Incident Metric described earlier
  - 2. "Near Misses" as defined by the company
    - a. Example: An undesired event that under slightly
       different circumstances could have resulted in harm to
       people, damage to property, equipment, or
       environment.<sup>5</sup>
    - b. Example: Lockout/Tagout process failures. An incident did not occur, but it could have.
  - Recurring work low priority orders that, when aggregated together, are significant.

<sup>&</sup>lt;sup>4</sup> CPUC General Order 167: See Appendix B

<sup>&</sup>lt;sup>5</sup> http://www.aiche.org/sites/default/files/docs/pages/CCPS\_ProcessSafety\_Lagging\_2011\_2-24.pdf

# a. Example: Low priority leak repairs

- b. Report annually on the number of RCA Triggers
- c. Report annually on the number of RCA Triggers by root cause category. Typically events and conditions that trigger a Root Cause Analysis, have multiple root causes.
- d. Report annually on the number of Root Cause Analyses completed
- e. Report annually on the number of Root Cause Analysis Corrective Actions completed compared to the number of Corrective Actions identified in the Root Cause Analyses
- f. Report on metric trends
  - i. Example: Number of RCA Triggers by root cause category

While some metrics may not be suitable for direct comparison between utilities, trends in metrics at a particular company will provide information to the company and regulators on the effectiveness and performance of company programs in improving safety.

# Appendix A

# Example Safety Culture Surveys

The Navy conducts Safety Climate Assessment Surveys:<sup>6</sup>

	Strongly Disagree	) Disagree	() Neutral	O Agree	Strongly Agree	⊘ N/A ⊘ Don't Know
CALL STREAM ST. 31 ST.	Enter any					
	here:					
TAKE A SURVEY	2. My unit provides adequa	sto rocognition for	induidual cafety ac	te		
DRVETINEORMATION	L. My unit provides adeque	ale recognition to	interviewan salety ac	ы. Г	1	16.
AMPLE SURVEYS	0	0	$\odot$	0		() N/A
New CSA Survey	Strongly Disagree	Disagree	Neutral	Agree	Strongly Agree	Don't
New MCAS Survey New ASPA Survey				I	J	Know
and the second	Enter any comment					
	here					
lew HHQ Survey						
MTRCYCL Survey	3. Safely decisions are ma	ide at the proper l	evels by the most qu	ualified personnel.		
080 Survey		6	6		Ø	N/A
			(C)			
D&R Survey	52 S.		1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 -		and a	
	Strongly Disagree	Disagree	Neutral	Agree	Strongly Agree	Don't
DBR Survey MV Survey ATC Survey		Disagree	1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 -	Agree	and a	Don't
MV Survey ATC Survey LT MET Survey	Strongly Disagree	Disagree	1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 -	Agree	and a	Don't
MV Survey ATC Survey LT NET Survey Hazing Survey	Enter any	Disagree	1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 - 1990 -	Agree	and a	Don't
IV Survey ATC Survey LT MET Survey Hazing Survey T UP UNIT SURVEYS	Enter any comment here:		Neutral	Agree	and a	
IV Survey TC Survey LT NET Survey tazing Survey T UP UNIT SURVEYS APLE RESULTS	Enter any comment		Neutral	Agree	and a	Don't
IV Survey TC Survey LT MET Survey tazing Survey F UP UNIT SURVEYS IAPLE RESULTS W RESULTS	Enter any comment here:		Neutral		and a	Don't
IV Survey TC Survey LT MET Survey tazing Survey T UP UNIT SURVEYS MPLE RESULTS W RESULTS RVEY ADMIN	Enter any comment here 4. SOPs and safety rules a		Neutral	Agree	Strongly Agree	Don't Know
IV Survey TC Survey T MET Survey tazing Survey TUP UNIT SURVEYS APLE RESULTS W RESULTS RVEY ADMIN ERVENTIONS	Enter any comment here:	are enforced in my	Neutral unit.	©	Strongly Agree	O Don't Know
IV Survey TC Survey TC Survey TUP UNIT SURVEYS PUP UNIT SURVEYS PLE RESULTS W RESULTS RVEY ADMIN ERVENTIONS UE PAPERS UE PAPERS	Enter any comment here 4. SOPs and safety rules a Strongly Disagree Enter any	are enforced in my	Neutral unit.	©	Strongly Agree	O Don't Know
IV Survey TC Survey T MET Survey tabling Survey T UP UNIT SURVEYS MPLE RESULTS W RESULTS RVEY ADMIN ERVENTIONS UE PAPERS JGGESTIONS	Enter any comment here: 4. SOPs and safety rules a Strongly Disagree	are enforced in my	Neutral unit.	©	Strongly Agree	O Don't Know

<sup>&</sup>lt;sup>6</sup> <u>https://www.safetyclimatesurveys.org/mainpage.aspx</u>

# Example Safety Culture Surveys

Contra Costa County provides Safety Culture Assessment Guidance for meeting the requirements of the Contra Costa Industrial Safety Ordinance:<sup>7</sup>

### **II. MY OPINIONS AND COMMENTS**

Please review each statement below and select the number from 1 to 5 that best expresses your response to the statement. Please note that selecting number 3 in response to a question means either that you do not know or that you do not have an opinion.

#### **Process Safety Reporting**

Note: For each statement below, you should select "3" under the response labeled "?" only if you do not know or you do not have an opinion.

	Tend to Dis			Disa agre		ø
	Tend to Agr	968 	ree			
ł.	This refinery provides adequate training on hazard identification, control and reporting		D			ß
2.	I have received training on hazard identification, control and reporting in the last 12 months		1	D	Ð	ß
3.	I can report hazardous conditions without fear of negative consequences		1	۵J	•	ß
4.	In general, workers don't bother to report minor process-related incidents, accidents, or near misses		1	D	•	ß
5.	I believe a culture exists at this refinery that encourages raising process safety concerns		2	▣	€	ß
6.	Corrective action is promptly taken when unsafe process safety conditions are brought to management's attention	Ω	2	Ø	⊡	Ø
7	I am confident that noncose entativities and					

<sup>7</sup> http://cchealth.org/hazmat/pdf/iso/attachment\_e.pdf

The above reference link includes an example for a numerical "Employee Perception Index"

Example safety culture assessment questions were developed as part of the Baker Panel investigation of the 2005 Texas City refinery explosion

8 v	r ann connaicht chail proclas sanory issues are.			
	a. Thoroughly investigated	DD	4	Ø
	b. Appropriately resolved	םם	€	Ø
8.	Workers are informed about the results of process related incident, accident, and near miss investigations	30	I	Ø
<b>9</b> .	I am satisfied with the process safety reporting system at this refinery	23	⊡	ß
10.	I do not hesitate to report actions or conditions that raise a process safety concern, even when a co-worker is involved	٥D	•	Ø

Please provide any comments you have about Process Safety Reporting in the space below.

## Safety Values / Commitment to Process Safety

Note: For each statement below, you should select "3" under the response labeled "?" only if you do not know or you do not have an opinion.

	Disagree
Tend	to Disagree ?
Tend to Agr	
My supervisor puts a high priority on process safety through actions and not just empty slogans	
Refinery management puts a high priority on process safety through actions and not just empty slogans	
Operational pressures do not lead to cutting corners where process safety is concerned	
At this refinery, process safety improvement is a long-term commitment that is not compromised by short-term financial goals.	
In my opinion, the people at my refinery with specific process safety responsibilities have the:	
a. Authority to make changes	
b. Resources to make changes	
In my opinion, process safety programs at my refinery have:	
a. An adequate number of people responsible for process safety	
b. Adequate funding	
	Second Sector Sector Sec

L	Supervisory Involvement and Support	bien tretenen orde	nanninana	10000000000	nassaninananana
	E For each statement below, you should select "3" under the response labeled "? or you do not have an opinion.	" only	if y	ou d	lo ne
					gree
	T	nd to	Disa	igre	e
	Tend	to Ag	ree		
		Agree			
21.	In my work group, process safety concerns are secondary to achieving production goals	🗆	▣	⊡	•
22.	My supervisor sometimes asks me to operate an unsafe process	🗆			•
23.	My supervisor will support me if I refuse to participate in unsafe work	🛛	ً	D	•
24.	My supervisor encourages me to identify and report unsafe conditions		ً	D	•
25.	My supervisor makes sure that procedures relating to the following activities are safe before such activities are initiated:				
	a. Operations	. 🗆	2		•
	b. Maintenance	m	[7]	D	•
		isi Annad	- Newsonia -		
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion.	only if y	you		
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion.	only if y	you ( Disa	gre	
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend	only if y to Dis	you Disa agro	gre	
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion.	to Dis	you Disa agro	gre	
ow o	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to	to Dis	you Disa agro	gre	
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to Agr nterlocks, alarms, and other process safety-related devices are regularly:	to Dis Agree	pou Disa agri	ee	
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to Agr nterlocks, alarms, and other process safety-related devices are regularly:	to Dis Agree ee	pou Disa agri	ee	•
	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to Agr nterlocks, alarms, and other process safety-related devices are regularly: Tested	to Dis Agree ee	pou d Disa agri ?	ere ere	•
	Procedures and Equipment         For each statement below, you should select "3" under the response labeled "?" of ryou do not have an opinion.         Tend         Tend to Agr         Interlocks, alarms, and other process safety-related devices are regularly:         Tested         Devices and the process safety-related devices are regularly:         Tested	to Dis Agree ee	pou d Disa agri ?	ere ere	•
	Procedures and Equipment         For each statement below, you should select "3" under the response labeled "?" of ryou do not have an opinion.         Tend         Tend to Agr         Interlocks, alarms, and other process safety-related devices are regularly:         .       Tested.         .       Maintained         .       Disabled or failed process safety devices are restored to service as soon as possible         Written operating procedures are:	to Dis Agree ee	pou d Disa agru ?	gre œ	e 3 3
ow o and a t t v a a	Procedures and Equipment         For each statement below, you should select "3" under the response labeled "?" of ryou do not have an opinion.         Tend         Tend to Agr         Tend to Agr         Interlocks, alarms, and other process safety-related devices are regularly:         .       Tested	to Dis Agree ce	pou d Disa agru ?	gre œ	e 3 3
>>> o	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to Agr nterlocks, alarms, and other process safety-related devices are regularly:	to Dis Agree ce		e e	e 3 3
ow o in in in in in in in in in in in in in	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion.      Tend     Tend to     Agr nterlocks, alarms, and other process safety-related devices are regularly:      Tested      Maintained Disabled or failed process safety devices are restored to service as soon as possible Written operating procedures are:      Regularly followed      Kept up to date  Procedures exist at this refinery that instruct operators to take action as soon as	to Dis Agree ee 1 2 1 2 1 2 1 2 1 2 1 2		e e	e 3 3 3
ow o and b b f f f f f f f f f f f f f f f f f	Procedures and Equipment For each statement below, you should select "3" under the response labeled "?" o r you do not have an opinion. Tend Tend to Agr nterlocks, alarms, and other process safety-related devices are regularly: . Tested	to Dis Agree ee 1 2 1 2 1 2 1 2 1 2 1 2		e e	e 3 3 3

### Worker Professionalism / Empowerment

Note: For each statement below, you should select "3" under the response labeled "?" only if you do not know or you do not have an opinion.

		Disagree
	Tend	l to Disagree
	Tend to Agr	
36.	I feel that I can influence the process safety policies implemented at this refinery	
37.	Workers at all levels of my refinery actively participate in:	
	a. Hazard reviews and assessments	
	b. Incident and accident investigations	
38.	When a process safety issue is involved, I can challenge decisions made by the following without fear of negative consequence:	
	a. My supervisor	
	b. Refinery management	
39.	Workers sometimes work around process safety concerns rather than report them	
40.	Creating unapproved shortcuts around process safety is not tolerated at my refinery	
41.	I am informed when potentially dangerous processes are started	
42.	I am responsible for identifying process safety concerns at my refinery	
43.	I feel free to refuse to participate in work activities that are unsafe	
44.	Operators are empowered to take corrective action as soon as possible (including shutting down when appropriate) if safety critical interlocks, alarms, or other process safety-related devices fail or become unavailable during operation	12345

Please provide any comments you have about Worker Professionalism / Empowerment in the space below.



	Process Safety Training					
	For each statement below, you should select "3" under the response labeled "?" or you do not have an opinion.	only if you do not				
	Тепк	Disagree I to Disagree 1				
	Tend to Ag					
45.	The training that I have received does not provide me with a clear understanding of the process safety risks at my refinery					
46.	I know how to access appropriate process safety resources if I need them					
47.	The following receive the necessary process safety training to do their job safely:					
	a. New workers					
	b. Experienced workers					
	c. My supervisor					
	d. Contractors					
48.	The process safety training that I have received allows me to recognize when a process should be shut down if safety critical interlocks, alarms or other process-safety devices fail or become unavailable during operation					
49.	The process safety training that workers receive at my refinery is adequate to prevent process-related incidents, accidents and near misses	12343				

# Appendix B

CPUC General Order 167, Maintenance and Operation Standards

for Electric Generating Facilities

Maintenance Performance Standard 4.

(Covers Root Cause Analysis)<sup>8</sup>

# MS 4 - Problem Resolution and Continuing Improvement

## **Performance Standard**

The company values and fosters an environment of continuous improvement and timely and effective problem resolution.

## **Assessment Guidelines**

## A. Self-Assessment

Self-Assessment activities are used to compare actual performance to management's expectations, and to identify and correct areas needing improvement. While self-assessments, by definition, are driven from within, they may be used to measure internal performance to external criteria, such as ISO, EPA or OSHA. Self-assessment is both a discreet activity and a continuous process that includes such activities as: Dedicated teams, with a specific chartered objective to assess certain program(s) or element(s).

<sup>&</sup>lt;sup>8</sup> <u>ftp://ftp.cpuc.ca.gov/ElectricGenerationPerf/Maintenance\_Standards\_Final\_Renumbered.doc</u>

Management monitoring of on-going performance through performance metrics or problem resolution process monitoring.

Discreet event investigations

# B. Problem Reporting, Root-Cause Analysis, and Corrective Actions

A systematic approach and process is used to identify and report problems, determine the cause(s) and establish corrective actions to prevent recurrence. Attributes of successful programs include:

Encouraging employees to report problems at low thresholds of significance.

Using a graded approach to significance, and performing more extensive root cause determination to those problems having high significance, and trend and track those with low significance.

Trending capability on information such as "cause code" or equipment or process involved.

Tracking of corrective actions to closure.