

Rulemaking No.: R.12-03-014

Exhibit No.: \_\_\_\_\_

Witness: Robert Sparks

Order Instituting Rulemaking to Integrate and Refine  
Procurement Policies and  
Consider Long-Term Procurement Plans.

Rulemaking 12-03-014

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

1  
2

**BEFORE THE PUBLIC UTILITIES COMMISSION OF THE  
STATE OF CALIFORNIA**

Order Instituting Rulemaking to Integrate and Refine  
Procurement Policies and  
Consider Long-Term Procurement Plans.

Rulemaking 12-03-014

3  
4  
5  
6  
7  
8

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

9 **Q. What is your name and by whom are you employed?**

10

11 **A.** My name is Robert Sparks. I am employed by the California Independent System  
12 Operator Corporation (ISO), 250 Outcropping Way, Folsom, California as Manager,  
13 Regional Transmission.

14

15 **Q. Please describe your educational and professional background.**

16

17 **A.** I am a licensed Professional Electrical Engineer in the State of California. I hold a  
18 Master of Science degree in Electrical Engineering from Purdue University, and a  
19 Bachelor of Science degree in Electrical Engineering from California State  
20 University, Sacramento.

21

22 **Q. What are your job responsibilities?**

23

24 **A.** I manage a group of engineers responsible for planning the ISO controlled  
25 transmission system in southern California to ensure compliance with NERC,  
26 WECC, and ISO Transmission Planning Standards in the most cost effective  
27 manner. With the California transmission system undergoing a major  
28 transformation, there are significant uncertainties that must be considered. In  
29 particular, I have been involved in the studies conducted by the ISO to evaluate

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 2 of 32**

1 systems needs in the absence of the San Onofre Nuclear Generating Station  
2 (SONGS).

3

4 **Q. What is the purpose of your testimony?**

5

6 **A.** I will describe the results of the study conducted by the ISO as directed by the  
7 May21, 2013 Revised Scoping Ruling and Memo of the Assigned Commissioner  
8 and Administrative Law Judge (hereinafter “the Revised Scoping Ruling”). I will  
9 also make some recommendations as to possible next steps in Track 4 of this LTPP  
10 proceeding.

11

12 **Q. Have you provided testimony about local capacity needs previously in this  
13 proceeding and in other dockets?**

14

15 **A.** Yes. I submitted opening and rebuttal testimony addressing the ISO’s assessment of  
16 local area needs in the LA Basin and Big Creek/Ventura areas in this LTPP docket,  
17 Track 1. My recommendations in Track 1 were based on the ISO’s once through  
18 cooling studies conducted as part of the 2011/2012 transmission planning process. I  
19 provided similar testimony about local area needs in the San Diego local area in  
20 Docket A.11-05-023 which was based on the same once through cooling studies for  
21 San Diego. My supplemental testimony in that proceeding can be found at  
22 [http://www.caiso.com/Documents/2012-04-06\\_A11-05-023\\_Sparks\\_SuppTest.pdf](http://www.caiso.com/Documents/2012-04-06_A11-05-023_Sparks_SuppTest.pdf).  
23 The Commission issued Decision 13-03-029 in A.11-05-023 on March 21, 2013 and  
24 Decision 13-02-015 in Track 1 on February 13, 2013.

25

26 **Q. What was the ISO asked to do in Track 4?**

27

28 **A.** The once through cooling study results for Los Angeles and San Diego local areas  
29 that I presented in prior testimony included the assumption that SONGS would be in

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 3 of 32**

1 operation through 2022. Although the SONGS units were out of service during the  
2 evidentiary hearings in both dockets, without additional analysis and record  
3 evidence, the Commission could not make a determination about procurement needs  
4 without SONGS. Track 4 was established to evaluate the impact of a long-term  
5 SONGS outage on mid-term and long-term local capacity needs, building on the  
6 modeling assumptions adopted by the Commission in the Track 1 and SDG&E  
7 PPTA decisions in A.11-05-023. The Commission requested that the ISO model  
8 three separate cases: 2022 without SONGS, 2022 with SONGS and 2018 without  
9 SONGS. Attachment A to the Revised Scoping Ruling contains the modeling  
10 assumptions to be used to study the three scenarios. It is my understanding that the  
11 purpose of the studies described in the Revised Scoping Ruling is to provide  
12 information about the “delta” (i.e., difference) between the resource needs  
13 determined by the Commission in the two previous decisions and resources needed  
14 to meet reliability requirements in the absence of SONGS.

15

16 **Q. Please briefly describe the differences between the scenarios and modeling**  
17 **assumptions set forth in Attachment A and the ISO’s once-through-cooling**  
18 **study scenarios.**

19

20 **A.** Probably the biggest differences between the prior ISO studies and the Track 4  
21 analysis are: (a) because the SONGS outage significantly impacts both San Diego  
22 and LA Basin, these local capacity areas have been studied together as one SONGS  
23 Study Area; (b) the inclusion of future preferred resource assumptions; and (c) non-  
24 once through cooling (OTC) generation retirement assumptions, based on facility  
25 age (more than 40 years old). The ISO utilized the commercial interest RPS  
26 portfolio from the 2012/2013 transmission planning cycle. This updated portfolio  
27 has some minor changes in the system-connected distributed generation (DG)  
28 compared to the same portfolio used in the 2011/2012 transmission planning cycle  
29 by having about 193 MW more of installed capacity assumptions for DG (or

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 4 of 32**

1 approximately 87 MW of net qualifying capacity). The local capacity area study  
2 methodology and 1-in-10 year load forecast all of which the ISO used in the OTC  
3 studies, were approved in the LTPP and SDG&E decisions and used for Track 4  
4 purposes, so there are no differences with respect to these inputs.

5

6 Because the Commission decisions approved demand response and incremental  
7 energy efficiency assumptions that differed from those the ISO used in the OTC  
8 studies, Attachment A provided very specific modeling instructions with respect to  
9 these resources and load modifiers. The Commission also directed the ISO to make  
10 certain assumptions about generator retirements for both OTC and non-OTC  
11 generating units, and provided specific locational information for incremental  
12 energy efficiency and demand response. What follows is a description of how the  
13 ISO modeled the assumptions described in Attachment A:

14

15 1. CEC's Load Forecast:

16 The ISO modeled the 2018 and 2022 1-in-10 peak load for the LA Basin and  
17 San Diego local capacity areas based on the CEC's mid-range economic and  
18 demographic assumptions. The most recently adopted forecasts are  
19 contained in the 2012 Integrated Energy Policy Report, August 2012  
20 revision, form 1.5d.<sup>1</sup> The following provides summary of the CEC's 1-in-10  
21 heat wave load forecast for the LA Basin and San Diego local capacity areas.

22

23

**Table 1 – CEC's 1-in-10 Heat Wave Load Forecast**

	<b>2018 Forecast</b>	<b>2022 Forecast</b>
L.A. Basin	21,870 MW	22,917 MW
San Diego	5,652 MW	6,056 MW
Total SONGS Study Area	27,522 MW	28,973 MW

---

<sup>1</sup> [http://www.energy.ca.gov/2012\\_energypolicy/documents/demand-forecast/Mid\\_Case\\_LSE\\_and\\_Balancing\\_Authority\\_Forecast.xls](http://www.energy.ca.gov/2012_energypolicy/documents/demand-forecast/Mid_Case_LSE_and_Balancing_Authority_Forecast.xls)

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

1                     2. Incremental Uncommitted Energy Efficiency (i.e., Incremental EE):

2                     Per the CPUC’s Revised Scoping Ruling, the low level of savings for  
3                     incremental EE was modeled for the studies. The CEC provided specific  
4                     locations (i.e., bus-bar data) for modeling incremental EE. The following  
5                     table provides a summary of the incremental EE, which was further scaled  
6                     up by 4.76% to account for the estimated resulting distribution system loss  
7                     reduction due to the incremental EE. The CEC noted that the incremental  
8                     EE was provided at the customer’s meter level. To account for distribution  
9                     losses when these values are modeled at the sub-transmission voltage level  
10                    (i.e., 66kV or 69kV), between 4 – 5% losses need to be added. The 4.76%  
11                    was provided by SCE and to account for distribution losses. The same factor  
12                    was also utilized for factoring the distribution losses in San Diego as  
13                    SDG&E was unable to provide an estimate at the time. This factor,  
14                    however, is within the range which the CEC mentioned it would be for  
15                    factoring in distribution losses for incremental EE.

16  
17                    **Table 2 – Summary of Incremental EE Assumptions**

	<b>2018 Forecast/Modeled</b>	<b>2022 Forecast/ Modeled</b>
L.A. Basin	427 / 448 MW	751 / 787 MW
San Diego	99 / 104 MW	187 / 196 MW
Total SONGS Study Area	526 / 552 MW	938 / 983 MW

18  
19                    The remainder of SCE service area (i.e., non-LA Basin) was also modeled  
20                    with incremental EE as reflected in the following table. This value equals  
21                    the difference of the total SCE area and the LA Basin values. A factor of  
22                    4.76% to account for distribution losses was also applied to the behind-the-  
23                    meter incremental EE. There was no further additional incremental EE  
24                    modeling for San Diego other than the above values.

**Table 3 – Incremental EE Assumptions for the Remainder of SCE System**

	<b>2018 Forecast/Modeled</b>	<b>2022 Forecast/Modeled</b>
Total SCE	556 / 582 MW	973 / 1019 MW
Non-LA Basin (SCE)	129 / 134 MW	222 / 232 MW

3. Demand Response (DR):

The Revised Scoping Ruling recommended a total of 189 MW of DR to be used for the SONGS Study Area under post first contingency, in preparation for the second contingency condition. This condition is sometimes referred to as an overlapping N-1-1 contingency condition, and is considered a Category C (C.3) contingency by both NERC and WECC reliability standards. The most critical N-1-1 contingency for the SONGS Study Area is the outage of the Sunrise Powerlink, system readjusted, followed by the outage of the Southwest Powerlink. The ISO modeled this amount of DR for the SONGS Study Area based on the following most effective locations in the LA Basin (173 MW), after the occurrence of the first contingency, in preparation for the second contingency. Any location for DR (16 MW) in San Diego would be effective for this critical N-1-1 contingency. For the locations in the LA Basin, the ISO modeled the amount of DR based on recommendations from the CPUC Energy Division staff. For the locations in San Diego, the ISO selected the substations that serve the highest MWs of customer load. Similar to the EE modeling described above, the DR was scaled up by a factor 4.76% to account for distribution losses.

The DR available after occurrence of the first contingency in preparation for the next contingency was based on programs that respond to dispatch instructions within 30 minutes or less, including notification time to customers.

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1 DR based on programs with slower response times would not be available  
2 within the required 30-minute time frame after the first contingency. The  
3 additional DR amount of 997 MW, based on the Revised Scoping Ruling,  
4 would be utilized to mitigate reliability concerns in the post second  
5 contingency condition. This would be applied to contingencies that are of  
6 Category D. An example is a major generating facility outage that occurs  
7 prior to or after the overlapping N-1-1 contingency. The amount of DR  
8 modeled for 2018 time frame is the same as modeled for year 2022.

**Table 4 – DR Modeled at the Most Effective Locations in the LA Basin  
and San Diego Areas**

<b>Substation</b>	<b>2018 (MW)</b>	<b>2022 (MW)</b>
Alamitos	6.75	Same amount as 2018
Barre	27.0	
Del Amo	25.3	
Ellis	42.4	
Johanna	16.2	
Santiago	28.8	
Viejo	9.9	
Villa Park	24.8	
Bernardo	8.4	
Margarita	8.4	
Total	197.95	

13  
14 4. Distributed Generation (DG):

15 There were two types of DG modeled for the studies: one was system-  
16 connected DG (i.e., DG connected beyond the customer load meter) as part  
17 of the CPUC Commercial Interest RPS portfolio, and the other one was



**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 8 of 32**

1           small photovoltaic (PV) to be connected behind the customer load meter.  
2           System-connected DG was modeled in the power flow study cases as part of  
3           the Commercial Interest RPS portfolio. Behind the meter DG (i.e., small  
4           PV), is largely embedded in the IEPR demand forecast, except for an  
5           approximate 1,300 MW of installed capacity in the ISO Balancing Authority  
6           Area. This amount is the net short of meeting the 3,000 MW CSI program  
7           target. As the Revised Scoping Ruling recommended, the location of the  
8           amount of 477 MW and 616 MW of net short installed capacity for behind  
9           the metered PV in the SONGS Study Area (or estimated 216 MW and 278  
10          MW of production at peak load conditions) for 2018 and 2022, respectively,  
11          is difficult to determine and therefore should be considered located in the  
12          most effective locations , similar to the additional larger amount of DR, for  
13          mitigating reliability concerns associated with contingencies that are  
14          subsequent to second contingency condition (i.e., post second contingency)  
15          following an N-1-1 overlapping contingency. Because the Revised Scoping  
16          Ruling discusses the behind the customer load meter-connected DG (small  
17          PV) in detail, the ISO does not want to repeat the assumptions for that  
18          connected DG here, but rather provides information for the system-  
19          connected DG for the SONGS study area. The following table provides the  
20          assumptions of system-connected DG, as part of the Commercial Interest  
21          RPS portfolio that was modeled in the power flow study cases for 2018 and  
22          2022 for the SONGS Study Area. The values are expressed in production  
23          (based on net qualifying capacity) and installed capacity. Net qualifying  
24          capacity was suggested by the CPUC at a factor of about 45% of its installed  
25          capacity at peak loads.

26

**Table 5 – System-Connected Distributed Generation Assumptions**

	<b>2018 NQC / Installed Capacity (MW)</b>	<b>2022 NQC / Installed Capacity (MW)</b>
LA Basin	95 / 211 MW	247 / 549 MW
San Diego Area	186 / 413 MW	210 / 467 MW

5. Transmission Projects:

Per the Revised Scoping Ruling, transmission projects that received the ISO Board and Management’s approval as of March 2013 should be modeled in the study cases; specifically the projects that would affect the local capacity requirements in the SONGS Study Area. The following table includes the latest projects in the SONGS Study Area that were approved by the ISO Board of Governors in the 2012/2013 Transmission Plan.<sup>2</sup>

**Table 6 – List of the latest ISO Board and Management Approved  
Transmission Projects in the SONGS Study Area**

<b>ISO Board Approved Transmission Projects in the SONGS Study Area (2012/2013 Transmission Plan)</b>	<b>LA Basin</b>	<b>San Diego Area</b>
Barre – Ellis Reconfiguration Project	√	
Install one 80 MVAR (each) at Johanna and Santiago and two 80 MVAR shunt capacitors at Viejo Substation	√	
Convert Huntington Beach Units 3 & 4 to Synchronous Condensers	√ (Modeled for 2018 Study Case)	

<sup>2</sup> (<http://www.caiso.com/Documents/BoardApproved2012-2013TransmissionPlan.pdf>), as well as from the Addendum to the Final 2013 Local Capacity Technical Analysis ([http://www.caiso.com/Documents/Addendum-Final2013LocalCapacityTechnicalStudyReportAug20\\_2012.pdf](http://www.caiso.com/Documents/Addendum-Final2013LocalCapacityTechnicalStudyReportAug20_2012.pdf)).

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

<b>ISO Board Approved Transmission Projects in the SONGS Study Area (2012/2013 Transmission Plan)</b>	<b>LA Basin</b>	<b>San Diego Area</b>
South Orange County Dynamic Reactive Support (aka 480 MVAR SVC Near SONGS)		√
Talega Area Dynamic Reactive Support (240 MVAR synchronous condenser at Talega 230 kV bus)		√
Sycamore – Penasquitos 230kV Line		√

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

6. New Generation Project Assumptions:

The following generation projects in the SONGS Study Area were modeled in the power flow study cases. The first three are completed projects in 2013, and the fourth is an approved repowering project in San Diego that was included in the SDG&E PPTA decision.

- Walnut Creek Energy Center (500 MW)
- NRG El Segundo Repowering Project (570 MW)
- Sentinel Peaker Project (850 MW)
- Escondido Repowering Project (45 MW)

7. Generation Retirement Assumptions:

The Revised Scoping Ruling included specified retirement assumptions about once-through cooled (OTC) generation and also aging or refurbished non-OTC plants. The following table includes the OTC units and non-OTC units in the SONGS Study Area. The Track 4 study assumed that OTC units would meet the compliance dates of the State Water Resource Control Board (SWRCB) by either retiring or repowering. Specific repowering assumptions assumed in the study were described above in the new generation project assumptions.

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1

**Table 7: Generation Retirement Assumptions in the Starting Study Cases**

Generating Plant	Total Plant Capacity (MW)	Individual Unit Capacity (MW)	LCR Area	SWRCB Compliance Date	Scheduled Retirement Date*
Alamitos (OTC)	2011	Unit 1 (175) Unit 2 (175) Unit 3 (332) Unit 4 (336) Unit 5 (498) Unit 6 (495)	LA Basin	12/31/2020	
El Segundo (OTC)	670	Unit 3 (335)^ Unit 4 (335)	LA Basin	12/31/2015	Unit 3 (6/2013)^
Huntington Beach (OTC)	904	Unit 1 (226) Unit 2 (226) Unit 3 (225) Unit 4 (227)	LA Basin	12/31/2020	Unit 3 (11/2012)**  Unit 4 (11/2012)**
Redondo Beach (OTC)	1343	Unit 5 (179) Unit 6 (175) Unit 7 (493) Unit 8 (496)	LA Basin	12/31/2020	

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

<b>Generating Plant</b>	<b>Total Plant Capacity (MW)</b>	<b>Individual Unit Capacity (MW)</b>	<b>LCR Area</b>	<b>SWRCB Compliance Date</b>	<b>Scheduled Retirement Date*</b>
Encina (OTC)	946 (OTC) 15 (non-OTC)	Unit 1 (106) Unit 2 (103) Unit 3 (109) Unit 4 (299) Unit 5 (329)	San Diego	12/31/2017	
Etiwanda (Non OTC)	640	Unit 3 (320) Unit 4 (320)	LA Basin	N/A	
Long Beach (Non-OTC Refurbished Plant)	260	Unit 1 (65) Unit 2 (65) Unit 3 (65) Unit 4 (65)	LA Basin	N/A	
Broadway Unit 3 (Non-OTC)	65	Unit 3 (65)	LA Basin	N/A	Repowered as Glenarm Unit 5 at 71 MW)
Cabrillo II (Non-OTC)	188	El Cajon (16) 9 Kearny Mesa Units (Total 136) 2 Mira Mar Units (Total 36)	San Diego	N/A	

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

Generating Plant	Total Plant Capacity (MW)	Individual Unit Capacity (MW)	LCR Area	SWRCB Compliance Date	Scheduled Retirement Date*
San Onofre Generating Station (SONGS)	2,246	Unit 1 (1,122) Unit 2 (1,124)	SONGS Study Area (LA Basin and San Diego)	12/31/2022	6/7/2013
<b>Total</b>	<b>9,288 MW #</b>				

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19

**Notes:**

^ El Segundo Unit 3 was retired in June 2013 upon completion of El Segundo Energy Center

\* Only publicly announced retirement is indicated in the table

\*\* Huntington Beach Units 3 and 4 were retired in January 2012 to provide offsets for emission credits required by the new Walnut Creek Energy Center (500 MW), scheduled to be on-line in June 2013. However, these two units temporarily were brought back to service for the summer 2012 due to extended outage of SONGS.

# Assuming Broadway Unit 3 is repowered with 71 MW, the net total retirement would be 9,217 MW.

8. **RPS Portfolio:**

The Commercial Interest RPS portfolio, utilized for the 2012/2013 transmission planning process, was used for Track 4 studies. The CPUC Energy Division staff also provided the listing of RPS projects for respective years 2018 and 2022 in Chart 2 in the Revised Scoping Ruling.

**Q. Did the ISO study the SONGS outage in the 2012/2013 transmission planning cycle?**

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 14 of 32**

1    **A.**    Yes. The ISO examined the long-term grid reliability impact in the absence of the  
2           two nuclear generating stations, Diablo Canyon Power Plant (DCPP) and SONGS.  
3           As part of the 2012-2013 transmission planning cycle, two studies related to the  
4           nuclear generation backup plan were performed. One addressed the extended outage  
5           scenario at DCPP or SONGS for an intermediate time frame (2017-2018). The other  
6           considered the reliability concerns and potential mitigation options in the long term  
7           (i.e., 2022 time frame). The study related to DCPP absence focuses on grid  
8           reliability implications for northern California and the ISO overall. The study  
9           related to SONGS absence focuses on grid reliability implications for southern  
10          California, specifically the local capacity areas in southern California, and the ISO  
11          overall. In addition, the ISO also performed the combined DCPP and SONGS  
12          absence studies, which focused on the grid reliability assessment for the ISO bulk  
13          transmission system.

14  
15    **Q.**    **Besides the assumption that DCPP was offline, in addition to the SONGS**  
16           **outage, how does the study conducted in the 2012/2013 transmission planning**  
17           **cycle differ from the Track 4 analysis?**

18  
19    **A.**    The following are the major differences between the studies conducted in the  
20           2012/2013 transmission planning cycle and the Track 4 analyses:

- 21           • The Track 4 study includes the ISO-approved transmission projects from the  
22           2012/2013 Transmission Plan in the SONGS Study Area, as discussed  
23           above;
- 24           • The Track 4 study includes the preferred resources described in the Revised  
25           Scoping Ruling and discussed above;
- 26           • For the Track 4 study the ISO prepared a 2018 Commercial Interest RPS  
27           case with the projects projected to be in service by that year. Previously in  
28           the 2012/2013 transmission planning cycle, the ISO utilized the CPUC RPS  
29           Calculator to prepare the 2018 study case. However, the 2018 study case in

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 15 of 32**

1           the 2012/2013 transmission planning cycle assumed the same amount of  
2           system-connected DG in the SONGS Study Area as in the 2022 Commercial  
3           Interest RPS case. The 2018 study case prepared for the Track 4 studies has  
4           different level of system-connected DG for 2018 and 2022 as described on  
5           page 8 above. This difference in system-connected DG model has a  
6           marginal effect on the local capacity study results.

- 7           • The Track 4 study included the additional non-OTC generation retirement  
8           assumptions described above. This results in an increase of an additional  
9           1,088 MW of non-OTC generation retirement in the SONGS Study Area for  
10          Track 4 analyses as discussed above.

11  
12 **Q. For purposes of the two no-SONGS Track 4 scenarios, what assumptions were**  
13 **made about reactive support in the ISO's power flow studies?**

14  
15 **A.** Consistent with the Revised Scoping Ruling, the ISO modeled the following  
16 reactive support projects:

- 17           • A total of 320 MVAR of shunt capacitors in the Southern Orange County  
18           at Johanna, Santiago and Viejo Substations;
- 19           • A total of 480 MVAR Static VAR Compensator (SVC) near San Onofre  
20           230kV switchyard;
- 21           • A total of 240 MVAR of synchronous condensers at Talega 230kV  
22           Substation; and
- 23           • An additional total of 150 MVAR of shunt capacitors at Penasquitos  
24           230kV Substation currently under development by SDG&E.

25  
26           In the 2012/2013 transmission planning cycle, the ISO evaluated, in an exploratory  
27           assessment, additional dynamic reactive support located at other substations in San  
28           Diego area (i.e., San Luis Rey, Penasquitos and Mission).

29



**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 16 of 32**

1   **Q.    Please describe how reactive support in specific locations can be used to**  
2   **address reliability impacts created by the absence of SONGS.**

3  
4   **A.**   SONGS provided a base load generation of 2,246 MW of real power and 1,100  
5   MVAR of dynamic reactive support to both SCE and San Diego local capacity  
6   areas. Its location, electrically, is ideal because it provided both real power and  
7   reactive power to meet electric demand as well as voltage support needs,  
8   particularly under a forced outage condition when SDG&E's electric system is  
9   disconnected from the Arizona, IID and CFE systems and would have to rely on the  
10   support from the SDG&E northern system that is connected to SCE. SONGS not  
11   only provided a strong source of real power for meeting demand, it also provided  
12   dynamic reactive output for voltage support for purposes of mitigating a potential  
13   voltage collapse due to instantaneous reactive power losses caused by massive and  
14   sudden increased power flow on SCE's and SDG&E's systems to meet SDG&E's  
15   entire imported power need under an overlapping outage condition. With the  
16   SONGS closure, there is an absence of 2,246 MW of real power to meet electric  
17   demand, as well as the loss of 1,100 MVAR of dynamic reactive output for voltage  
18   support under contingency conditions.

19

20   **Q.    Would additional reactive support at the SONGS location, in addition to some**  
21   **of the other locations that the ISO considered in the 2012/2013 planning cycle,**  
22   **be sufficient to offset the permanent SONGS outage?**

23

24   **A.**   No. As I described above, the ISO evaluated various locations for installing  
25   dynamic reactive support devices such as static VAR compensators (SVC), or  
26   synchronous condensers to make up for the loss of dynamic reactive support that  
27   SONGS provided. It is not surprising that the optimal locations for these dynamic  
28   reactive support devices are at or near SONGS, because the voltage needs to be  
29   supported to enable increased power transfer from SCE to SDG&E system under the

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 17 of 32**

1 critical contingency condition (overlapping loss of SWPL and Sunrise). However,  
2 there is a limit on where dynamic reactive support can be provided because its  
3 primary function is to provide voltage support to mitigate potential voltage collapse.  
4 The power still needs to be generated elsewhere to provide real power to meet  
5 electric demand. Furthermore, there may be environmental or permitting limits  
6 associated with locating dynamic reactive support facilities in the best electrical  
7 locations, and sites that are far from heavily populated areas may be much less  
8 effective.

9

10 **Q. Did the ISO evaluate any transmission mitigation solutions - including**  
11 **additional reactive support- as part of the Track 4 analysis?**

12

13 **A.** No. The ISO strictly followed the Revised Scoping Ruling. As I described above,  
14 the ISO's understanding is that the purpose of the Track 4 studies is to update the  
15 decisions in Track 1 and the SDG&E PPTA proceeding to account for the difference  
16 in resource needs in the absence of SONGS. In light of SCE's June 7, 2013,  
17 announcement that SONGS will be permanently shut down, a timely evaluation of  
18 additional resource needs certainly makes sense.

19

20 **Q. What were the ISO's objectives for determining resource needs in the LA**  
21 **Basin/San Diego study area?**

22

23 **A.** The ISO's study objectives included: (a) minimizing the OTC generation  
24 repowering or replacement need; and (b) minimizing residual new resource needs.  
25 To meet these objectives, the ISO used an iterative process to determine the general  
26 vicinity of optimal resource locations to mitigate reliability concerns. In doing so,  
27 the ISO relied on a number of factors: (i) power flow studies; (ii) inputs from the  
28 state energy agencies regarding forecasted preferred resources at specific load  
29 substations; (iii) inputs from the utilities regarding potential sites for resource

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 18 of 32**

1 development (i.e., small peaking units), and (iv) known generation development in  
2 the area. In addition, ISO Board approved transmission projects, as listed in Table  
3 6, were incorporated in the starting study cases. The ISO views the study results  
4 described below as a benchmark from which consideration of potential alternatives  
5 to conventional generation (e.g., additional preferred resources, new transmission)  
6 can be evaluated to determine the extent to which they would reduce the need for  
7 conventional generation.

8

9 **Q. Please describe the ISO's study process and the study results for the 2018**  
10 **Without SONGS scenario.**

11

12 **A.** Table 9 provides a summary of the study results for year 2018 without SONGS.  
13 Please note that the study results are based on the preferred resource assumptions  
14 listed on Tables 2 – 5. OTC generation with compliance dates up to December 31,  
15 2017 was assumed to be off-line as listed in Table 7. In addition, the non-OTC  
16 generation in the SONGS study area, as discussed above and listed in the same  
17 table, was assumed to be off-line in the starting 2018 study cases. The primary  
18 reliability constraint that drives resource needs is the post-transient voltage  
19 instability concern under the most critical Category C overlapping outage (N-1-1) of  
20 the Sunrise Powerlink, system readjusted, and then followed by the outage of the  
21 Southwest Powerlink line. The studies were performed and identified based on  
22 applicable WECC voltage stability criteria. The following explanation is provided  
23 for better understanding of the individual column heading of the following table.

24

- OTC Replacement Assumptions: OTC generation repowering or replacement in compliance with the SWRCB's Policy on OTC plants.

25

26

- Additional resource needs: these could be from additional conventional resources, or preferred resources. If new conventional generation, it is referred to generating units that are typical 100 MW in size. The

27

28

- locations are approximately based on their electrical effectiveness to

29

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1 provide mitigation to reliability concerns as well as informal inputs from  
2 the utility staff to the ISO in previous planning cycles. Only general  
3 location information is provided here in the summary table.

- 4 • Extension of Non-OTC Aging Generation Assumptions: potential  
5 interim extension power purchasing contract to keep aging non-OTC  
6 generation in operation until long-term mitigation (i.e., generation  
7 repowering or replacement, etc.) can be implemented.
- 8 • Repowering of Non-OTC Generation Assumptions: if these generating  
9 units are needed for the long term (i.e., 2022 or beyond) because of being  
10 located in effective locations, the ISO assumes that these units would be  
11 replaced by repowering.

**Table 9 – Summary of the 2018 Without SONGS Study Results**

Area	OTC Replacement Assumptions (MW)	Additional Resource Assumptions (MW)	Extension of Non-OTC Aging Generation Assumptions (MW)	Repowering of Non-OTC Generation Assumptions (MW)
Southwestern LA Basin	0	0	0	260
Northwestern LA Basin	0	0	0	0
Eastern LA Basin	0	0	640	0
<b>Subtotal LA Basin</b>	<b>900</b>			
Northwest San Diego	520		0	0
Southwest San Diego	0	100	0	0
Southeast San Diego	0	300	0	0
<b>Subtotal San Diego</b>	<b>920</b>			
<b>Total SONGS Study Area</b>	<b>1820</b>			

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 20 of 32**

1           Based on the study results in the table above, there is a need to extend the operation  
2           of 640 MW of non-OTC generation in the eastern LA Basin as well as the  
3           repowering or replacement of 260 MW of non-OTC generation in the southwestern  
4           LA Basin. For San Diego sub-area, the ISO identified the need for repowering or  
5           replacement of 520 MW of OTC generation in the northwest area, adding 100 MW  
6           of resources in the southwest area, and constructing 300 MW of new generation in  
7           the southeastern San Diego area. These locations are based on known resource  
8           development in the San Diego area.

9

10   **Q.    What was the ISO's study process and the study results for 2022 Without**  
11   **SONGS scenario?**

12

13   **A.**    The *incremental* resource needs (beyond year 2018) are summarized in Table 10.  
14           Just as with the 2018 Without SONGS scenario, these study results are based on the  
15           incremental energy efficiency, demand response and system connected PV  
16           assumptions listed in Tables 2 – 5 above. The columns and headings for this table  
17           are the same as Table 9 except for the Non-OTC Retirement column, which reflects  
18           the non-OTC generating unit retirements as suggested in the Revised Scoping  
19           Ruling that were not assumed retired in the 2018 study.

20

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1

**Table 10 – Summary of the 2022 Without SONGS Study Results**

<i>(Incremental Resource Need)</i>			
Area	OTC Replacement Assumptions (MW)	Retirement of Non-OTC Aging Generation Assumptions (MW)	Additional Resource Assumptions (MW)
-			
Southwestern LA Basin	2912	0	550
Northwestern LA Basin	0	0	0
Eastern LA Basin	0	-640	0
<b><i>Subtotal LA Basin</i></b>	<b><i>2822</i></b>		
Northwest San Diego	0	0	0
Southwest San Diego	0	0	0
Southeast San Diego	0	0	0
<b><i>Subtotal San Diego</i></b>	<b><i>0</i></b>		
<b><i>Total SONGS Study Area</i></b>	<b><i>2822</i></b>		

2

3

4

5

6

7

8

9

10

11

Similar to the year 2018 Without SONGS study results, the primary reliability concern that drives the resource needs in the SONGS Study Area is the post-transient voltage instability concern due to overlapping Category C outage of the Sunrise Powerlink, system readjusted, then followed by the Southwest Powerlink line. This is the most critical outage that affects reliability of the SONGS Study Area. The ISO identified the need to repower or replace 2,912 MW of OTC generation in the southwestern LA Basin that is subject to OTC compliance by the end of 2020 time frame. In addition, to be able to retire 640 MW of non-OTC generation the eastern LA Basin, instead of replacing it in kind at its existing

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 22 of 32**

1 location, the ISO evaluated other effective locations to see if there could be lower  
2 generation needs. Approximately 550 MW of new resources at various locations in  
3 the southwestern LA Basin could facilitate the retirement of the 640 MW of the  
4 non-OTC generation in the eastern LA Basin. I also note that even if the 640 MW  
5 of this non-OTC generation remains in operation, approximately 400 MW of  
6 generation still is needed at various locations in the southwestern LA Basin to  
7 mitigate the reliability concern. Therefore, with resources at the more effective  
8 locations, we would be able to reduce the generation need in the LA Basin, as a  
9 whole, by 490 MW ( $640 + 400 - 550 = 490$  MW). The following table provides a  
10 consolidated summary of the years 2018 and 2022 generation need, and the total for  
11 the two timelines.

12

13 **Q. Can you provide a comparison of the 2018 and 2022 Without SONGS**  
14 **scenarios?**

15

16 **A.** Yes. Table 11 contains a comparison of the total resource needs in the SONGS  
17 study area, given the generation retirements discussed earlier in my testimony and  
18 the additional resource locations I described in the preceding answer.

19

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1  
2  
3

**Table 11 – Summary of the Without SONGS Study Scenarios for 2018 and 2022**

Area	2018 - WithoutSONGS				2022 - WithoutSONGS (IncrementalNeed)			Total Resource Needs (MW)
	OTC Replacement Assumptions (MW)	Additional Resource Assumptions (MW)	Extension of Non-OTC Aging Generation Assumptions (MW)	Repowering of Non-OTC Generation Assumptions (MW)	OTC Replacement Assumptions (MW)	Retirement of Non-OTC Aging Generation Assumptions (MW)	Additional Resource Assumptions (MW)	
Southwestern LA Basin	0	0	0	260	2912	0	550	3722
Northwestern LA Basin	0	0	0	0	0	0	0	0
Eastern LA Basin	0	0	640	0	0	-640	0	0
<i>Subtotal LA Basin</i>			<i>900</i>			<i>2822</i>		<i>3722</i>
Northwest San Diego	520	0	0	0	0	0	0	520
Southwest San Diego	0	100	0	0	0	0	0	100
Southeast San Diego	0	300	0	0	0	0	0	300
<i>Subtotal San Diego</i>			<i>920</i>			<i>0</i>		<i>920</i>
<b>Total SONGS Study Area</b>			<b>1820</b>			<b>2822</b>		<b>4642</b>

4

5

6

**Q. Did the ISO consider other locations in the SONGS study area for resources to replace the generation assumed to be retiring?**

7

8

9

**A.** Yes. The ISO performed an additional power flow analyses for a scenario where further resources were added in the San Diego area. The purpose of this analysis was to demonstrate the interaction between the LA Basin and San Diego local capacity areas, and to a certain extent, how much LA Basin resource needs would be reduced when resources are added in San Diego. The analysis also provides information suggesting the range of flexibility associated with where replacement resources can be electrically located and still effectively meet the local need. Although the feasibility of constructing new generation in this vicinity is unknown, for this analysis, the ISO assumed 565 MW of conventional gas-fired resources connected to San

10

11

12

13

14

15

16

17

18



**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

Onofre 230kV switchyard. The following table provides a summary of the study results, indicating a 1.24 MW reduction in the LA Basin for every 1 MW of generation that is added to San Onofre switchyard. The study results further illustrate how resource development location affects the total resource needs in local capacity areas.

**Table 12 – Summary of Additional Resource Additions in San Diego (in the – Without SONGS Scenarios)**

Area	2018 - WithoutSONGS				2022 - WithoutSONGS (Incremental Need)			Total Resource Needs (MW)
	OTC Replacement Assumptions (MW)	Additional Resource Assumptions (MW)	Extension of Non-OTC Aging Generation Assumptions (MW)	Repowering of Non-OTC Generation Assumptions (MW)	OTC Replacement Assumptions (MW)	Retirement of Non-OTC Aging Generation Assumptions (MW)	Additional Resource Assumptions (MW)	
Southwestern LA Basin	0	0	0	260	2462	0	300	3022
NorthwesternLA Basin	0	0	0	0	0	0	0	0
Eastern LA Basin	0	0	640	0	0	-640	0	0
<i>Subtotal LA Basin</i>			<i>900</i>			<i>2122</i>		<i>3022</i>
NorthwestSan Diego	520	0	0	0	0	0	565	1085
Southwest San Diego	0	100	0	0	0	0	0	100
Southeast San Diego	0	300	0	0	0	0	0	300
<i>Subtotal San Diego</i>			<i>920</i>			<i>565</i>		<i>1485</i>
<b>Total SONGS Study Area</b>			<b>1820</b>			<b>2687</b>		<b>4507</b>

**Q. What are the residual resource needs for the SONGS study area, based on the ISO Track 4 study results compared to the Track 1 SDG&E A.11-05-023 procurement decisions?**

**A.** As I discussed above, the ISO evaluated two different total resource development scenarios, illustrated in Tables 11 and 12 above. In Table 11, the ISO assumed that about 80% of the replacement resource development would be in the LA Basin, and 20% would be located in San Diego. For the scenario depicted in Table 12, the ISO

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

**Page 25 of 32**

1           assumed about two-thirds of the replacement resource development would be in the  
2           LA Basin, and one-third would be in San Diego. Because these two scenarios  
3           produced different total resource needs for the SONGS study area, identifying  
4           residual resource needs requires two calculations. Table 13 sets forth the total  
5           resource needs for both scenarios in 2022 based on the study results from Track 4  
6           (total need by 2022 without SONGS) and then identifies the residual needs by  
7           subtracting the maximum procurement authorizations from Track 1 and D. 13-03-  
8           029 in A.11-05-023 from the total need study result. As depicted in the last column,  
9           the calculated residual resource needs for the study area are 2,534 MW, or 2,399  
10          MW, depending on resource development scenario each of the two local capacity  
11          areas. The preferred resource and DG modeling assumptions that I described  
12          earlier in this testimony have been included for informational purposes.

13

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1 **Table 13 – Residual Resource Needs in 2022 Without SONGS**

Scenario	Track 1 Decisions (MW)		Track 4 Studies (2022) (SONGS Study Area = LA Basin + San Diego) (MW)				Residual Resource Needs (Total Track 4 – Maximum Track 1) for SONGS Study Area (MW)
	LA Basin	San Diego	DR Assumptions Modeled for Studies***	Inc. EE Assumptions Modeled for the Studies	System- Connected DGs (Commercial Interest)	Identified Resource Needs Without SONGS	
80%/20% (LA/SD) Total Resource Development Scenario	1,800*	308**	198	983	1,016 (Installed) 457 (NQC)	4,642	4,642 – 1,800 – 308 = 2,534 Breakdown: LA Basin (1,922) San Diego (612)
Two-thirds/One- Thirds(LA/SD) Total Resource Development Scenario	1,800*	308**	198	983	1,016 (Installed) 457 (NQC)	4,507	4,507 – 1,800 – 308 = 2,399 Breakdown: LA Basin (1,222) San Diego (1,177)

2

3 Notes:

4 \*Maximum authorized procurement resources in the LA Basin, including preferred  
5 resources

6 \*\*Includes 10 MW of net increase for Escondido

7 \*\*\* Post first contingency values (for use in preparation for second contingency)

8

9 **Q. Please describe the 2022 With SONGS study process and study results.**

10

11 **A.** For this request, the ISO performed two study scenarios: one without the SONGS  
12 separation and the other with the SONGS separation scheme in service. In brief, the

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

1           SONGS separation scheme can be described as a relay protection system that was  
2           designed to automatically separate the SCE and SDG&E electric system during  
3           times of system trouble. Specifically, the scheme would open the circuit breakers  
4           between the SCE and SDG&E systems at the SONGS 230kV switchyard when the  
5           SONGS interconnection overload relay exceeds 8,000 Amps. This action would  
6           electrically separate the SCE and SDG&E systems. The ISO consulted with SCE  
7           and was advised that the SONGS separation scheme likely would have been put  
8           back in service had SONGS returned to service although, the scheme would have  
9           been evaluated for a potential higher setpoint. Therefore, because there was  
10          uncertainty about the form of the SONGS separation scheme had SONGS returned  
11          to service, the ISO performed two studies for the 2022 With SONGS scenario: with  
12          and without the SONGS separation scheme as it existed at the time SONGS was  
13          taken offline. The following table includes a summary for both scenarios for the  
14          2022 With SONGS studies. These are mutually exclusive values and are not  
15          additive.  
16

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

**Table 14 – Summary of 2022 Studies (With SONGS Scenario)**

Area	2022 - With SONGS SONGS separation scheme disabled		2022 - With SONGS SONGS separation scheme maintained	
	OTC Replacement Assumptions (MW)	New Generation Assumptions (MW)	OTC Replacement Assumptions (MW)	New Generation Assumptions (MW)
Southwestern LA Basin	1588	0	1438	0
Northwestern LA Basin	0	0	0	0
Eastern LA Basin	0	0	0	0
<i>Subtotal LA Basin</i>	<i>1588</i>		<i>1438</i>	
Northwest San Diego	0	0	0	0
Southwest San Diego	0	0	0	140
Southeast San Diego	0	90	0	300
<i>Subtotal San Diego</i>	<i>90</i>		<i>440</i>	
<b>Total SONGS Study Area</b>	<b>1678</b>		<b>1878</b>	

For the 2022 With SONGS and with SONGS separation scheme maintained, the constraints are related to transmission facility loading concerns for the LA Basin and San Diego local capacity areas. Specifically, the need for generation resources (OTC generation repowering or replacement need in the amount of 1,438 MW) in the Western LA Basin is triggered by the thermal loading concern on the Serrano – Villa Park No. 1 230kV line due to an overlapping Category C N-1-1 contingency of the Serrano – Lewis No. 1, system readjusted, followed by the Serrano – Villa Park No. 2 230kV line. For the San Diego local capacity area, the new generation need (440 MW) is caused by the need to maintain flow within 8,000 Amps going south at the SONGS switchyard between SCE and SDG&E under an N-1-1 contingency of the Sunrise Powerlink, system readjusted, followed by the Southwest Powerlink line outage.

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 29 of 32**

1 For the 2022 With SONGS and the SONGS separation scheme disabled, the  
2 primary need for generation resources (via 1588 MW of OTC generation  
3 repowering or replacement) in the Western LA Basin is caused by the same  
4 overloading concern on the Serrano – Villa No. 1 230kV line under the same N-1-1  
5 contingency as described above. For San Diego local capacity area, the need for  
6 new generation (90 MW) is caused by overloading concern on the San Onofre – San  
7 Luis Rey No. 1 230kV line under the same N-1-1 contingency in San Diego.

8

9 **Q. Has the ISO considered the impact of the higher amount of demand response**  
10 **and additional small PV suggested in the Revised Scoping Ruling as being**  
11 **available under post second contingency conditions?**

12

13 **A.** Yes, to a certain extent. In a 2022 without SONGS scenario, the post second  
14 contingency includes a major combined cycle generating facility outage that occurs  
15 after an N-1-1 overlapping contingency of the Sunrise Powerlink and Southwest  
16 Powerlink lines. According to NERC reliability standards, this is a Category D  
17 contingency (extreme event resulting in two or more (multiple) elements removed  
18 or cascading out of service). Under these circumstances, the additional 997 MW of  
19 DR and approximately 796 MW (installed capacity) of customer-connected small  
20 PV identified in the Revised Scoping Ruling for post-second contingency could  
21 help to avoid a certain amount of load shedding. SDG&E has installed an  
22 involuntary load dropping scheme that would automatically drop approximately up  
23 to two blocks of 400 MW of involuntary load in this scenario to avoid a widespread  
24 uncontrolled power system outage in the WECC system. Implementation and  
25 utilization of this demand response and small PV could reduce the reliance on this  
26 involuntary load shedding under the condition described above.

27

28 **Q. Is the ISO recommending that the Commission make a procurement decision**  
29 **based on these study results?**

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**R.12-03-014**

**Page 30 of 32**

1    **A.**    Not at this time.  As I mentioned previously, the ISO views these study results as a  
2           benchmark from which consideration of potential alternatives to conventional  
3           generation (e.g., additional preferred resources, new transmission) can be evaluated  
4           to determine the extent to which they would reduce the need for conventional  
5           generation. The ISO will continue its studies to evaluate potential transmission  
6           mitigation solutions-including additional reactive support- that might address a  
7           portion of these needs. These studies are being conducted as part of the 2013/2014  
8           transmission planning cycle that is currently underway. The ISO is also willing to  
9           evaluate any additional preferred resources that are determined through this  
10          proceeding to be viable from a development standpoint to determine the extent to  
11          which they may reduce the needs for conventional generation. The ISO also wants  
12          to consider incorporating the 2013 IEPR demand forecast which is anticipated to be  
13          completed and adopted by the CEC Commission by the end of this year.

14  
15    **Q.**    **Are there differences between the assumptions in the 2013/2014 cycle studies**  
16           **and the Track 4 studies?**

17  
18    **A.**    The ISO 2013/2014 transmission planning cycle utilizes the same load forecast and  
19           incremental uncommitted energy efficiency as the Track 4 studies.  In addition, the  
20           Track 4 analysis includes the DR assumptions described in the Revised Scoping  
21           Ruling recommended, whereas the 2013/2014 TPP study base assumptions do not  
22           yet include these amounts (but can be considered as a mitigation option).  
23           Additional non-OTC generation retirements in the SONGS Study Area are  
24           incorporated for Track 4 studies, whereas the starting 2013/2014 TPP base cases do  
25           not include these assumptions for the LA Basin area.

26  
27    **Q.**    **Does the ISO recommend that the transmission planning study results be**  
28           **presented to the Commission in Track 4 to inform the procurement decision?**

29

**TRACK 4 TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION  
R.12-03-014**

**Page 31 of 32**

1    **A.**    Yes. The ISO recommends that the Commission wait to make a decision about the  
2            need for additional resources until the ISO has completed its studies of potential  
3            transmission mitigation solutions (including the need for additional reactive  
4            support). With that information, the Commission can then consider the appropriate  
5            resource “mix” that can meet the local reliability needs arising from the SONGS  
6            retirement. Such a mix can include additional preferred resources and other  
7            alternatives to conventional resources, depending on location and effectiveness.  
8

9    **Q.**    **Can you suggest a possible procedural timetable for presentation of the ISO’s**  
10           **additional study results and a Commission decision?**  
11

12   **A.**    Yes. The ISO’s draft study results will be presented in the draft 2013/2014  
13            Transmission Plan which is usually presented at the end of January. The ISO will  
14            be able to present testimony on transmission mitigation solutions by the end of  
15            March, 2014. This will allow for a Commission decision on additional resource  
16            needs related to the SONGS outage by July, 2014.  
17

18   **Q.**    **Does this conclude your testimony?**  
19

20   **A.**    Yes, it does.