



STANDARD CATHODIC PROTECTION MAINTENANCE REPORT

(Form must be completed in Non-erasable Ink)

GT&D
01/09
FO-16-D

A. RECORD INFORMATION

LOCATION	Redacted	CITY OAKLAND	CP SYSTEM NO. C7-29	SAP# GD.CORR.0738.RECTI.0001
AREA 2		DIVISION EAST BAY	DISTRICT CENTRAL	YEAR 2011

B. PIPE-TO-SOIL POTENTIAL MEASUREMENTS (MILLIVOLTS)

BI-MONTHLY TEST LOCATION	BASE DATA	LAST YR. READING										
1. Redacted	973	973	900	737	890	912	698	903	867			
DATA RECORDED BY (LAN ID)		Redacted										
DATA RECORDED BY (INITIALS)												
DATE (MONTH/DAY)		12-10-10	2-4	4-11	6-5-11	8-10-11	10-4-11	10-24-11	12-5-11			

C. GALVANIC ANODE/RECTIFIER MEASUREMENTS

GALVANIC ANODE OR RECTIFIER LOCATION	BASE DATA	LAST YR. READING	INTERFERENCE TEST RECTIFIER - 1. <u>2.5</u> AMPS, 2. <u> </u> AMPS, 3. <u> </u> AMPS, 4. <u> </u> AMPS									
			VOLTS/AMPS									
1. END OF Redacted #930	2.5A 26V	2.1A 25.2V										2.8A 25.3
2.												
3.												
4.												
DATA RECORDED BY (LAN ID)		Redacted										Redacted
DATA RECORDED BY (INITIALS)												
DATE (MONTH/DAY)		9-22-10										88-12

D. RECORD REVIEW

BI-MONTHLY REVIEWED BY (LAN ID)		Redacted										
BI-MONTHLY REVIEWED BY (INITIALS)												
DATE (MONTH/DAY)		10-31-09	5-7-11	5-7-11	7-19-11	4-30-12	4-30-12	4-30-12	4-30-12	8/4/12		



**E. LOG OF CATHODIC PROTECTION
MAINTENANCE WORK**
(Form must be completed in Non-erasable Ink)

GT&D
01/09
FO-16-D

CPA System No. _____

DATE	LAN ID	INITIALS	WORK DESCRIPTION
6-5-11	Redacted		MONITORED AREA, FOUND AREA RESTORED
10-24-11			Found Regulator Touching Service Valve Moved Regulator and cleared contact.
8-8-12			RECTIFIER EVALUATION completed by Redacted ON 10-29-11
8-12-12			AREA RESTORED 6-5-11