

From: Prosper, Terrie D.
Sent: 9/23/2013 8:56:18 AM
To: Doll, Laura (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD)
Cc:
Bcc:
Subject: RE: CPUC Reportable Gas Incident - San Bruno
Thanks!

----- Original message -----

From: "Doll, Laura" <LRDD@pge.com>
Date:
To: "Hagan, Jack (Brigadier General – CA)" <emory.hagan@cpuc.ca.gov>, "Malashenko, Elizaveta I." <elizaveta.malashenko@cpuc.ca.gov>, "Clanon, Paul" <paul.clanon@cpuc.ca.gov>, "Prosper, Terrie D." <terrie.prosper@cpuc.ca.gov>
Subject: FW: CPUC Reportable Gas Incident - San Bruno

A little more info on this 3rd party dig-in: gas flow was stopped around 1:30 am and repairs to the 2” pipe are continuing.

Early information suggests that this area was properly marked by USAA in advance of the work.

From: [Redacted]
Sent: Sunday, September 22, 2013 11:10 PM
To: UO EP Gas Incident Notify
Cc: [Redacted]
Subject: CPUC Reportable Gas Incident - San Bruno

At approximately 2018 hours on September 22, 2013, there was a third party dig-in of a 2” steel main, located at [Redacted] in San Bruno, that caused an unintentional release of gas. The third-party excavator, Granite Construction, were performing rail work when they struck the main. PG&E crews arrived at approximately 2140 hours and are currently working to shut-in the gas. There were no injuries or deaths. The damage is expected to be less than \$50,000. The Fire Department were on scene. Major Bay Area media (KTVU-2) was on scene and is therefore, a CPUC reportable incident.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

6111 Bollinger Canyon Road, 4th Floor

San Ramon, CA 94583

Office Redacted

Cell Redacted

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>