

Response to Questions

Q1:

Q1: How can we reconcile the ISO's use of a 100% contingency for the CUC's Powerlink mission case and the 50% contingency for the setting of the bounds of the capacity? Do the studies indicate whether the ISO's studies presented in the contingency studies ultimately approved?

Response:

As we indicated in the meeting, ISO's decision to increase reliability criteria with the ultimate approved compared to the route that was originally approved corridor still provided significant capacity of 1000 MW? load shedding risk surprise of the ultimately approved.

“Q. 10. . 1000 MW of capacity for the CUC.”

A. The flow thermal load, stability analysis was on ASPEN10 at the 3500 MW limit. The import level. The contingency of the common mode outage lines west of Imperial Valley substation, the performance found to be equivalent to that of the Sunrise or SDG&E. For the common mode of 500 kV lines west of Imperial Valley substation, the CAISO found that a Special Protection Scheme needed that would shed up to 500 to 1000 MW of load in (emphasis added) 1000 MW to 2000 MW of the Imperial Valley Substation.

The testimony clearly indicates contingency for contingencies also included, and included for the 1000 MW of Diego was also included. The preference or had an advantage over the approved corridor in this case, the significant benefit of the supported contingency. The contingency.

Q2:

Q2: How can we explain the local capacity benefit provided by the Sun contingency? Why is this criteria used for the Sun project?

Response:

Local capacity requirements are based on the consequences of studied, and then using the largest result to establish the isolate the local capacity benefit. The results by the area.

requirements and without the below is an ISO's Local Capacity, a "reliable" transmission

There are several components of the Technical Study. Consistent with mandatory nature of the NERC Planning under a statutory obligation to ensure reliable operation of transmission grid consistent with the ISO's further under an obligation, to secure compliance with all "Applicable Reliability Criteria" which the unique to the transmission participating transmission Owners ("PTOs").

Pursuant to its tariff authority, the ISO consulted stakeholders, has approved Grid Planning Standards intended to interpret NERC Planning Standards in instances in which the apply standards more stringent than those established criteria form Reliability Criteria to be followed performance of the ISO Controlled Grid under Contingency. The Planning Standards define reliability on a "reliable" using the term "adequacy." "Adequacy" is the ability of systems to supply the aggregated energy requirements of customers at all times, taking into account the system such as transmission ratings and scheduled and unscheduled outages of system elements. "Security" is the ability to withstand disturbances such as electric short circuits or system elements. The Standards are organized by Performance Categories. For instance, one category requires that ensure grid integrity is maintained under certain adverse security, but also that all customers continue to receive e.g., adequate service, grid reliability and service reliability 4).


Before the construction of the Sunrise:
With everything else, the Sunrise project had not Category B contingency that the 1 of the 1,100 500 kv The West

☐

☐

☐

Figure 1: Continuity
 G-1, Continuity



Under these circumstances, the import level into the San could be subtracted from the peak load to determine the net available capacity. The net available capacity for the outage of this unit is approximately 500 MW. The results, from the analysis, are shown in the table below.

Table 1: LCR Area Peak Load (MW) Diego

Study Area	2021
	4 A- (MW)
10 Peak Load Area	5,749
Import Capability with	-2500
Loss of Otay Mesa	+605
LCR-N	3 854

MW
MW

As explained previously, the most severe constraint on the system is the requirement. Before the construction of the new transmission line, the N-1 contingency loss of a single 230 kV path (44 transfer path) (switching) results in a loss of the Miguel area. The loss of the Otay Mesa generator is less than a single 230 kV line outage. The results in higher local capacity than the outage was not relevant in the capacity requirements. The Sunrise was observed operating limit based on final limits were the transmission line before the stability limits were entered.

MW

After the construction of the Sunrise:

Following the construction of the Sunrise, the category of the most contingency is the same as the one before. The loss of one 500 kV circuit (Sunrise or S 500 kV circuit) that is because each line is capable produced by Otay Mesa area by the Figure 2 below.

MW

MW

원

원
원
원
원

SONGS


Path

N-1, N-1
□□□□□□□□□□

5
23
69 kV

Figure 2: Contingency

N-1, Contingency



원

원

The ISO performed the detailed analysis of each scenario for
 Page 3 of 3
 In this analysis, voltage stability/collapse limits are the limiting
 원

원

5 원

Table 2: ILCR in the Area

Study Area		2021 ILCR
10 Peak Load Area		4 A- ()
Imports Available		5,749
		3086
		2 524 – 2 663

Comparing the results in the two areas, the ILCR in the 10 Peak Load Area is significantly higher than in the Imports Available Area. This is due to the higher peak load in the 10 Peak Load Area, which results in a higher ILCR. The ILCR in the Imports Available Area is lower because of the lower peak load and the presence of imports, which helps to reduce the ILCR. The ILCR in the 10 Peak Load Area is 5,749, while the ILCR in the Imports Available Area is 3,086. The difference between the two areas is 2,663.

A significant portion of these local benefits are provided by the system for benefits from the Otay Valley area. The Otay Valley area is a major source of benefits for the system, and the benefits from this area are significant. The benefits from the Otay Valley area are provided to the system through the 10 Peak Load Area, which is a major source of benefits for the system. The benefits from the Otay Valley area are provided to the system through the 10 Peak Load Area, which is a major source of benefits for the system. The benefits from the Otay Valley area are provided to the system through the 10 Peak Load Area, which is a major source of benefits for the system.

The table below reports the results of the analysis. The table shows the results of the analysis for the 10 Peak Load Area and the Imports Available Area. The table shows the results of the analysis for the 10 Peak Load Area and the Imports Available Area. The table shows the results of the analysis for the 10 Peak Load Area and the Imports Available Area.

	Before Analysis	After Analysis
Sunrise 500 kV	No	No
Sunrise related 230 reinforcement	No	YES
SWPL (Imperial 500 kV line)	No	No
Otay Mesa generation	No	Yes
Otay Mesa voltage (functioning)	No	Yes
Limiting function for studied	N-1 employed for Sunrise	Voltage collapse

Q3: How does the ISO planning standards compare to NERC planning

Response:

Reliability assessment results are measured against the applicable determine if system performance criteria have been met according to the WECC Transmission Planning Standards, the ISO planning standards are developed or approved by the ISO Board. The current version of stakeholder comments for the latest ISO Board approved on July, 2011 is available at:

http://www.caiso.com/informed/Pages/StakeholderProcesses/CompletedStakeholderProcesses/TransmissionPlanningStandards.aspx

A link to the ISO standards is provided below:

Reliability Standards

The relevant criterion is WECC, available at:

http://www.wecc.biz/library/Documentation%20Categorization%20Files/Forms/AllItems.aspx?RootFolder=%2flibrary%2fDocumentation%20Categorization%20Files%2fRegional%20Criteria&FolderCTID=&View=%7bAD6002B2%2d0E39%2d48DD%2dB4B5%2d9AFC9F8A8DB3%7d

Q4: Why are the ISO standards for power trains single power plant gas turbine gas turbines be considered separate entities "single plant" outage?

Response:

First, the ISO contingency, instead of outage. As the ISO outage is considered in the ISO's capacity, the most significant excessive and unacceptable levels of

Setting this aside, the ISO has reviewed the Palomar to see if any parts constitute the gas turbines as separate entities. The criteria require that the ISO have for three years, for the period immediately following the commissioning of the plant

The ISO cannot release the actual data due to generator's summarize the results (GoP) review data is confidential for the facility owner, therefore, we cannot provide this information directly. In the event of outages, the identified:

- 14 full plant trips of Metcalf between Sept 2009 and
- full plant trips of Palomar between July 2009 to

Based on this review, the data does not support treating separate generators, but in general, single generators for contingency analysis.

Q5: Was the question raised about the profile of the plants whether the ISO considered all solar generation to use

Response:

The ISO has not assumed all solar generation to use an extensive process for by developing different profiles for solar resources in 2020 based on the expected portfolios' profiles accounted for different technologies, 2,58MW of (2,464, Thin Film Fixed, 1,045MW fixed small solar, 1,749MW geographically distributed, 1,560MW tracking and 3939MW solar

Please refer to the Exhibit 2, CAISO's 2011 Testimony http://www.caiso.com/Documents/2011-07-01_R10-05-006_Testimony.pdf