

Rulemaking: 12-03-014

Exhibit No.: CEJA x SDG&E – 6

Commissioner: Florio

ALJ: Gamson

Order Instituting Rulemaking to Integrate and
Refine Procurement Policies and Consider
Long-Term Procurement Plans

R.12-03-014

(Filed March 22, 2012)

SDG&E Response to DRA-CEJA-Sierra Club Data Request 2, Question 8

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA
October 28, 2013

**DRA-CEJA-Sierra Club DATA REQUEST
DRA-SDG&E-DR-02
SDG&E LTPP – TRACK 4 – R.12-03-014
SDG&E RESPONSE
DATE RECEIVED: SEPTEMBER 6, 2013
DATE RESPONDED: SEPTEMBER 17, 2013**

8. Describe how much DR SDG&E deployed on the afternoon of Sept. 14, 2012, during the hour that SDG&E load averaged 4,620 MW. Also describe how much DR SDG&E could have deployed that hour based on existing DR under contract and DR pricing programs.

SDG&E Response 8:

SDG&E deployed 52 MW of demand response during the system peak hour on September 14th 2012. SDG&E estimates a total of 65 MW of demand response based on existing DR under contract and DR pricing programs was available that day.