

From: Hagan, Jack (Brigadier General – CA)  
Sent: 10/23/2013 6:25:30 PM  
To: Doll, Laura (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD)  
Cc:  
Bcc:  
Subject: Re: CPUC/DOT Reportable Incident L-124A Dig-In

Dam farmers!!!!

Brigadier General (CA) Jack Hagan  
Director, Safety & Enforcement Division  
California Public Utilities Commission  
(916) 267-7201 Cell  
Sent from my iPhone

On Oct 23, 2013, at 18:09, "Doll, Laura" <LRDD@pge.com> wrote:

FYI. Note no media onsite as of this hour.

**From:** Redacted  
**Sent:** Wednesday, October 23, 2013 5:41 PM  
**To:** Redacted; Gas Ops S&P Regulatory Compliance; Singh, Sumeet; Redacted; Falk, Michael; Bigras, Pierre; Mannie, Joel C; UO EP Gas Incident Notify  
**Cc:** Redacted  
Redacted; Christopher, Melvin J. (GSO); Redacted  
Redacted  
**Subject:** CPUC/DOT Reportable Incident L-124A Dig-In

At approximately 1435 hours PG&E was notified that a farmer was ripping his field with a CAT D-9 and struck PG&E's 16-inch steel transmission line, L124 just northwest of Redacted, resulting in a release of gas. It is unknown at this time whether USA was notified. PG&E's GSR was onsite at 1520 hours and the flow of gas was stopped at 1645 hours by closing the main line valves. There were no injuries, no fatalities and no ignition as a result of this incident. No media was onsite. No customer outages have been reported. This incident was reported to DOT at 1722 hours and CPUC at 1725 hours because the volume of gas released is estimated to be in excess of 3 million cubic feet.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

Redacted

PG&E is committed to protecting our customers' privacy.  
To learn more, please visit  
<http://www.pge.com/about/company/privacy/customer/>