

From: Doll, Laura
Sent: 10/21/2013 11:08:17 AM
To: pac@cpuc.ca.gov (pac@cpuc.ca.gov); eim@cpuc.ca.gov (eim@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fw: Walnut Creek Gas Incident

Fyi

From: [Redacted]
Sent: Monday, October 21, 2013 11:04 AM
To: UO EP Gas Incident Notify
Cc: Redding, Steve (M&C DIR); [Redacted] (Diablo & North Bay); [Redacted] (GE&O); [Redacted]
[Redacted]
Subject: Walnut Creek Gas Incident

At approximately 0901 hours on October 21, the Fire Department notified PG&E of a gas blowing at [Redacted] in Walnut Creek. The leak, on a 2" plastic main, is believed to have been caused by a leak on a nearby 6" water main. A third party contractor, Horizon Construction, had been making repairs to the broken water pipeline the day before. PG&E's crew arrived on scene at approximately 0938 hours and stopped the flow of gas at approximately 1015 hours by squeezing the main at 1801 Lacassie Avenue. PG&E's crews are working with the Horizon Construction to determine the best course of action to repair the main in light of the water main break. Twenty-five services, with 65 customers, remain without gas service at this time. No estimate at this time of when repairs will be completed or when service will be restored. There were no injuries or deaths. The damage to PG&E's facilities is expected to be less than \$50,000. The Fire Department and Police were on scene with traffic rerouted and nearby homes evacuated. Major Bay Area media (KTVU-2) was on scene and this is therefore, a CPUC reportable incident.

[Redacted]

Gas Operations | Standards and Policies

Regulatory Compliance & Support

[Redacted]

