

GM 162870



Public Utilities Commission
STATE OF CALIFORNIA

July 22, 1965

COMMISSIONERS
FREDERICK D. HOLOBOFF, PRESIDENT
PETER E. MITCHELL
GEORGE G. GROVER
WILLIAM M. BENNETT
A. W. GATOV

LHS	COAST VALLEYS DIVISION			GOB
SLC				EHH
EMK	REPLY	FILE	CIRCULATE	WPT
DSA	JUL 26 1965			RKM
EEH				LCS
ECH	ONLY COPY			RAB
CHB	COPY TO			HJD
RRJ				EAG

FILE NO. G.O. 112-A/5-65 CALIFORNIA STATE BUILDING
SAN FRANCISCO, CALIF. 94103

ADDRESS ALL COMMUNICATIONS
TO THE COMMISSION

Pacific Gas and Electric Company
245 Market Street
San Francisco, California 94106

Attention: Mr. John C. Morrissey
Attorney

JUL 26 1965

JAT DIV. GAS SUPT. JPS
LBB
LCS
WPT
FILE
RT JBR EL RAH RKM

189M

Gentlemen:

This will acknowledge receipt of your letter dated June 29, 1965,
forwarding for filing a proposed Redacted

Redacted
Redacted

The report indicates that the installation will take place in areas of Class 3 location and Type C construction will be employed throughout the project. Since the pipe material used is salvage and reconditioned pipes from Main No. 100 originally installed in 1929, with 33,000 minimum yield and (80%) joint efficiency, the maximum allowable operating pressure under Section 107 of General Order No. 112-A will be 412 psig.

The report submitted in accordance with the requirements of Chapter IV, Section 401.2 of General Order No. 112-A has been reviewed and is acceptable for filing.

Very truly yours,

PUBLIC UTILITIES COMMISSION
STATE OF CALIFORNIA

By *William W. Dunlop*
William W. Dunlop, Secretary

7-23-65

cc: EHFisher RDSmith LHSmith EFSibley MHChandler
ATSchmidt