

From: [Redacted]
Sent: 10/2/2013 4:18:55 PM
To: cm1@cpuc.ca.gov (cm1@cpuc.ca.gov)
Cc: Redding, Steve (M&C DIR)
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=SRR3); Doll, Laura
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD); [Redacted]
[Redacted]
Bcc:
Subject: Odor Investigation at Chestnut ave Plumbwood Pl


Chuck,

After our discussion today I contacted the PG&E local leadership at our San Carlos headquarters that maintains the gas facilities in your neighborhood in San Bruno. They had a leak investigation performed this afternoon at the location you described which is highlighted in the attached file. The investigation of all mains, services and meter sets resulted in no leakage found. Should the location in the file not represent an accurate depiction of where you described or if you ever notice any area odor at this location or any other please contact us immediately.

It was a pleasure meeting you today and feel free to call with any follow up questions relating to our integration of Picarro Surveyor as a compliance leak survey tool at PG&E.

Thanks,

[Redacted]



Gas M&C Superintendent | Odyssey Program

[Redacted]