

From: Doll, Laura
Sent: 10/3/2013 12:42:17 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fw: CPUC Reportable Gas Incident- Santa Clara

From: [Redacted]
Sent: Thursday, October 03, 2013 12:35 PM
To: UO EP Gas Incident Notify
Cc: [Redacted]
Subject: CPUC Reportable Gas Incident- Santa Clara

At approximately 10:59a PG&E responded to a third party dig-in on a 1 1/4" plastic service line at 4401 Great America Pkwy in Santa Clara. The third-party contractor, Asphalt and Cement Works, did not have a valid USA ticket. One commercial customer was affected by the dig-in and the building was evacuated. Gas flow was stopped at 12:04p. There was no fire, death, injury, or explosion. Local FD was onsite shortly after the incident began. The costs of repair are not expected to exceed \$50k and less than 3mmcf of gas was released. Estimated time of restoral is 2:30p. The incident is reportable to the CPUC due to the presence of media.

Please let me know if you have any questions.

[Redacted]

Supervisor

Customer Impact-Gas

[Redacted]