

GM 162870

COMMISSIONERS
FREDERICK B. HOLOBOFF, PRESIDENT
MILNER E. MITCHELL
GEORGE G. GROVER
WILLIAM M. BENNETT
A. W. GATOV



Public Utilities Commission
STATE OF CALIFORNIA

July 22, 1965

LHS	COAST VALLEYS DIVISION			COB
SLC				EMH
EMK	REPLY	FILE	CIRCULATE	WPT
DSA	JUL 26 1965			RKM
ESH				LCS
ECH	ONLY COPY			RAB
CHB	COPY TO			HJD
RRJ				EAG

FILE NO. G.O. 112-A/5-65 CALIFORNIA STATE BUILDING
SAN FRANCISCO, CALIF. 94102

ADDRESS ALL COMMUNICATIONS
TO THE COMMISSION

Pacific Gas and Electric Company
245 Market Street
San Francisco, California 94106

JAE DIV. GAS SUPT. JPS
 JUL 26 1965 LBB
 DOM LCS
 FILE WPT
 BB JBR EL RAH RKM / JFM

Attention: Mr. John C. Morrissey
Attorney

Gentlemen:

This will acknowledge receipt of your letter dated June 29, 1965,
forwarding for filing a proposed Redacted,
Redacted

Redacted The report indicates
that the installation will take place in areas of Class 3 location
and Type C construction will be employed throughout the project.
Since the pipe material used is salvage and reconditioned pipes from
Main No. 100 originally installed in 1929, with 33,000 minimum yield
and (80%) joint efficiency, the maximum allowable operating pressure
under Section 107 of General Order No. 112-A will be 412 psig.

The report submitted in accordance with the requirements of Chapter IV,
Section 401.2 of General Order No. 112-A has been reviewed and is
acceptable for filing.

Very truly yours,

PUBLIC UTILITIES COMMISSION
STATE OF CALIFORNIA

By
William W. Dunlop, Secretary

7-23-65

cc: EHFisher RDSmith LHSmith EFSibley MHChandler
ATSchmidt