

From: Campbell, Ben (Hydrotest)
Sent: 11/11/2013 3:25:18 PM
To: Sunil Shori (Sunil.shori@cpuc.ca.gov)
Cc: Singh, Sumeet
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=S1ST56905772); Gas Ons
Support (/O=PG&E/OU=Corporate/cn=Recipients/cn=SBResponderGroup); Redacted
Redacted

Bcc:
Subject: Fwd: T-42 & T-43B RCP Reports

Sunil

Here is the revised T-43B report.

Ben Campbell
415-971-5571

Sent from my iPhone

Begin forwarded message:

From: Redacted
Date: November 11, 2013, 1:12:58 PM PST
To: "Campbell, Ben (Hydrotest)" <BCC3@pge.com>
Subject: RE: T-42 & T-43B RCP Reports

Ben,

Find the revised file attached. Note this I only revised and re-certified page 12.....Deck

Redacted

From: Deck Redacted
Sent: Thursday, November 07, 2013 1:46 PM

To: Campbell, Ben (Hydrotest)
Cc: Redacted
Subject: RE: T-42 & T-43B RCP Reports

Ben,

Find attached the revised report. The observed maximum stress strain pressure was 822 psig not 565 psig as indicated. The error appears to be a typing error over a calculated value.

Yielding of the pipe was never observed up to and including the 822 psig spike pressure. The stress/strain curve bent to the left indicating a large volume of air in the test segment and not deformation of the pipe itself. This is explained in a note on page 10 of the revised report. The old and revised test reports both correctly indicate that the newly established MAOP can be as much as 410 psig.

Jim Knight will prepare and issue a revised report that will be forwarded to you in the next few days.

Please advise of any further questions or issues.

Best Regards.....Deck

Redacted

From: Redacted
Sent: Thursday, November 07, 2013 2:37 PM
To: Redacted
Subject: RE: T-42 & T-43B RCP Reports

Second RCP Report.

Thank you,

Redacted

From: Redacted
Sent: Thursday, November 07, 2013 12:37 PM
To: Redacted
Subject: RE: T-42 & T-43B RCP Reports

See attached. One more will be on it's way.

Thank you,

Redacted

From: Redacted

Sent: Thursday, November 07, 2013 12:36 PM

To: Redacted

Subject: FW: T-42 & T-43B RCP Reports

Thank you,

Redacted

From: Redacted

Sent: Thursday, November 07, 2013 12:27 PM

To: Redacted

Cc: Campbell, Ben (Hydrotest)

Subject: T-42 & T-43B RCP Reports

Sending these on behalf of Ben Campbell. See attached for the T-42 & T-43B RCP Reports.

Thank you,

Redacted

Gas Transmission Systems, Inc.

6121 Bollinger Canyon Rd | San Ramon, CA 94583

Redacted

PG&E is committed to protecting our customers' privacy.

To learn more, please visit

<http://www.pge.com/about/company/privacy/customer/>

PG&E is committed to protecting our customers' privacy.

To learn more, please visit

<http://www.pge.com/about/company/privacy/customer/>

PG&E is committed to protecting our customers' privacy.

To learn more, please visit

<http://www.pge.com/about/company/privacy/customer/>

<Test 43B signed Revision 1.pdf>