

From: Doll, Laura
Sent: 11/22/2013 3:44:45 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: CPUC/DOT Reportable Incident - San Ardo

FYI

From: Redacted
Sent: Friday, November 22, 2013 3:17 PM
To: CPUC Gas Incident Notify
Cc: Redacted
Subject: CPUC/DOT Reportable Incident - San Ardo

At approximately 1327 hours PG&E was notified that a farmer was plowing a field at Redacted Redacted in the town of San Ardo, when he struck and severed PG&E's 6-inch steel gas transmission Line 187 causing a release of gas. The farmer did not call USA and did not hand dig to locate the gas line prior to using mechanical equipment. PG&E's GSR arrived on scene at 1355 hours and field crews arrived at 1425 hours. The flow of gas has not yet been stopped as the shut in plan is still being determined. The town of San Ardo will likely experience gas service interruption. No injuries, no fatalities, no ignition, no media. Cal Fire is on scene. This incident was reported to DOT at 1453 hours and the CPUC at 1514 hours because the release of gas is expected to exceed 3 million cubic feet and the cost of damages due to the release of gas is expected to exceed \$50,000.

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

Redacted