



2012 Daily Forecasted vs. Actual DR

| Programs | No. of DR Events | Daily Forecast | Ex-Post | Difference | % |
|-----------|------------------|-------------------------------|---------|--------------------------|--------------|
| | | (Averaged MW over All Events) | | (Range from Low to High) | |
| AMP-DA | 3 | 44 | 50 | -1 to 10 | -1% to 23% |
| AMP-DO | 3 | 138 | 129 | -11 to -5 | -8% to -3% |
| BIP | 1 | 219 | 221 | 2 to 2 | 1% to 1% |
| CBP-DA | 5 | 26 | 20 | -10 to -2 | -34% to -7% |
| CBP-DO | 6 | 28 | 23 | -6 to -3 | -24% to -10% |
| DBP | 3 | 38 | 38 | -6 to 7 | -16% to 18% |
| PDP | 7 | 28 | 25 | -28 to 4 | -27% to 13% |
| SmartAC | 1 | 110 | 78 | -32 | -29% |
| SmartRate | 6 | 19 | 19 | -5 to 9 | -19% to 108% |

^Excludes dynamic pricing events prior to August 2012. PG&E discovered and corrected errors in those models in late July.