

From: Doll, Laura
Sent: 11/1/2013 2:56:07 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: Courtesy Notification L-210C Potentially Out of Class

Liza

FYI. You may recall I mentioned this work in Vallejo to you two weeks ago, and here is the notice of completion.

Laura

From: Redacted
Sent: Friday, November 01, 2013 2:14 PM
To: 'michael.robertson@cpuc.ca.gov'
Cc: 'dennis.lee@cpuc.ca.gov'; 'aimee.cauguiran@cpuc.ca.gov'; 'sunil.shori@cpuc.ca.gov'
Subject: FW: Courtesy Notification L-210C Potentially Out of Class

Mr. Robertson,

PG&E would like to provide an update to the attached Courtesy Notification Regarding Out of Class Operation Discovery on Transmission Pipeline L-210C in the City of Vallejo.

The roughly 80-foot section of pipe which may be 24-inch OD 0.250-inch WT X-52 was removed and is scheduled for destructive testing at ATS to determine the actual pipe specifications. The removed section of pipe was replaced with roughly 80 feet of 24-inch OD 0.375-inch WT X-60 DSAW and was tied in on October 27, 2013. Pressure was restored to an MAOP of 650 psi on the same day.

Sincerely,

Redacted

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

6111 Bollinger Canyon Road, San Ramon, Ca 94583

Redacted

From: Redacted

Sent: Monday, October 21, 2013 9:50 AM

To: Robertson, Michael

Cc: Lee, Dennis M.; Cauguiran, Aimee (aimee.cauguiran@cpuc.ca.gov); Shori, Sunil (sunil.shori@cpuc.ca.gov)

Subject: Courtesy Notification L-210C Potentially Out of Class

Mr. Robertson,

Attached find a courtesy notification regarding an 80 foot section of L-210C in Vallejo that may be operating out of class.

Sincerely,

Redacted

Regulatory Compliance
PG&E - Gas Standards and Policies
6111 Bollinger Canyon Rd., CA

Redacted