



2012 Daily Forecasted vs. Actual DR

Programs	No. of DR Events	Daily Forecast	Ex-Post	Difference	%
		(Averaged MW over All Events)		(Range from Low to High)	
AMP-DA	3	44	50	-1 to 10	-1% to 23%
AMP-DO	3	138	129	-11 to -5	-8% to -3%
BIP	1	219	221	2 to 2	1% to 1%
CBP-DA	5	26	20	-10 to -2	-34% to -7%
CBP-DO	6	28	23	-6 to -3	-24% to -10%
DBP	3	38	38	-6 to 7	-16% to 18%
PDP	7	28	25	-28 to 4	-27% to 13%
SmartAC	1	110	78	-32	-29%
SmartRate	6	19	19	-5 to 9	-19% to 108%

^Excludes dynamic pricing events prior to August 2012. PG&E discovered and corrected errors in those models in late July.