

From: Cherry, Brian K
Sent: 12/10/2013 1:32:54 PM
To: Paul Clanon (paul.clanon@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov); Jack Hagan (Jack.Hagan@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: Gas Incident in Oakland This Morning

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: "Stavropoulos, Nickolas" <NISL@pge.com>
To: "Officers - All" <AllPGEOfficers@exchange.pge.com>, "Lemler, Gregg (ET)" <GLL1@pge.com>, "Hogan, Patrick" <PIHF@pge.com>
Cc: "King, Mary K." <MKK8@pge.com>, "Zigelman, Jacob" <Jacob.Zigelman@pge-corp.com>
Subject: Gas Incident in Oakland This Morning

Senior Team,

This morning at 8:39am we received a 911 Call from Oakland FD reporting a ruptured gas line and fire in the street at [Redacted] in Oakland. Gas flow was stopped at 11:35am by squeezing of the 4 inch plastic main. Attached is a ground level picture of the fire and a schematic of the gas lines and electrical vault in the area of the fire. Cause of the leak and fire is underway. No injuries reported. PG&E emergency response personnel are on site from customer, claims, communications, etc. in support of the gas operations IC, Kevin Souza. Jesus Soto just arrived on site.

Here is the unofficial timeline of the incident derived from entries into IMT and FAS and with information obtained from the incident commander.

[Redacted] Oakland, CA – 4” plastic main
8:39am – Oakland Fire Department calls PG&E emergency line reporting a

ruptured gas line in Oakland with fire coming from the ground
8:42am – Gas M&C Supervisor Mark Augustine notified of event via phone,
requested M&C crew response
8:44am – Gas Service Rep Steve Harvey onsite
9:20am – Gas M&C crews onsite (4 total crews)
9:40am – Gas M&C Superintendent Kevin P Souza onsite, assumed IC
responsibilities
11:35am – Gas flow stopped by applying squeezers to 4” plastic main

We will provide an update when we have an understanding of the
possible cause.

Best, Nick