

From: Cherry, Brian K
Sent: 12/17/2013 1:56:59 PM
To: Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: 3-in PL FW: Gas Incident: PG&E Incident No: 131217-5629

From: [Redacted]
Sent: Tuesday, December 17, 2013 1:43 PM
To: UO EP Gas Incident Notify
Subject: 3-in PL FW: Gas Incident: PG&E Incident No: 131217-5629

At approximately 11:16am on 12/17/2013, PG&E was notified of a dig-in [Redacted], San Jose. San Jose Water Department struck a 3-inch plastic main with a backhoe, which resulted in a release of gas. PG&E arrived on-site at approximately 11:33am. Gas flow was stopped at 1:15pm. Fire department and police department were also on site. KTVU arrived on site later making this incident reportable. 4 buildings have been evacuated, along with 1 apartment complex.

I also just received a call from the CPUC and they are wanting to go on-site.

[Redacted]
PG&E Regulatory Compliance, Senior Engineer

[Redacted]

Think and Act Safely

From: webmaster@cpuc.ca.gov [mailto:webmaster@cpuc.ca.gov]
Sent: Tuesday, December 17, 2013 1:31 PM
To: usrb@cpuc.ca.gov
Cc: [Redacted]

Subject: Gas Incident: PG&E Incident No: 131217-5629

The Following information regarding this incident has been reported:

Reporting Date: 12/17/2013 1:24:15 PM

Incident Date: 12/17/2013 @ 11:16 a.m.

Reported By: Redacted

Utility Name: PG&E

Phone Number: Redacted

Email Address:

Incident Location: Redacted santa clara

Reported to DOT? no

DOT Number:

Reasons For Reporting:

- Fatalities? No (Utility: 0, Others: 0)
- Names of Fatalities:
- Injuries? No (Utility: 0, Others: 0)
- Names of Injured:
- Damage? No (Utility: 0, Others: 0)
- Interruption? No (Total Customers: 0, Total Hours: 0)
- Operator Judgement? No
- Transmission Shutdown? No
- Transmission Test Failure? No
- Media Coverage? Yes

Cause of Incident: Digin (Other Cause: none)

Emergency Action:

Public Agencies on Scene: Police; Fire; Media;

Gas Facilities Involved: Distribution;

- Specifications of Failed Facilities:
- Pipe Size (in.): 3
- MAOP (psi):
- Operating Press (psi):
- Type(s): Plastic

DigIn Information: USA Required;

- Excavator Name: SJ Water Dept
- Contact:

- Phone:

Incident Recovery:

- On Scene Date & Time: 12/17/2013 @ 11:33 a.m.

- Service Restored: @ 00:00 a.m.

Summary: At approximately 11:16am on 12/17/2013, PG&E was notified of a dig-in at 975 The Alameda, San Jose. San Jose Water Department struck a 3-inch plastic main with a backhoe, which resulted in a release of gas. PG&E arrived on-site at approximately 11:33am. Fire department and police department were also on site. KTVU arrived on site later making this incident reportable.