

From: Doll, Laura
Sent: 12/17/2013 2:52:15 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: UPDATE Explosion at [Redacted] County

The latest.

From: [Redacted]
Sent: Tuesday, December 17, 2013 2:07 PM
To: UO EP Gas Incident Notify
Subject: RE: Explosion at [Redacted] County

An update on this event:

[Redacted] is on site as field support and confirmed the fire originated in the oven, and that we do not believe there is any tampering with the oven. He believe the root cause was the delayed ignition and build up of gas. The explosion was a result of natural gas ignition on **non-PGE facilities**. Randy conducted a leak survey inside the jail, and the outside grounds and found no indications of a leak.

Thanks.

[Redacted]
PG&E| Regulatory Compliance| Senior Engineer
[Redacted]

Think and Act Safely

R
e
d
a
c
t
e
d

From: [Redacted]
Sent: Tuesday, December 17, 2013 1:20 PM
To: UO EP Gas Incident Notify
Subject: Explosion [Redacted] County

At approximately 11:54, PG&E was notified of an explosion at [Redacted] at the [Redacted] with injured parties en route to the hospital. PG&E arrived on site at 12:12. There was no gas released as a result of the explosion. The fire department and media are on site. This incident is a CPUC reportable due to it being an explosion.

R

d
a

The Following information regarding this incident has been reported:

Reporting Date: 12/17/2013 1:07:06 PM

Incident Date: 12/17/2013 @ 11:54 a.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: [Redacted]

Reported to DOT? no

DOT Number:

Reasons For Reporting:

- Fatalities? No (Utility: 0, Others: 0)
- Names of Fatalities:
- Injuries? No (Utility: 0, Others: 0)
- Names of Injured:
- Damage? No (Utility: 0, Others: 0)
- Interruption? No (Total Customers: 0, Total Hours: 0)
- Operator Judgement? Yes
- Transmission Shutdown? No
- Transmission Test Failure? No
- Media Coverage? No

Cause of Incident: Unknown (Other Cause: Explosion at [Redacted])

Emergency Action:

Public Agencies on Scene: Fire; Ambulance; Media;

Gas Facilities Involved: Distribution;

- Specifications of Failed Facilities:
- Pipe Size (in.): 4
- MAOP (psi): 60
- Operating Press (psi): 55
- Type(s): Plastic unk

DigIn Information:

- Excavator Name:
- Contact:
- Phone:

Incident Recovery:

- On Scene Date & Time: 12/17/2013 @ 12:12 p.m.
- Service Restored: @ 00:00 a.m.

Summary: At approximately 11:54, PG&E was notified of an explosion at [Redacted] [Redacted] with injured parties en route to the hospital. PG&E arrived on site at 12:12. There was no gas released as a result of the explosion. The fire department and media are on site. This incident is a CPUC reportable due to it being an explosion.

[Redacted]

PG&E | Regulatory Compliance | Senior Engineer

[Redacted]

Think and Act Safely