

From: Doll, Laura
Sent: 12/17/2013 1:47:46 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: Dig-in in San Jose

San Jose Water Department dig-in.

Evacuations should be short.

From: [Redacted]
Sent: Tuesday, December 17, 2013 1:43 PM
To: UO EP Gas Incident Notify
Subject: 3-in PL FW: Gas Incident: PG&E Incident No: 131217-5629

At approximately 11:16am on 12/17/2013, PG&E was notified of a dig-in at [Redacted], San Jose. San Jose Water Department struck a 3-inch plastic main with a backhoe, which resulted in a release of gas. PG&E arrived on-site at approximately 11:33am. Gas flow was stopped at 1:15pm. Fire department and police department were also on site. KTVU arrived on site later making this incident reportable. 4 buildings have been evacuated, along with 1 apartment complex.

I also just received a call from the CPUC and they are wanting to go on-site.

[Redacted]

PG&E Regulatory Compliance Senior Engineer

[Redacted]

Think and Act Safely

From: webmaster@cpuc.ca.gov [mailto:webmaster@cpuc.ca.gov]

Sent: Tuesday, December 17, 2013 1:31 PM
To: usrb@cpuc.ca.gov
Cc: [Redacted]
Subject: Gas Incident: PG&E Incident No: 131217-5629

The Following information regarding this incident has been reported:

Reporting Date: 12/17/2013 1:24:15 PM
Incident Date: 12/17/2013 @ 11:16 a.m.
Reported By: [Redacted], Compliance Engineer
Utility Name: PG&E
Phone Number: [Redacted]
Email Address: [Redacted]

Incident Location: [Redacted]

Reported to DOT? no
DOT Number:

- Reasons For Reporting:**
- Fatalities? No (Utility: 0, Others: 0)
 - Names of Fatalities:
 - Injuries? No (Utility: 0, Others: 0)
 - Names of Injured:
 - Damage? No (Utility: 0, Others: 0)
 - Interruption? No (Total Customers: 0, Total Hours: 0)
 - Operator Judgement? No
 - Transmission Shutdown? No
 - Transmission Test Failure? No
 - Media Coverage? Yes

Cause of Incident: Digin (Other Cause: none)

Emergency Action:

Public Agencies on Scene: Police; Fire; Media;

- Gas Facilities Involved:** Distribution;
- Specifications of Failed Facilities:
 - Pipe Size (in.): 3
 - MAOP (psi):
 - Operating Press (psi):
 - Type(s): Plastic

DigIn Information: USA Required;

- Excavator Name: SJ Water Dept
- Contact:
- Phone:

Incident Recovery:

- On Scene Date & Time: 12/17/2013 @ 11:33 a.m.
- Service Restored: @ 00:00 a.m.

Summary: At approximately 11:16am on 12/17/2013, PG&E was notified of a dig-in at [Redacted] [Redacted] San Jose Water Department struck a 3-inch plastic main with a backhoe, which resulted in a release of gas. PG&E arrived on-site at approximately 11:33am. Fire department and police department were also on site. KTVU arrived on site later making this incident reportable.