

From: Doll, Laura
Sent: 12/19/2013 2:16:11 PM
To: 'michael.robertson@cpuc.ca.gov' (michael.robertson@cpuc.ca.gov);
'eim@cpuc.ca.gov' (eim@cpuc.ca.gov)
Cc: Yura, Jane (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=JKY1); Cherry,
Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7); Yee,
Frances (/o=PG&E/ou=Corporate/cn=Recipients/cn=FSC2); Gibson, Bill (Codes)
(/o=PG&E/ou=Corporate/cn=Recipients/cn=WLG3); emory.hagan@cpuc.ca.gov
(emory.hagan@cpuc.ca.gov); 'Clanon, Paul' (paul.clanon@cpuc.ca.gov); Terrie D.'
'Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov);
'urrb@cpuc.ca.gov' (urrb@cpuc.ca.gov); Christopher, Melvin J. (GSO)
(/O=PG&E/OU=Corporate/cn=Recipients/cn=M6CE)

Bcc:

Subject: RE: Davis update

Liza and Mike,

I'm happy to update my previous messages about the low gas pressure event in Davis today.

Only a handful of business customers were affected, and the situation continues to be safely managed by local PG&E crews.

We were able to reroute gas delivery to avoid any further interruptions to customers in the area.

We have isolated the issue at a local regulation station in Davis and crews are mobilizing to make any necessary repairs. SED representative Banu was on-site earlier today and we will be sending her additional information about the low pressure event today.

Temperatures are moderate for this time of year, and we anticipate having adequate gas supply to meet current demand.

If you have any interest in further discussion about this, Mel Christopher, Senior Director of gas system operations, can be available for a call today around 4:30; let me know. Otherwise we will continue to work through Banu in providing information about the event.

If we don't otherwise connect, have a great holiday and much needed break.

Laura

-----Original Message-----

From: Doll, Laura

Sent: Thursday, December 19, 2013 12:36 PM

To: eim@cpuc.ca.gov; pac@cpuc.ca.gov; michael.robertson@cpuc.ca.gov; terrie.prosper@cpuc.ca.gov

Cc: Cherry, Brian K; Yura, Jane; Gibson, Bill (Codes)

Subject: Davis update

The latest word is that the pressure reduction in Davis is being mitigated without major loss of service to

customers. Work remains underway and we will keep you informed.