

From: Doll, Laura  
Sent: 1/9/2014 5:47:09 AM  
To: pac@cpuc.ca.gov (pac@cpuc.ca.gov); eim@cpuc.ca.gov (eim@cpuc.ca.gov);  
terrie.prosper@cpuc.ca.gov (terrie.prosper@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fw: DOT and CPUC Reportable Incident - Felton  
Fyi

**From:** [Redacted]  
**Sent:** Thursday, January 09, 2014 03:33 AM  
**To:** UO EP Gas Incident Notify  
**Cc:** [Redacted]  
**Subject:** DOT and CPUC Reportable Incident - Felton

On January 9, 2014 at approximately 0054 hours, the Felton Fire Department reported a structure fire at [Redacted] in Felton, Ca. Pacific Gas and Electric (PG&E) was on scene at approximately 0146 hours. The structure was completely burnt to the ground. The fire melted PG&E's meter set, which resulted in an unintentional release of natural gas. PG&E shut off the meter at [Redacted] which was across the street from [Redacted] to prevent further damage from occurring. There were no injuries or deaths and [Redacted] has been blocked off. The local fire and police departments were on scene. Local media (KSBW Channel 8) was on scene. The Fire Department's initial assessment was that the fire was caused by a houseline rupture but further investigation is currently being done. Damages will exceed \$50,000, thus, making this a DOT and CPUC reportable event.

Please let me know if you have any questions.

[Redacted]

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

6111 Bollinger Canyon Road, 4<sup>th</sup> Floor

San Ramon, CA 94583

[Redacted]

Redacted