

From: Prosper, Terrie D.
Sent: 1/23/2014 7:20:20 AM
To: Doll, Laura (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD)
Cc:
Bcc:
Subject: RE: CPUC reportable gas incident - San Francisco

Thanks!

----- Original message -----

From: "Doll, Laura"
Date:01/23/2014 5:56 AM (GMT-08:00)
To: "Clanon, Paul" ,"Malashenko, Elizaveta I." ,"Prosper, Terrie D."
Subject: Fw: CPUC reportable gas incident - San Francisco

Fyi

From: [Redacted]
Sent: Wednesday, January 22, 2014 11:20 PM
To: UO EP Gas Incident Notify
Cc: [Redacted]
Subject: CPUC reportable gas incident - San Francisco

At approximately 2005 hours PG&E was notified a third party driver struck the meter set at [Redacted] in San Francisco causing a release of gas. The driver fled the scene after striking the meter. PG&E's gas service rep arrived on scene at 2012 hours and attempted to stop the flow of gas by closing the service valve but gas was still hissing from the valve and riser connection. PG&E crews arrived on site at 2045 hours and tighten the valve at the threaded connection to further stop the flow of gas at 2100 hours. Crews are currently working to make permanent repairs to the service line. The affected building was vacant at the time of the incident. Out of an abundance of caution, the fire department evacuated the neighboring building. There were no injuries, no fatalities and no ignition as a result of this incident. This was report to the CPUC because Channel 4 news was observed on scene.

[Redacted]

Regulatory Compliance

Gas Operations | Pacific Gas and Electric

6111 Bollinger Canyon Road, San Ramon, Ca 94583

[Redacted]

Redacted

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>