



### District Regulator Data Sheet

62-6271 (12/09)  
Gas T&D  
Page 1 of 2

Division	SACRAMENTO	District Station No.	R-DA-012	Associated Station No.(s)	DA-07, DA-02
Location	Redacted			Wall Map, Plat, Block	Reda
Job No. References	Stage SINGLE				
Installation Date	Date of Last Major Alteration 10/30/09				
Inlet Pressure: MAOP/MOP	175#/170#	Set points (working run):	Regulator 52# 51	Monitor 57# 53	Reliefs: N/A
Outlet Pressure: MAOP/MOP	55#/52# 51	Set points (stand-by):	Regulator 50# 47	Monitor 57# 53	Reliefs: N/A

**Run- Left, Middle, Right, Top, or Bottom (Looking Downstream): LEFT**

		UPSTREAM DEVICES	DOWNSTREAM DEVICES	RELIEF VALVE	AUTOMATIC SHUTOFF
Manufacturer		MOONEY (93R)	MOONEY (95R)		
Serial Number		106051	106062		
Model		FLOWGRID	FLOWGRID		
Size / Flange Type		4" ANSI 300	4" ANSI 300		
Inlet Pressure Rating		740#	740#		
Outlet Pressure Rating		-	-		
Head (Diaphragm) Size		4" 75 DURO	4" 75 DURO		
Orifice Size or Core Capacity		100% GRID	100% GRID		
Valve Seat or Boot Material		NITRILE	NITRILE		
Main Spring Range		-	-		
Pilot	Manufacturer	MOONEY	MOONEY		
	Model	S-20	S-20		
	Spring Range	25-90#	25-90#		
	Orifice Size	3/32"	3/32"		
	Filter Type	MOONEY	MOONEY		
Restrictor Type	MOONEY	MOONEY			
Other Equipment					

**Line Filter**

Size	GWP	Make	Model	Filter Element, Type
N/A				

**Pressure Recording Device**

Manufacturer	Serial No.	Model	Range(s)	Chart No. and Rotation
SCADA				

**Station Valves**

Valve No	Size	Type	Manufacturer	Figure No.	Connection Type/Flange Rating	Max. Working Press.
V-23	4"	PLUG	WALWORTH	1760-F	FLNG ANSI 300	720#
V-25	4"	PLUG	WALWORTH	1760-F	FLNG ANSI 300	720#
V-28	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
V-29	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
V-24	2"	PLUG	WALWORTH	1660-F	FLNG ANSI 300	720# (BY-PASS)
Outlet Fire Valve	Use Valve Maintenance Record Form F4430-04-1					
Inlet Fire Valve	V-20	Use Valve Maintenance Record Form F4430-04-1				

**Enclosure**

Upstream: Above Ground	<input type="checkbox"/>	Vault	<input checked="" type="checkbox"/>	Dimensions 6'x5'x9.5' Cu. Ft. 285 Type Construction CONCRETE Type Closure ALUMINUM
Downstream: Above Ground	<input type="checkbox"/>	Vault	<input checked="" type="checkbox"/>	Dimensions 6'x5'x9.5' Cu. Ft. 285 Type Construction CONCRETE Type Closure ALUMINUM



### District Regulator Data Sheet

62-6271 (12/09)  
Gas T&D  
Page 1 of 2

Division	SACRAMENTO	District Station No.	R-DA-012	Associated Station No.(s)	DA-07, DA-02
Location	Redacted			Wall Map, Plat, Block	Red
Job No. References	Stage SINGLE				
Installation Date	Date of Last Major Alteration 10/30/09				
Inlet Pressure: MAOP/MOP	175#/170#	Set points (working run):	Regulator 52# 51	Monitor 57# 53	Reliefs N/A
Outlet Pressure: MAOP/MOP	55#/52# 51	Set points (stand-by):	Regulator 50# 49	Monitor 57# 53	Reliefs N/A

2-19-13 2040

**Run- Left, Middle, Right, Top, or Bottom (Looking Downstream): RIGHT**

	UPSTREAM DEVICES	DOWNSTREAM DEVICES	RELIEF VALVE	AUTOMATIC SHUTOFF
Manufacturer	MOONEY (94R)	MOONEY (96R)		
Serial Number	106061	106064		
Model	FLOWGRID	FLOWGRID		
Size / Flange Type	4" ANSI 300	4" ANSI 300		
Inlet Pressure Rating	740#	740#		
Outlet Pressure Rating	-	-		
Head (Diaphragm) Size	4" 75 DURO	4" 75 DURO		
Orifice Size or Core Capacity	100% GRID	100% GRID		
Valve Seat or Boot Material	NITRILE	NITRILE		
Main Spring Range	-	-		
Pilot	Manufacturer	MOONEY	MOONEY	
	Model	S-20	S-20	
	Spring Range	25-90#	25-90#	
	Orifice Size	3/32"	3/32"	
	Filter Type	MOONEY	MOONEY	
Restrictor Type	MOONEY	MOONEY		
Other Equipment				

**Line Filter**

Size	GWP	Make	Model	Filter Element, Type
N/A				

**Pressure Recording Device**

Manufacturer	Serial No.	Model	Range(s)	Chart No. and Rotation
SCADA				

**Station Valves**

Valve	Valve No.	Size	Type	Manufacturer	Figure No.	Connection Type/Flange Rating	Max. Working Press.
Valve	V-22	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
Valve	V-26	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
Valve	V-27	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
Valve	V-30	4"	PLUG	WALWORTH	19604-14	FLNG ANSI 300	720#
Valve	V-31	2"	PLUG	WALWORTH	2987-F	FLNG ANSI 300	720# (BY-PASS)
Valve							
Outlet Fire Valve	Use Valve Maintenance Record Form F4430-04-1						
Inlet Fire Valve	V-20	Use Valve Maintenance Record Form F4430-04-1					

**Enclosure**

Upstream: Above Ground	<input type="checkbox"/>	Vault	<input checked="" type="checkbox"/>	Dimensions 6'x5'x9.5' Cu. Ft. 285	Type Construction CONCRETE	Type Closure ALUMINUM
Downstream: Above Ground	<input type="checkbox"/>	Vault	<input checked="" type="checkbox"/>	Dimensions 6'x5'x9.5' Cu. Ft. 285	Type Construction CONCRETE	Type Closure ALUMINUM

