

From: Cherry, Brian K  
Sent: 2/2/2014 4:23:27 PM  
To: Paul Clanon (paul.clanon@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: Unit 2 Trip Due to Flashover on Lightning Arrestor  
FYI.

Sent from my iPad

Begin forwarded message:

**From:** DCPD Communications <[DCPDCommunications@pge.com](mailto:DCPDCommunications@pge.com)>  
**Date:** February 2, 2014 at 4:14:50 PM PST  
**To:** DCPD \*NPG Nuclear Power Generation Business Unit  
<[DCPDNPG@pge.com](mailto:DCPDNPG@pge.com)>  
**Cc:** Officers - All <[AllPGEOfficers@exchange.pge.com](mailto:AllPGEOfficers@exchange.pge.com)>  
**Subject: Unit 2 Trip Due to Flashover on Lightning Arrestor**

DCPD Employees;

At approximately 1130 this morning, Unit 2 tripped, safely activating our automatic safety shut-down system as designed. The trip occurred due to a flashover on the Bravo Phase Lightning Arrestor on Unit 2. Build-up of dust and wet weather conditions likely caused the flashover. Unit 2 is in a safe condition and currently in Mode 3. Unit 1 is safely operating at 100 percent power.

The trip was event-free and our initial response to the event has been very professional. Whether you are responding to this incident or working on other activities, we ask that you keep a high-level of situational awareness, look out for one another and, as always, approach your work in a safe and methodical manner marked by a strong questioning attitude.

The Outage Coordination Center is activated and this event is being referenced

as 2Z18. We will continue to keep you – and our external stakeholders – informed as our team successfully works through 2Z18.

Barry Allen