

From: Cherry, Brian K  
Sent: 2/25/2014 1:01:01 PM  
To: Denise Tyrrell (denise.tyrrell@cpuc.ca.gov); Paul Clanon  
(paul.clanon@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fwd: CPUC Reportable Gas Incident

FYI

Brian K. Cherry  
PG&E Company  
VP, Regulatory Relations  
77 Beale Street  
San Francisco, CA. 94105  
(415) 973-4977

Begin forwarded message:

**From:** [Redacted]  
**Date:** February 25, 2014 at 12:26:25 PM PST  
**To:** UO EP Gas Incident Notify  
<DCSTSGasIncidentNotify@exchange.pge.com>  
**Cc:** [Redacted]  
**Subject:** CPUC Reportable Gas Incident

At approximately 0940 hours PG&E was notified of a gas odor at [Redacted]  
[Redacted], Oakland. The gas odor was detected at [Redacted]  
[Redacted] PG&E was on site at approx. 1000 hours. It was determined that a  
main line valve on the schools roof was open and releasing gas. This valve was  
connected to burners in an old science lab. The schools maintenance worker  
shut the valve above the science room. PG&E did not have to shut off the gas  
meter. The school evacuated the students from the premises.

This incident is being reported to the CPUC due to operator judgment because  
there are multiple Bay Area media entities onsite, and because of the school  
evacuation.

Redacted Gas Operations Support Team Pacific Gas and Electric Company

Redacted

GOST Shared Line: 925.328.5400 Direct Line: Redacted