

From: Doll, Laura
Sent: 2/18/2014 5:20:39 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc: Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov)
Bcc:
Subject: FW: CPUC Reportable Incident - San Francisco

FYI

From: [Redacted]
Sent: Tuesday, February 18, 2014 4:24 PM
To: UO EP Gas Incident Notify
Cc: [Redacted]; [Redacted]; [Redacted]; [Redacted]
[Redacted]
Subject: CPUC Reportable Incident - San Francisco

At approximately 2:32pm, PG&E was notified of a 3rd party dig-in at the intersection of [Redacted] [Redacted] that caused an unintentional release of gas. The line struck was a 4" plastic main. PG&E GSR / Crews were on site at 2:50pm. Traffic has been blocked, and a nearby school, [Redacted], has been evacuated. The FD / PD / Media were all on site. There were no fires / explosions / injuries / fatalities in result of this incident. There are 4 service interruptions as a result of this incident. The flow of gas was stopped at 3:10pm. Repairs are estimated to be complete at approximately 7:00pm. The 3rd party involved was [Redacted]. According to the supervisor on site, [Redacted], it is unclear whether the 3rd party was working under a valid USA ticket, and it is unclear whether there were proper markings for the gas lines.

This incident is reportable to the CPUC due to the presence of media.

Thanks

Eric

Redacted

*Rate Case Witness Assistant | Chapter 4A
Gas Transmission Integrity Management
Pacific Gas & Electric
6111 Bollinger Canyon Rd #4750G*

*San Ramon, Ca 94583
Office: 1-925-328-5866*

Redacted

Fax: 1-925-328-5595

Redacted