

From: Doll, Laura
Sent: 2/19/2014 3:04:43 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov)
Cc: Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov)
Bcc:
Subject: FW: CPUC Reportable Incident - San Jose

FYI

From: Redacted
Sent: Wednesday, February 19, 2014 3:02 PM
To: UO EP Gas Incident Notify
Cc: Rodriguez, Ken; Camera, Steve Jr.; DeCosta, Jason; Hernandez, Philip
Subject: CPUC Reportable Incident - San Jose

At approximately 10:52am, PG&E was notified of a third party dig in at Redacted in San Jose that caused an unintentional release of gas. The line struck was a ½ inch plastic service coming off of a 10” steel main. PG&E GSR was on site at 11:06am. PG&E Crews were on site at 12:19pm. The fire department / police department evacuated a nearby bank, and blocked off the traffic to the area to restrict access around the incident. Media came on site at an unknown time. There were no fires / explosions / injuries / fatalities as a result to this incident. The flow of gas was stopped at 2:01pm. There have been 94 service interruptions as a result to this incident. Service is expected to be restored by 5:00pm. The 3rd party is Northern Underground Construction. A contact for the 3rd party is Redacted. The 3rd party was working under a valid USA ticket, and the area was marked. According to the supervisor on site, the markings for the 10” steel main were accurate, however, the markings for the ½” plastic service appeared to be inaccurate.

This incident is reportable to the CPUC due to the presence of media.

Thanks

Redact

Redacted

*Rate Case Witness Assistant | Chapter 4A
Gas Transmission Integrity Management
Pacific Gas & Electric
6111 Bollinger Canyon Rd #4750G*

*San Ramon, Ca 94583
Office: 1-925-328-5866*

Mobile: 1-925-588-5443

Fax: 1-925-328-5595

Email Redacted