

From: Cherry, Brian K
Sent: 2/25/2014 1:01:01 PM
To: Denise Tyrrell (denise.tyrrell@cpuc.ca.gov); Paul Clanon
(paul.clanon@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: CPUC Reportable Gas Incident

FYI

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: [Redacted]
Date: February 25, 2014 at 12:26:25 PM PST
To: UO EP Gas Incident Notify
<DCSTSGasIncidentNotify@exchange.pge.com>
Cc: [Redacted]
Subject: CPUC Reportable Gas Incident

At approximately 0940 hours PG&E was notified of a gas odor at [Redacted]
[Redacted] The gas odor was detected at [Redacted]
[Redacted] PG&E was on site at approx. 1000 hours. It was determined that a
main line valve on the schools roof was open and releasing gas. This valve was
connected to burners in an old science lab. The schools maintenance worker
shut the valve above the science room. PG&E did not have to shut off the gas
meter. The school evacuated the students from the premises.

This incident is being reported to the CPUC due to operator judgment because
there are multiple Bay Area media entities onsite, and because of the school
evacuation.

Redacted Gas Operations Support Team Pacific Gas and Electric Company

Redacted
GOST Shared Line: 925.328.5400 Direct Line: Redacted