



CPUO Meeting Materials

Weekly Non-Destructive Examination Program Updates

March 14, 2014

DRAFT For Discussion Purposes Only

1



- PG&E/SE Alignment
 - L-114
 - Extent of Conditions for TCI Inspections
 - NDE Program Enhancements
 - NDE Program Validation Protocols/Extent of Conditions (LLNL)
- Completed Activities To Date
- Next Steps
 - Schedule
 - Immediate Needs



- See presentation dated 3/7/2014 for past items
- Completed all 43 committed digs/re-inspections (Appendix I)
- Leak Survey details
 - Leak Survey began on 600 miles of identified Gas Transmission pipeline (12/2/2013)
 - February Leak Survey Finalized :
 - Zero leaks found on weld (Girth or Long Seam)
 - PG&E requesting authorization to suspend “monthly” leak surveys (Appendix II)
- LLNL finalized “Review of PG&E Proposed Dig Plan” (Appendix III)
 - Established 3 alternatives
 - Re-inspection/Digs with 5% error
 - Re-Inspection/Digs with 2% error
 - Comprehensive analysis of weld inspections through existing film
 - PG&E working to secure LLNL’s services for Comprehensive analysis
 - Contract routing for signature

¹Activity progress/completion is discussed in the Completed Activities To Date section

²Dates are contingent on weather, permit, and/or construction schedules



LLNL Recommended Alternative

- Comprehensive Analysis Alternative
 - Analyze all film for 488 non-compliant welds
 - Establish conditional probability of weld flaws being present by utilizing rejection information from construction
 - Utilize probability of weld flaws within population of 488
 - Utilize non-compliant weld film and establish total % of area that can detect
 - Determine population of welds requiring re-inspection
 - Dig/Re-inspect welds requiring it
 - Speculation that many of the required digs be of the 43 PG&E has already re-inspected
 - Will need to confirm once analysis is complete
 - LLNL issued summary report on 3/13/2014 (Appendix III)

¹Activity progress/completion is discussed in the Completed Activities To Date section

²Dates are contingent on weather, permit, and/or construction schedules



Completed Activities to Date

- See 2/7/14 presentation for items prior to 2/1/14
- Excavated/Tested/Passed 43 welds as of 3/11/14:
 - 5 welds on L-132
 - 12 welds at Vernalis Station
 - 2 welds at 8 Mile Rd Pressure Limiting Station (PLS)
 - 4 welds on L-108 (MLV38.1)
 - 4 welds at Gateway Generating Station
 - 8 welds at L-108 (MLV38.17)
 - 3 welds on DFM-1616
 - 3 welds on L-331A (WV-7)
 - 2 welds on L-302W(Appendix I)
- Completed L-114 Final Report
- Created Map of pipeline segments to be Leak Surveyed as a result of L-114 Findings
- Completed 3 monthly Leak Surveys of 600 miles of pipeline
 - Zero leaks on welds have been found



- High Level activities within the next 6 Weeks
- See 2/7/14 presentation for prior items:
 - Finalize Comprehensive Analysis of TCI Data Set
 - Establish required digs (3 months)
 - Finalize digs/re-inspections (TBD)
 - Establish LLNL contract update for analysis associated with recommended alternative for TCI Validation
 - LLNL to perform analysis of all film ~~and~~ recommendations for re-inspection
 - PG&E has contract in progress currently
- Issue revised standards/Testing/Training for NDE Program (4/15/2014)



Appendix I

Summary of WV-8A Re-Inspections

DRAFT For Discussion Purposes Only

12



Technical Services, Inc.
 P. O. Box 721139, Houston, Texas 77272-1139

Redacted

www.ndttechnicalservices.com

SUMMARY AND ASSESSMENT OF EOC – RE-INSPECTION PERFORMED ON GIRTH WELDS

In accordance with the approved PG&E Inspection Test Plan (ITP), on March 11, 2014 a re-inspection utilizing radiographic examination with AGFA D5 film was performed on two (2) girth welds at verification dig site WV-8A (Hershey Junction) in Dunnigan, CA. Once each of the welds were radiographed they were “fingerprinted” (weld features compared against original images) to verify that the original radiographic film images of the weld matched the images of the re-inspected girth weld.

The following weld numbers were re-inspected:

<u>Original Weld Id Number</u>	<u>Re-inspection Weld Id Number</u>
Location: 8A W-127	W-127-RI
Location: 8A W-128	W-128-RI

The following were the results of these-inspections:

Weld Number: W-127-RI Comments: Weld matched fingerprint and weld was determined to be acceptable to API 1104, 20th edition.

Weld Number: W-128-RI Comments: Weld matched fingerprint and weld was determined to be acceptable to API 1104, 20th edition.

Location 8A contained two (2) 20 in. OD girth weld identified as Weld #127 & 128. A copy of WIX’s Radiographic Testing Inspection report indicating the results of their evaluation of welds examined are attached.


This summary completes the evaluation and documentation of the re-inspections performed on the two (2) identified girth welds on the WV-8A project in Dunnigan, CA.

Let me know should you require any additional information concerning these reviews and approvals.

Respectfully,

Redacted

President
ASNT Level III – 2820
ACCP Professional Level III



Western Industrial X-Ray, Inc.
 P.O. Box 238 Fairfield, CA
 (707) 425-4673
 (888) For X-Ray
 info@wixinc.net
 www.wixinc.net

Date 3/11/2014 Page 1 Of 1
 Radiographic Report or Control # Rig G - 01
 Customer PG&E
 Address _____
 Customer's P.O. Number _____
 Job Location Hershey Junction, Dunnigan L302W
 Job Number 42070345 WV-08A
 Item Description 20" Girth Welds
 100% Insp. Spot Insp. _____ Percent _____

Nondestructive Inspection Report

Piece or Joint #s	Weld Number	Film No.	Acc	Rej	Defect Code	Comments	Work Summary	
							Amount	Description
20" x .500" w	127 RI	3	✓				<u>2</u> Travel Hours	_____ # Persons
20" x .500" w	128 RI	3	✓				<u>0930</u> In Time	<u>1300</u> Out Time
							<u>3.5</u> Work Hours	
							_____ Standby Hours	
							<u>5.5</u> Total Hours	
							_____ Per Diem	_____ # Persons
							Mileage One Way _____ Round Trip _____	
							<u>2</u> Weld <u>20</u> in. dia	_____ Weld _____ in. dia
							_____ Weld _____ in. dia	_____ Weld _____ in. dia
							_____ Weld _____ in. dia	_____ Weld _____ in. dia
							<u>6</u> Film <u>26" x 90</u> Type <u>D5</u>	
							_____ Film _____ x _____ Type _____	
							Technique Date/Procedure Qualification	
							Inspection Specification <u>API 1104</u>	
							Acceptance Standard <u>20th</u>	
							RT Procedure No. <u>RT7</u> Shooting Sketch (RSSS) <u>D</u>	
							View: <u>DWE</u> <u>SWV</u> Source <u>Ir192</u> Curies <u>95</u>	
							Physical Source Size: <u>106x09</u> Effective Focal Spot: <u>139</u>	
							Pb Screens: Front <u>005</u> Center <u>NA</u> Back <u>01</u>	
							Dia. <u>20</u> Material Type: <u>X52</u> Thickness: <u>5</u> Reinf.: <u>125</u>	
							SFD: <u>20</u> Source To Obj.: <u>19.5</u> IQI Essential Wire: <u>1B-8 / 016</u>	
							Exp. Time: <u>2</u> min. <u>30</u> sec. Dev. Time: <u>5m</u> @ <u>68</u> deg.	
							Film Manufacturer: <u>Agfa</u> Speed: <u>D5</u> No. of Exp. <u>3</u> Film <u>3</u>	
							Geometric Unsharpness (Ug): <u>004</u> Avg. Density: <u>2.6</u>	
							Dia. _____ Material Type: _____ Thickness: _____ Reinf.: _____	
							SFD: _____ Source To Obj.: _____ IQI Essential Wire: _____	
							Exp. Time: _____ min. _____ sec. Dev. Time: _____ @ _____ deg.	
							Film Manufacturer: _____ Speed: _____ No. of Exp. _____ Film _____	
							Geometric Unsharpness (Ug): _____ Avg. Density: _____	
							Dia. _____ Material Type: _____ Thickness: _____ Reinf.: _____	
							SFD: _____ Source To Obj.: _____ IQI Essential Wire: _____	
							Exp. Time: _____ min. _____ sec. Dev. Time: _____ @ _____ deg.	
							Film Manufacturer: _____ Speed: _____ No. of Exp. _____ Film _____	
							Geometric Unsharpness (Ug): _____ Avg. Density: _____	


Defect Code

- BT - Burn Through
- C - Crack
- CV - Root Concavity
- CX - Root Convexity
- DT - Drop Through
- ICP - Inadequate Cross Penetration
- IF - Incomplete Fusion
- IP - Incomplete Penetration
- PD - Inadequate Penetration Due to High-Low
- OX - Oxidation
- P - Porosity
- SL - Slag Lines
- SI - Slag Inclusions
- UC - Undercut
- TI - Tungsten Inclusion

Redacted

Level II

Level I



The person signing this document represents that they have the authority to sign on the behalf of the customer. This report does not guaranty or warranty the condition of the materials tested. Western Industrial X-Ray, Inc. is not liable for any interpretation of results or losses attributable to any testing performed. There is no warranty for these services. Any liability is limited to the amount paid for the services in question. Final film interpretation is the responsibility of the customer.

Redacted

Date 3-11-2014



Appendix II

PG&E Weld Quality Leak Survey Recommendation

DRAFT For Discussion Purposes Only

13

RC&E Weld Quality Control Leak Survey Recommendation

Background

In 2012, RC&E began reviewing its Non Destructive Examination (NDE) Program against best industry practices. As part of the RC&E Gas Operations NDE Process Improvement Initiative, the Gas Quality and Improvement (G&I) Group requested the NDE Services Group of RC&E's Applied Technology Services (ATS) to perform job observations of NDE vendors. During the performance of one of these unannounced job observations at a project site on L-114 in Brentwood, CA, the RC&E ATS NDE inspector observed TC Inspection (TCI) performing Radiographic Testing (RT) in a noncompliant manner to both the referenced code (American Petroleum Institute) API edition and their own method procedure.

Actions Taken

RC&E took immediate action, which included ceasing all work with TCI and conducting an in-depth examination of all weld inspections completed by TCI from 2012-2013. RC&E is currently working with Kieffer and Associates, as well as Lawrence Livermore National Labs (LLNL), to do a thorough review of records and to determine the best approach to verify quality. This effort will give RC&E actionable data to identify potential weld inspection gaps and develop a plan to resolve them.

In addition to the statistical work on inspection quality assessments being undertaken by LLNL, RC&E has also evaluated the quality of inspection records for 3,755 welds inspected by this vendor dating back to year 2010. RC&E has also evaluated the radiographic film quality and inspection coverage, finding potential inspection quality issues with 468 of those, as outlined below.

- 1) 137 welds - Inspections performed with the 2 exposures instead of 3
- 2) 127 welds - Inspections performed where the exposure angle is in excess of 120 degrees
- 3) 224 welds - Inspections performed with missing weld coverage

The CPUC found RC&E to be in violation of 49CFR 192.243 and API 1104 for the 224 welds and RC&E was fined \$8.1 million as a result of the violation. RC&E has since excavated and evaluated the safety and the quality of inspection for 43 welds, beginning with the worst quality radiographs. These welds met criteria for API 1104 and revealed that the lower quality of radiographs has not missed any defects that would be of a size that would cause an increased pipeline safety risk or be out of compliance with API 1104.

RC&E has also initiated a monthly leak survey of pipe potentially impacted by a lack of adequate documentation or quality control practices for weld inspections. RC&E determined the scope of the leak survey by considering the following factors:

- Pipe Installation Year : Code requirements for radiography of welds were not implemented until July 1962. As a result, pipe installed prior to 1962 is not subject to the radiography quality control issues being addressed by this work. Therefore, only post-1962 pipe was considered for inclusion in the leak survey.

3/13/2014

- **Land Movement:** In discussing construction-related threats to pipeline integrity, ASME B31.8S-2004, the consensus industry standard for managing system integrity of gas pipelines and incorporated by reference into 49 CFR 192, states that “the existence of these construction related threats alone does not pose an integrity issue. The presence of these threats in conjunction with the potential for outside forces significantly increases the likelihood of an event.” The primary threat for outside forces associated with girth welds is interaction with areas of potential land movement. Therefore, only pipe with a vulnerability to land movement was included in the scope of the survey.
- **Class Location :** All Class 3 and 4 pipe meeting the prior criteria are included in the scope of the survey due to population density near the pipeline.
- **High Consequence Areas (HCAs) :** HCAs in Class 1 and 2 locations are also included in the scope of the survey due to population near the pipeline.

As a result of these criteria, approximately 600 miles of pipe were included in the scope of the survey. PG&E has conducted a leak survey of these pipelines for 3 months, and has not found any leaks during these surveys.

Recommendation

The supplemental leak survey was initiated to ensure the safety of the public near PG&E's pipelines. While PG&E felt a leak survey was appropriate to ensure the safety of the public in the short term, leak survey is not the most effective method to understand the overall risk associated with PG&E's welding quality control process for the following reasons:

- A leak survey only detects an issue with a weld after it has already failed, which does not educate the scope of the potential issue as effectively as a random sample of welds would.
- Since the leak rate on welds is very low (less than 1% of overall leaks), it is unlikely that the leak survey will produce significant results on the state of the welds associated with this pipe.
- Since the issue being addressed is a quality control and an inspection issue and not a construction issue, conducting a leak survey does not address how well the quality control on the weld was conducted or documented, even if it identifies an issue with the weld itself.

Based on the results of the leak survey conducted so far, the ongoing efforts with Kiefner and LLNL, and the findings so far from the in-field evaluations, PG&E believes it is appropriate to suspend these future “monthly” leak surveys pending results of the additional studies underway. If any welds excavated through the study indicate an immediate safety issue, PG&E will re-initiate the leak survey process.

3/13/2014

SB_GT&S_0070190



Appendix III

Review of PG&E Proposed Dig Plan

DRAFT For Discussion Purposes Only

14

Official 켄□η Use 켄□η Only
켄□η

켄□η
켄□η

Review 켄□η of 켄□η PG&E 켄□η 켄□η 켄□η

K. 켄□η Le A. 켄□η, 켄□η G. 켄□η B
and 켄□η L. 켄□η 켄□η Glascoe
켄□η

February 켄□η 켄□η

켄□η
켄□η

OFFICIAL 켄□η USE 켄□η ONLY

: May 켄□η be 켄□η exempt 켄□η from 켄□η public 켄□η release 켄□η under 켄□η 켄□η 켄□η
exemption 켄□η and 켄□η category:
: 켄□η

Exemption 켄□η 켄□η Information

Department 켄□η of 켄□η Energy 켄□η review 켄□η require 켄□η before 켄□η public

- : Date: 켄□η 켄□η 6, 켄□η 2014
- : Name/org: 켄□η Lee 켄□η G. 켄□η Glascoe 켄□η Engineering
- : Guidance: 켄□η AR-2 켄□η (August 켄□η 1999)

켄□η
켄□η

Technical 켄□η Report
submitted 켄□η Pacific 켄□η Gas 켄□η and 켄□η Electric 켄□η Company

켄□η

켄□η
켄□η
켄□η
켄□η
켄□η
켄□η
켄□η

켄□η
켄□η

Official 켄□η Use 켄□η Only

Review of PG&E Proposed

Kristin P. Lennox, Alan Lamont, Graeme Boquet and Lee

Executive Summary

A variety of methods were used to assess and bound risk welds that were subjected to incomplete inspections at in assessed. A comprehensive analytical approach that identified and mitigate risk more effectively based solely on the region based method underlying how to set estimates. A contractor inspected in a weld in the inspections were covered. G&E proposed statistical sampling based digital remediation strategy, and requested that the plan and present possible alternatives.

From a purely technical standpoint, due to size considerations, and there are limits on that can be made due to the lack of random addressed by changing the sample size calculation and fixing the statistics may be less critical than two more. First, the confidence bound G&E proposed (95% confidence that there are 0% defects in the population) is weak, particularly for welds with inspection industry standards considered unusually high. The proposed analysis largely is not the most information about the set of the form of nonparaphy. This is a pessimistic view of the risk situation.

This document contains three proposed alternatives. The first alternative does not a comprehensive assessment of weld defect probability for suggested. This is using graphic information as well as about replacement rates for defective welds. This method can be carried out in parallel with rapidly provide an improved assessment of the state assessment is complete, the decision can be made as weld inspection is necessary. The proposed method is purely statistical in nature and designed to address problems regarding the original sampling based sample sizes. The consistent with the sampling strategy, they would not leverage any information and the default sample sizes would provide flaw rates with the set.

Official Use Only

inspections and a lower bound on risk. The latter assumptions of the confidence, 5% bound on and are purely statistical in nature. That is, they quality based on incomplete radiographic information.

3 Alternative Comprehensive Risk Based Method

There are difficulties in using only statistical methods to address this situation:

- 1) They may not provide a low enough bound on the set of 488. In particular, the current statistical flaw rate (5%) that the human replacement rate of welds at install time. Since believe that improper welding was linked to imp. is 1/6 in to believe that the flaw rate is prior to any being a lower bound could require a substantially higher sample size than 2) Statistical bounds rely on key assumptions about out. Specifically, any member of a population show probability of being selected, or that all items equal probability of exhibiting a flaw. Since weld: dig plan according to this radiograph, of these assumptions (e.g., welds are more likely in welds where the original radiography was poor with flaws that were not repaired are those due to poor radiography. Therefore, sampling based flawed radiography is likely to have produced results will probably be poor and their satisfied with the 5% bounding criteria and the assumptions, then the also indicates a completely random sample for the IS based procedure.

If, however, PG&E or their regulators desire a lower there are alternative methods to a purely statistical approach to a stronger, technically approaches, as noted previously do not account for the partial information about weld: inspection data. Not inspections do not necessarily have probability of finding flaws; they have a reduced (or pos finding flaws for some portion of the circumference of determined that a particular inspection had a very high chan significant weld defects, say in the case. In case, only welds where the inspection is likely to is present, should be inspected for

Official Use Only

This analysis would require additional indices in the installation and the percentage of defective welds detected at installation and a detailed analysis of welds in the installation. Certified in spite of imperfect radiography. The approach would be able to generate a substantially more benefit than assessed relatively quickly.

Such analysis would be conditional on the probability of the underlying rate of flaws at installation and radiographic information is available. The probability of a particular pipe can be treated as a constant.

$$\Pr(\text{flaw present} \mid \text{no flaw detected}) = \frac{\Pr(\text{no flaw detected} \mid \text{flaw present}) \Pr(\text{flaw present})}{\Pr(\text{no flaw detected})}$$

where $\Pr(A|B)$ is the probability of A being true is the probability of missing a flaw that is present) can be $\frac{\Pr(\text{no flaw detected} \mid \text{flaw present}) \Pr(\text{flaw present})}{\Pr(\text{no flaw detected})}$. how much of the weld lacks a flaw can be estimated by considering the replacement rate of similar welds, and the ability to detect the probability that the weld is not flawed and the

For a simplified example, imagine a weld with 90% from a line with a 2% defect rate. The weld is flawed in the being flawed is:

$$\Pr(\text{flaw present} \mid \text{no flaw detected}) = \frac{(1 - 0.9)(0.02)}{0.98 + (1 - 0.09)(0.02)} \approx 0.002$$

That is, we would expect only 0.2% of such weld collection that completely uninspected welds. Note that the notional, that is, the information about the on a girth weld where welds are inspected to detect that influenced neither the detection probability

A comprehensive analysis of conditional probability? every weld in the data set, and then an expected entire collection. The more, and there is a would be less than one, and the detection

² See, e.g., *Revolutions in Statistics* for *Engineering* and *the Sciences*; Brooks/Cole, Inc. (2004), p. 82.

Official Use Only

expected flaw higher than PG&E and their regulators with, then the welds with the highest conditional probability for failure to the welds selected for re-inspection were chosen based on the poor quality of work it is expected that the agency has been conducting also

4 Alternative Statistical Methods

While a purely statistical approach is used of all available welds, it may be preferable to other methods. Two purely sampling based approaches providing confidence with the original analysis are the methods in terms of sampling assumptions are also

4.1 Finite Sample Analysis

The total population size is 488 welds. It is than 5% welds) is acceptable, than this can be determined how many welds must be checked. The first probability of no observed failures given a sample of population where the maximum acceptable number of (x=25) is assumed to exist. This probability can be

Pr(no observed failures | x failures total) = (C(N-x, n) / C(N, n)) * 0.995^n

where N is the population size and n is the sample size.

population size to determine the number of flawed welds in the population below the 95% confidence level, one identifies the calculated probability of observing no failures. The minimum sample size is 43. Neither 90% confidence that the flaw rate is 6.5%.

This method is a good one for the original PG&E sample calculation. Disadvantages of this method need for completely sampling for all welds in order for the method to be

3 John W. Sargent, Sampling Techniques, John Wiley and Sons, (1977) p. 5

Official Use Only

Official Weld Use Only

sampling plan and comprehensive approach potential advantages and disadvantages of the present

The statistical approach in the assumptions of the sample size calculation, but data points in the anticipated low rate of weld defects. A sample size of the the give a 95% confidence 5% defect rate with 54 samples observed in a welded assumption is key for this analysis, and does not plan. An alternative that assumes a 10% defect rate is a flaw for any section of 48 welds. 5 samples observed flawed welds to conclude with 95% confidence rate for improperly inspected welds is no greater than

In the context of the the approach, is strictly rigorous; random sampling is not being carried out advisable in this case. Although the strategy of inspecting radiographic records violates the assumptions of both approaches, the results are likely to be conservative

Of potentially greater concern is the 5% upper bound records provided in the installation and discussions with subject matter experts, one would not expect to see that had never been inspected. The bound may therefore However, purely statistical approaches would require exhaustive substantially lower bounds. This is due to the fact approaches do not take into account partial information form of complete inspection data. Given that even an carries some information about weld quality, there is a rate could be more effectively by carefully analyzing the inspection data along with weld quality information from This is a problem. The authors consider most suitable problem. The strategy used out in parallel with the axis welds, and the likely benefits assessed based on quickly. The analysis is complete, the potential need for additional