

From: Doll, Laura  
Sent: 3/13/2014 10:42:22 PM  
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Shori, Sunil (sunil.shori@cpuc.ca.gov) (sunil.shori@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov); Tyrrell, Denise (denise.tyrrell@cpuc.ca.gov) (denise.tyrrell@cpuc.ca.gov); Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov); 'Mike Robertson' (michael.robertson@cpuc.ca.gov)  
Cc: Singh, Sumeet (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=S1ST56905772); Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)  
Bcc:  
Subject: Repair work occurring on Line 101 in [Redacted] tonight

Good evening –

This evening while PG&E crews were performing work to facilitate the upgrade of a section of Line 101 for pigging, a valve control fitting that was being installed resulted in a leak. We are instituting immediate repairs given that the leak is on the transmission system.

The line will be closed in and blown down to make safe repairs tonight.

The location of the venting to blow down the line is at [Redacted]  
[Redacted] It will begin between 11:00 pm and 1:00 am and will last about 30 minutes, with anticipated noise and associated odor release.

Officials in both [Redacted] have been notified, including police/fire dispatch and Mayor Maltbie..

While this is not a reportable event, we wanted you to be aware that this work is underway this evening, and we will follow up with a courtesy notification that includes additional details tomorrow.

Laura