



Redacted

Redacted

Redacted

March 12, 2014

Elizaveta Malashenko, Deputy Director  
Safety and Enforcement Division  
California Public Utilities Commission  
505 Van Ness Avenue  
San Francisco, CA 94102

Re: Courtesy Notification of a Safety-Related Condition on Distribution  
Feeder Main 1816-01 in Aptos

Dear Ms. Malashenko,

On March 7, 2014, a redwood tree fell on the Distribution Feeder Main (DFM) 1816-01, causing damage to the normally-exposed 10-inch pipeline along [Redacted]. There was no release of gas. This Safety-Related Condition will be eliminated by replacing a section of the pipeline on Wednesday March 12, 2014, and is therefore not required to be reported to PHMSA per CFR §191.23(b)(4). However, in keeping with our commitment to transparency, we wanted to take this opportunity to notify you of this event.

DFM 1816-01 has a Maximum Allowable Operating Pressure (MAOP) of 303 psig and is a single transmission pipeline serving the [Redacted] area. The fallen redwood tree downed electric primary wires. PG&E electric crews observed the tree lying on the gas pipe and called gas employees to investigate. Upon discovery of the damage to the pipeline, the pressure in the pipeline was lowered to 180 psig, and additional compressors were placed at the High Pressure Underground Holder in [Redacted]. PG&E's Pipeline Engineering and General Construction departments have been working around the clock to install an underground replacement section of pipeline on the opposite side of [Redacted]. The replacement pipe will be tied in on March 12, 2014 and the damaged pipe will be deactivated and removed. Pressure will be restored to a normal operating pressure of 285 psig after the new pipe is in service. There is no interruption of gas service anticipated.

Sincerely,

/S/

Redacted

Cc: Dennis Lee, CPUC  
Mike Robertson, CPUC

Redacted  
Laura Doll, PG&E  
Bill Gibson, PG&E  
Sumeet Singh, PG&E