From: Doll, Laura

Sent: 3/14/2014 6:18:20 AM

To: michael.robertson@cpuc.ca.gov (michael.robertson@cpuc.ca.gov);

elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); paul.clanon@cpuc.ca.gov (paul.clanon@cpuc.ca.gov); sunil.shori@cpuc.ca.gov

(sunil.shori@cpuc.ca.gov); terrie.prosper@cpuc.ca.gov (terrie.prosper@cpuc.ca.gov); denise.tyrrell@cpuc.ca.gov

(denise.tyrrell@cpuc.ca.gov)

Cc: Singh, Sumeet

(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=S1ST56905772); Cherry,

Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)

Bcc:

Subject: RE: MORNING UPDATE on Repair work occurring on Line 101 in Redacted

Work continued through the night and the venting/blowdown process is now expected to occur around 7:00 am.

We have received a few media calls, and PGE communications staff are onsite.

Laura

From: Doll, Laura

Sent: Thursday, March 13, 2014 10:42 PM

To: Tyrrell, Denise (denise.tyrrell@cpuc.ca.gov) <denise.tyrrell@cpuc.ca.gov>; elizaveta.malashenko@cpuc.ca.gov <elizaveta.malashenko@cpuc.ca.gov>; 'Mike Robertson' <michael.robertson@cpuc.ca.gov>; Shori, Sunil (sunil.shori@cpuc.ca.gov) <sunil.shori@cpuc.ca.gov>; Terrie D.' 'Prosper (terrie.prosper@cpuc.ca.gov) <terrie.prosper@cpuc.ca.gov>; Clanon, Paul

<paul.clanon@cpuc.ca.gov>

Cc: Singh, Sumeet; Cherry, Brian K

Subject: Repair work occurring on Line 101 in Redacted tonight

Good evening –

This evening while PG&E crews were performing work to facilitate the upgrade of a section of Line 101 for pigging, a valve control fitting that was being installed resulted in a leak. We are instituting immediate repairs given that the leak is on the transmission system.

The line will be closed in and blown down to make safe repairs tonight.

The location	of the venting to blow down the	line is at Redacted
Redacted	It will begin between 11:00 pm and 1:00 am and will last about 30 minutes, with	
anticipated n	noise and associated odor release.	
	both Redacted I Mayor Maltbie	have been notified, including police/fire
While this is not a reportable event, we wanted you to be aware that this work is underway this evening, and we will follow up with a courtesy notification that includes additional details tomorrow.		
Laura		