

From: Cherry, Brian K
Sent: 3/17/2014 7:20:22 AM
To: Denise Tyrrell (denise.tyrrell@cpuc.ca.gov); Liza Malashenko (elizaveta.malashenko@cpuc.ca.gov); Paul Clanon (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fwd: A Message from Ed Halpin: DCP Unit 1 Status

Brian K. Cherry
PG&E Company
VP, Regulatory Relations
77 Beale Street
San Francisco, CA. 94105
(415) 973-4977

Begin forwarded message:

From: DCP Unit 1 Status <DCPUnit1Status@pge.com>
Date: March 16, 2014 at 8:21:40 PM PDT
To: Officers - All <AllPGEOfficers@exchange.pge.com>
Cc: "Halpin, Ed" <E1H8@pge.com>, "Allen, Barry" <BSA8@pge.com>, [Redacted]
Subject: A Message from Ed Halpin: DCP Unit 1 Status

PG&E Officers;

The purpose of this communication is to make you aware that we are in the process of ramping Unit 1 off-line—after safely and successfully today reaching 93 percent power—due to a reactor coolant pump seal that was not operating as it is designed.

The seal, which was installed in 2012, was not worked on during 1R18. Installation of the new seal will take approximately 12 days to complete. This evolution also will include completion of a root cause analysis. While disappointed, our team is engaged, aligned and moving to action in a safe and methodical manner.

Please find below a high-level update on current plant status.

Unit 1:

- Unit 1 is ramping to Mode 5.

Unit 2:

- Unit 2 is safely operating at 100 percent power with no major challenges.

We will continue to update you throughout this evolution with important milestones. If you have any questions or concerns, you are welcome to reach out to me at your convenience.

Thank you for your support.

Ed