



Brian K. Cherry  
Vice President  
Regulatory Relations

Pacific Gas and Electric Company  
77 Beale St., Mail Code B10C  
P.O. Box 770000  
San Francisco, CA 94177

Fax: (415) 973-7226

March 6, 2014

Paul Clanon  
Executive Director  
California Public Utilities Commission  
505 Van Ness Avenue  
San Francisco, CA 94102

Subject: Class "H" Circuit on North Side of Kamm Avenue, Carruthers, CA.

Dear Mr. Clanon:

In accordance with General Order 95, Rule 31.3 - Avoidance of Conflicts and Crossings, Pacific Gas and Electric Company (PG&E) hereby provides notice that PG&E proposes to install a new overhead 12.47 KV line in Carruthers California on the north side of Kamm Avenue from the intersection of Blythe and Kamm to the intersection of Marks and Kamm. The new 12.47 KV line will run parallel to an existing line on the south side of Kamm Avenue thereby occupying both sides of the thoroughfare.

As required by Rule 31.3, we enclose (1) description of the route and configuration of the lines" and (2) "copies of letters showing mutual consent for such occupancy by all pole using line operators having service areas in the general vicinity of the length of thoroughfare concerned."

We would appreciate receiving an acknowledgement of this letter at your earliest opportunity.

Sincerely,

Brian K. Cherry  
VP, Regulatory Relations

Attachment

cc: Raymond Fugere, Safety and Enforcement Division