



**Business Intelligence Center of Excellence**

# CC&B Online Query

Gen Order Gas Exist Elec New Elec Smart Meter Complex Elec Gas Leak EC / Damaged Equip

Code Description Job Code Field Activity Code Completion Code Hazard Code

**Parameter(s):**

Field Order ID: 1653216153 Taken By: Redacted Time Taken: 19:43 Rescheduled By:  
 Premise ID: 1653216499 Date Taken: 4/25/11 Status: Completed

**Customer Information**

Account ID: 0903364653  
 Hm Ph:  
 Bus Ph:  
 Cont Ph: Redacted  
 Name:  
 Address:  
 City:

**Premise Information**

Prem Type: RES  
 Bus Activity:  
 Home Area: DJCH101  
 Sub Area: DJCS104  
 Check Digit:  
 SL:  
 LS:  
 Gas Sp Id: 1653216410  
 Elec Sp Id:  
 MtrRd Route: SJC35SM

**New Business/ Disconnect-Reconnect**

Contractor:  
 Contractor Ph:  
 Contractor Waiting:  
 Job Owner:  
 Job Owner Ph:  
 Site Ready:

**Completion Information**

Job Code: 4180 - G Unspecified-Outside  
 Fld Act Type 1: GASUNSPO Comp Code 1: 4130 - G Leak-Outside-Full Leak Inv  
 Fld Act Type 2: Comp Code 2: -  
 Fld Act Type 3: Comp Code 3: -  
 Fld Act Type 4: Comp Code 4: -  
 FAS Priority: 1  
 MIR:  
 OEC:

**PM Information**

PM Order:  
 PM Operation:

**Order Dates/Misc.**

Date Wanted: 4/25/11  
 App Start Time: 08:00  
 App End Time: 20:00  
 Order Exp Date: 4/25/11  
 Dispatcher ID: 2APJDO9

**New Hazards / Surveys / Misc.**

New Hazard Code 1: -  
 New Hazard Code 2: -  
 New Hazard Code 3: -  
 Survey 1:  
 Survey 2:  
 Survey 3:  
 Call Ahead Attempt:  
 Call Ahead Success:  
 Return To Record:  
 Service Rpt: Y

Check Digit:  
 Tot Amt Owing:  
 Cash Only Flag:

**Technician Information:**

Tech ID: D1GCAV3  
 Comp Date/Time: 4/25/11 9:51 PM  
 Dispatched Time: 19:47  
 Acknwldg Time:  
 En Route Time: 19:53  
 On Site Time: 20:08

**Service History / Existing Hazards**

Service Hist 1: 12-23-2009 GASLEAKH  
 Service Hist 2: 09-02-2010 C-TEST  
 Hazard Code 1: 19 - Other Gas  
 Hazard Code 2: -  
 Hazard Code 3: -  
 Hazard Date 1: 12/23/09  
 Hazard Date 2:  
 Hazard Date 3:

**Cancel Information**

User ID:  
 Rsn Code:  
 Code Desc:

**Attachments**

# of Attachments:





---

**Parameter(s):**

<b>Field Order ID:</b>	1653216153	<b>Taken By:</b>	Redacted	<b>Time Taken:</b>	19:43
<b>Premise ID:</b>	1653216499	<b>Date Taken:</b>	4/25/11	<b>Status:</b>	Completed

---

**CSR Remarks:**

MEET SUPER Redacted

**EMR Ord Detail:**

BEWARE OF TENANT-- collie

**EMR Completion:**

**Dispatcher:**

**General:**

0.60 CFH A.F...FULL SHUT DOWN PERFORMED..HSELINE HELD..0 CFH..USED CGI SENSIT GOLD FOR SWEEPS..OUTSIDE

**Extended:**

SWEEP 0%LEL...INSIDE SWEEP 0%LEL...CKD APPLS FOR SAFE OPERATION...ADVISED ON FAF FILTER..ALSO ADVISED ON SMALL WATER LEAK ON TOP OF WATER HEATER...NO OTHER GAS APPLS IN HSE..ON CALL SUPERVISOR Redacted ALSO ONSITE...CUST WAS IRATE UPON ARRIVAL...SEEMS OK AFTER SHUT DOWN...

**Cancel Notes:**