

From: Doll, Laura
Sent: 4/8/2014 4:07:13 PM
To: pac@cpuc.ca.gov (pac@cpuc.ca.gov); eim@cpuc.ca.gov (eim@cpuc.ca.gov);
terrie.prosper@cpuc.ca.gov (terrie.prosper@cpuc.ca.gov);
denise.tyrrell@cpuc.ca.gov (denise.tyrrell@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fw: CPUC Reportable Incident - [Redacted] San Francisco

Fyi

From: [Redacted]
Sent: Tuesday, April 08, 2014 04:03 PM
To: UO EP Gas Incident Notify
Cc: [Redacted] Truong, Chanh; [Redacted]
Subject: CPUC Reportable Incident - [Redacted] San Francisco

R
e
d
a
c
t

At approximately 1300 hours a third party contractor, [Redacted] Construction, working for the City of San Francisco struck a 4-inch plastic distribution main while excavating to install new sewer laterals. The contractor was unable to produce a USA ticket on site, but there are marks on the ground and the marks correctly identify the location of the main. PG&E was notified of this dig-in at 1316 hours, company personnel were on site at 1329 hours and the gas was shut off at 1417 hours. Seven services lost gas supply. There were no injuries, no fatalities and damages are less than \$50,000. Estimated time of restoration is 1730 hours. This incident is reportable to the CPUC due to the presence of media on site.

Please let me know if you have any questions regarding this incident.

[Redacted]

PG&E - Gas Operations, Regulatory Compliance

4420F, 6111 Bollinger Canyon Rd., San Ramon, CA 94583
w: (925) 328-5756

[Redacted]