




From: Doll, Laura
Sent: 4/3/2014 10:45:43 AM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov); Tyrrell, Denise (denise.tyrrell@cpuc.ca.gov) (denise.tyrrell@cpuc.ca.gov); Terrie D. 'Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: SF Divisadero & Pine Dig In

update


From: 
Sent: Thursday, April 03, 2014 10:43 AM
To: BAR GAS_Update
Subject: RE: SF Divisadero & Pine Dig In


Contractor M-Squared was the damaging contractor, struck 1" plastic with an excavator. Crew digging over svc now to squeeze, should have blow stopped at approx 10:55. External Communication heading out to speak to media. No known evacuations at this time.

Gas Superintendent – San Francisco & Peninsula Divisions

Operations Maintenance & Construction



From: 
Sent: Thursday, April 03, 2014 10:36 AM
To: BAR GAS_Update
Subject: SF Divisadero & Pine Dig In

At approximately 10:07, we received a report of a dig in at 1910 Divisadero called in by SFFD. SFFD closed off the street between Pine and California, media is on site. Gas crew is on site assessing the damage. More to follow.

Redacted

Gas Superintendent – San Francisco & Peninsula Divisions

Operations Maintenance & Construction

Redacted