

From: Doll, Laura
Sent: 4/28/2014 3:25:05 PM
To: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Clanon, Paul (paul.clanon@cpuc.ca.gov); kenneth.bruno@cpuc.ca.gov (kenneth.bruno@cpuc.ca.gov); Tyrrell, Denise (denise.tyrrell@cpuc.ca.gov) (denise.tyrrell@cpuc.ca.gov); Terrie D.' Prosper (terrie.prosper@cpuc.ca.gov) (terrie.prosper@cpuc.ca.gov)
Cc:
Bcc:
Subject: [Redacted] Update at 1500

This incident was a contractor dig-in.

Appears that the repairs will be done by 5:00 today.

From: [Redacted]
Sent: Monday, April 28, 2014 3:04 PM
To: [Redacted] CCR Gas Update; [Redacted]
Cc: Gas Incident GEP; [Redacted]
Subject: RE: Dig-in [Redacted] Update at 1500

Update at 1500 April 28th

Incident

The incident did occur at the [Redacted] Police and Fire are no longer on scene.

Current Action

PSS [Redacted] Discussed operation of main valves, and implications with SFFD Captain/IC. He was very good to work with and has more complete understanding of distribution mains and valves. The USA marks lead right from the strike to the valve. The strike was between the welder's truck and the nose of the crew truck.

Valves 1151 and 879 are closed. Restoration is underway. Gas will be restored to the customer at 1700. T&R was on scene with the customer. [Redacted] is the new Ops Chief on scene as of 1430.

Customer Impact

One customer lost service. Service will be restored at 1700.