

From: [Redacted]
Sent: 5/9/2014 5:31:01 PM
To: 'Bruno, Kenneth' (kenneth.bruno@cpuc.ca.gov)
Cc: elizaveta.malashenko@cpuc.ca.gov (elizaveta.malashenko@cpuc.ca.gov); Lee, Dennis M. (dennis.lee@cpuc.ca.gov); Cauguiran, Aimee (aimee.cauguiran@cpuc.ca.gov); Tong, Kan Wai (kanwai.tong@cpuc.ca.gov); [Redacted]
[Redacted] Gibson,
Bill (Codes) (/o=PG&E/ou=Corporate/cn=Recipients/cn=WLG3); [Redacted]
[Redacted] Ramaiya, Shilpa
R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd); Shori, Sunil (sunil.shori@cpuc.ca.gov) (sunil.shori@cpuc.ca.gov)

Bcc:

Subject: RE: Smith-Blair manufacturer warning

Mr. Bruno,

Attached find the response to your request.

Sincerely,

[Redacted]

PG&E - Gas Operations, Regulatory Compliance
4420F, 6111 Bollinger Canyon Rd., San Ramon, CA 94583

[Redacted]

-----Original Message-----

From: Bruno, Kenneth [mailto:kenneth.bruno@cpuc.ca.gov]
Sent: Wednesday, April 30, 2014 7:55 AM
To: bob.stoltz@swgas.com; [Redacted] remove
Cc: Lee, Dennis M.; Cauguiran, Aimee; Tong, Kan Wai
Subject: Smith-Blair manufacturer warning

Please see the attached manufacturer warning letter regarding the use of Smith-Blair repair clamps on HDPE and MDPE pipes. Smith-Blair, Inc. does not recommend the use of its repair clamps in any application on polyethylene pipe containing natural gas. Please check your respective systems and let me know by May 9, 2014 if these fittings are present in your respective natural gas systems or inventory, and if applicable, your plan for replacement. Please let me know if you have any questions.

Thank you,

Kenneth Bruno
Acting Program Manager
Gas Safety & Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission
Office: (415) 703-5265
Cell: (415) 852-2936

