

From: Sandoval, Catherine J.K.
Sent: 6/26/2014 8:45:54 PM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7);
Baker, Amy C. (amy.baker@cpuc.ca.gov); Katague, Ditas
(ditas.katague@cpuc.ca.gov)

Cc:

Bcc:

Subject: Sparking PG&E electric line by [Redacted]

Brian, I want to report a sparking PG&E electric line by the [Redacted]
[Redacted], San Francisco, California, that seems triggered by dense fog. [Redacted] near the
[Redacted] On Tuesday night as dense fog rolled up the hill, I saw sparks at the top of the
pole and saw an arch. On Wednesday it was still sparking in denser fog but not as frequently
and I did not see any arching. I've read that dense fog is associated with sparks, especially if the
line is dirty. This seems to occur at night. I observed it between 9:30-10:30 pm at the pole right
outside the driveway to the [Redacted] Though PG&E should check it out.
Thanks, Commissioner Sandoval

Sent from my Verizon Wireless 4G LTE Smartphone

SB_GT&S_0519983